

OHA - Drinking Water Services – Turbidity Monitoring Report
Conventional or Direct Filtration

County: Polk

Name: City of Dallas

ID #41: 00248

WTP: Dallas

Month/Year: July 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.059	.061	.066	.061	.067	.060	.067
2	.061	.060	.061	.061	.062	.061	.062
3	.067	.061	.061	.061	.061	.059	.067
4	.061	.061	.061	.062	.061	.062	.062
5	.061	.061	.061	.065	.061	.061	.065
6	.061	.061	.061	.061	.061	.061	.061
7	.061	.059	.061	.061	.062	.062	.062
8	.060	.062	.060	.061	.062	.060	.061
9	.060	.059	.061	.061	.061	.062	.062
10	.061	.059	.061	.060	.086	.061	.086
11	.061	.059	.061	.061	.061	.062	.062
12	.062	.067	.061	.061	.062	.061	.067
13	.062	.059	.061	.061	.062	.062	.062
14	.062	.061	.061	.062	.061	.062	.062
15	.062	.061	.061	.061	.061	.061	.071
16	.061	.061	.066	.061	.080	.062	.080
17	.061	.061	.061	.065	.068	.062	.068
18	.061	.061	.061	.060	.062	.062	.062
19	.062	.059	.061	.064	.061	.061	.064
20	.061	.061	.067	.058	.067	.068	.068
21	.061	.061	.061	.067	.061	.061	.068
22	.067	.061	.061	.061	.065	.065	.067
23	.061	.061	.061	.061	.061	.061	.061
24	.061	.061	.061	.062	.062	.061	.062
25	.061	.061	.061	.061	.061	.062	.062
26	.061	.061	.061	.061	.086	.061	.086
27	.060	.061	.061	.062	.061	.059	.062
28	.061	.061	.061	.061	.061	.066	.066
29	.061	.061	.059	.061	.061	.062	.062
30	.067	.061	.067	.061	.062	.061	.067
31	.061	.061	.067	.074	.062	.064	.074

Conventional or Direct Filtration Monthly Summary 95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? Yes / No All the 4-hour turbidity readings $\leq$ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes / No All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? Yes / No	
Notes:		PRINTED NAME: Jason Anderson SIGNATURE: <i>Jason Anderson</i> DATE: 8/4/25 PHONE #: (503) 623-2175 CERT #: 7030	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

Name:

City of Dallas

ID #41:

00248

WTP-: Month/Year:

July 2025

Log Requirement
(Circle One): 0.5 (1.0)

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/0740	1.29	112	145	20.4	7.38	23	Y	3439.5
2/0755	1.34	112	150	20.3	7.24	23	Y	3430.6
3/0820	1.32	112	148	19.5	7.27	31	Y	3277.6
4/0950	1.34	112	150	19.0	7.30	31	Y	3157.7
5/0955	1.44	112	161	17.5	7.42	31	Y	3147.5
6/0930	1.22	112	136	18.2	7.30	31	Y	3208.9
7/0835	1.39	112	156	19.4	7.16	31	Y	3144.6
8/0830	1.22	112	137	20.3	7.23	23	Y	3256.0
9/0815	1.36	112	152	20.5	7.22	23	Y	392.8
10/0825	1.36	112	152	19.8	7.26	31	Y	3127.6
11/0800	1.27	112	142	19.4	7.28	31	Y	3152.9
12/0930	1.33	112	149	20.5	7.29	23	Y	3253.5
13/0930	1.21	112	136	21.5	7.26	23	Y	3522.4
14/0820	1.25	112	140	22.2	7.26	23	Y	3456.6
15/0750	1.21	112	136	21.4	7.23	23	Y	3366.7
16/0800	1.10	112	123	21.5	7.27	23	Y	3632.3
17/0742	1.11	112	124	21.0	7.21	23	Y	3603.4
18/0820	1.09	112	122	21.0	7.25	23	Y	3294.6
19/09:25	1.13	112	126	20.5	7.16	28	Y	3284.9
20/08:45	.96	112	107	20.2	7.32	27	Y	3284.9
21/1030	1.12	112	125	19.0	7.31	31	Y	3160.4
22/0930	1.20	112	134	19.2	7.39	31	Y	3176.8
23/1230	1.18	112	132	20.1	7.26	23	Y	3156.4
24/0730	1.08	112	120	20.8	7.31	22	Y	3287.5
25/0850	1.01	112	113	20.8	7.32	22	Y	3214.9
26/1024	1.14	112	133	19.7	7.28	22	Y	3225.4
27/0600	1.07	112	119	19.4	7.34	22	Y	3208.2
28/0955	1.33	112	149	19.7	7.35	31	Y	3120
29/0820	1.26	112	141	19.5	7.34	31	Y	3280.3
30/0815	1.17	112	131	19.8	7.28	31	Y	3263.8
31/0830	1.26	112	141	20.4	7.30	23	Y	3269.7

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350