

OHA - Drinking Water Services – Turbidity Monitoring Report
Conventional or Direct Filtration

County: Polk

Name: City of Dallas

ID #41: 00248

WTP: Dallas

Month/Year: Aug 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.061	.061	.061	.068	.062	.067	.068
2	.061	.061	.061	.061	.078	.067	.078
3	.067	.000	.061	.061	.066	.065	.067
4	.065	.067	.061	.061	.061	.061	.067
5	.065	.065	.066	.061	.061	.061	.066
6	.060	.062	.066	.067	.066	.067	.067
7	.070	.067	.065	.065	.066	.065	.070
8	.067	.061	.061	.065	.067	.068	.068
9	.067	.073	.061	.065	.065	.068	.073
10	.067	.068	.093	.061	.065	.068	.093
11	.062	.067	.067	.066	.068	.068	.068
12	.061	.065	.067	.068	.066	.068	.068
13	.067	.061	.068	.073	.070	.081	.090
14	.073	.067	.067	.061	.071	.086	.086
15	.079	.065	.067	.067	.077	.074	.077
16	.067	.067	.067	.073	.099	.105	.105
17	.086	.065	.068	.067	.084	.097	.097
18	.098	.073	.068	.067	.071	.149	.149
19	.079	.084	.073	.086	.099	.120	.120
20	.124	.074	.109	.077	.124	.136	.136
21	.095	.067	.061	.073	.077	.108	.108
22	.093	.080	.077	.073	.088	.121	.121
23	.078	.080	.072	.068	.083	.112	.112
24	.073	.071	.065	.073	.101	.101	.101
25	.074	.067	.071	.073	.093	.105	.105
26	.073	.068	.066	.091	.078	.111	.111
27	.080	.067	.067	.068	.074	.090	.090
28	.073	.067	.067	.067	.068	.074	.074
29	.072	.067	.067	.083	.072	.093	.093
30	.072	.078	.067	.067	.079	.084	.084
31	.073	.074	.067	.071	.099	.086	.099

Conventional or Direct Filtration Monthly Summary 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: Jason Anderson SIGNATURE: <i>Jason Anderson</i> DATE: 9/3/25 PHONE #: (503) 623-2175 CERT #: 7030	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effic. (OAR 333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - *Giardia* Inactivation

Name:

City of Dallas

ID #41:

00248

WTP-:

Month/Year:

AUG 2025

Log Requirement

(Circle One): 0.5 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/0730	1.19	112	133	20.9	7.21	23	Y	3230.5
2/1050	1.10	112	123	20.4	7.23	22	Y	3222.2
3/1945	1.08	112	120	20.1	7.33	22	Y	3263.8
4/0845	1.29	112	144	19.0	7.13	31	Y	3194.1
5/0800	1.20	112	134	18.9	7.28	31	Y	3157.4
6/1045	1.25	112	140	19.3	7.29	31	Y	2913.3
7/0830	1.11	112	124	19.1	7.26	31	Y	2779.7
8/0820	1.17	112	131	19.0	7.33	31	Y	3133.4
9/0930	1.24	112	138	19.3	7.22	31	Y	3284.9
10/1000	1.08	112	120	20.3	7.23	22	Y	3317.1
11/0825	1.17	112	131	21.7	7.03	23	Y	3557.0
12/0755	1.34	112	151	22.1	7.21	23	Y	3538.0
13/0745	1.28	112	143	21.9	7.18	23	Y	3597.8
14/0830	1.38	112	155	21.6	7.13	23	Y	3540.0
15/0815	1.21	112	135	21.4	7.14	23	Y	3311.7
16/0910	1.36	112	152	20.6	7.29	23	Y	3289.7
17/0945	1.16	112	130	19.8	7.36	31	Y	3205.9
18/0815	1.20	112	134	20.0	7.32	23	Y	3389.2
19/0800	1.40	112	156	19.5	7.29	31	Y	3508.4
20/0841	1.36	112	152	19.8	7.23	31	Y	3401.4
21/0805	1.31	112	147	19.9	7.34	31	Y	3190.7
22/0855	1.11	112	124	20.4	7.25	23	Y	3153.1
23/0840	1.14	112	127	20.7	7.30	22	Y	3154.3
24/1030	1.25	112	140	20.4	7.39	23	Y	3166.4
25/0865	1.17	112	131	21.9	7.22	23	Y	3169.4
26/1115	1.33	112	148	21.2	7.28	23	Y	3099.9
27/0900	1.30	112	145	21.9	7.24	23	Y	2923.0
28/0836	1.24	112	138	21.0	7.23	23	Y	2674.9
29/1128	.88	112	98	20.4	7.39	22	Y	2671.4
30/0900	1.36	112	152	20.1	7.29	28	Y	2635.8
31/0830	1.11	112	124	19.3	7.31	31	Y	2648.6

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350