


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County:

Douglas

System Name:	Milo Academy	ID#:	41 00250	WTP - :		Month/Year:	January-21
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.09	0.08	0.08	0.07	0.08	0.07	0.09
2	0.09	0.18	0.20	0.14	0.09	0.09	0.20
3	0.08	0.08	0.08	0.09	0.08	0.07	0.09
4	0.07	0.07	0.07	0.07	0.07	0.07	0.07
5	0.07	0.06	0.06	off	0.10	0.09	0.10
6	0.08	0.08	0.08	0.07	0.07	0.09	0.09
7	0.13	0.21	0.15	0.11	0.10	0.09	0.21
8	0.08	0.08	0.07	0.08	0.08	0.09	0.09
9	0.17	0.20	0.15	0.09	0.09	0.08	0.20
10	0.08	0.09	0.12	0.21	0.17	0.08	0.21
11	0.13	0.13	0.11	0.10	0.10	0.09	0.13
12	0.08	0.08	0.07	0.13	0.18	0.13	0.18
13	0.10	0.09	0.08	0.07	0.07	0.07	0.10
14	0.07	0.07	0.07	0.07	0.07	0.07	0.07
15	0.11	0.14	0.12	0.27	0.19	0.08	0.27
16	0.08	0.08	0.09	0.09	0.13	0.20	0.20
17	0.18	0.08	0.08	off	off	0.19	0.19
18	off	off	off	off	off	off	off
19	off	off	off	off	off	0.26	0.26
20	off	off	off	off	off	0.27	0.27
21	0.16	0.15	0.16	0.18	0.19	0.11	0.19
22	0.09	0.08	0.08	0.08	0.09	0.09	0.09
23	0.14	0.18	0.28	0.17	0.10	0.10	0.28
24	0.09	0.09	0.09	0.09	0.09	0.08	0.09
25	0.09	0.08	0.08	0.09	0.08	0.08	0.09
26	0.08	0.08	0.21	0.13	0.10	0.09	0.21
27	0.09	0.08	0.08	0.08	0.07	0.08	0.09
28	0.14	0.14	0.10	0.09	0.14	0.11	0.14
29	off	off	0.23	0.13	0.14	0.10	0.23
30	0.10	0.13	0.14	0.14	0.13	0.11	0.14
31	0.10	0.13	0.15	0.17	0.18	off	0.18

95% of daily turbidity readings ≤ 0.3 NTU? <span style="float: right;">Yes / No</span> All daily turbidity readings ≤ 1 NTU? <span style="float: right;">Yes / No</span> All turbidity readings < IFE <sup>2</sup> triggers <span style="float: right;">Yes / No</span>	CT's met everyday? (see back) <span style="float: right;">Yes / No</span>	All Cl2 residual at entry point ≥ 0.2 mg/l? <span style="float: right;">Yes / No</span>
---	---	---

Notes:	PRINTED NAME: Jeff Miller SIGNATURE:  PHONE #: ( 541 ) 825-3200 DATE: 2/10/21 CERT #: 8052
--------	--

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Jan-21

System Name: Milo Academy		ID#: 41 00250		WTP -:		Disinfection Giardia Log Inactiv:		1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 14:30	0.53	307	162.7	9.0	7.2	41.9	yes	31
2/ 15:00	0.50	307	153.5	9.1	7.2	41.5	yes	31
3 / 15:15	0.51	307	156.6	9.3	7.3	42.5	yes	31
4 / 16:00	0.48	307	147.4	9.9	7.5	43.6	yes	31
5 / 10:45	0.65	307	199.6	8.7	7.3	44.9	yes	31
6 / 14:45	0.48	307	147.4	9.7	7.1	38.4	yes	31
7 / 14:00	0.47	307	144.3	9.2	7.1	39.7	yes	31
8 / 10:45	0.47	307	144.3	9.0	7.3	43.1	yes	31
9 / 15:00	0.47	307	144.3	9.0	7.3	43.1	yes	31
10/ 16:00	0.46	307	141.2	9.1	7.2	41.3	yes	31
11/ 17:00	0.47	307	144.3	9.2	7.2	41.1	yes	31
12 / 11:00	0.45	307	138.2	10.0	7.2	38.9	yes	31
13 / 10:30	0.55	307	168.9	11.3	7.1	34.9	yes	31
14 / 10:30	0.47	307	144.3	9.5	7.3	41.7	yes	31
15 / 10:45	0.57	307	175.0	9.2	7.3	43.0	yes	31
16 / 10:45	0.56	307	171.9	9.1	7.4	44.8	yes	31
17/ 10:30	0.55	307	168.9	9.5	7.5	45.2	yes	31
18 / 10:45	0.56	307	171.9	9.6	8.1	55.6	yes	31
19 / 10:45	0.64	307	196.5	8.3	8.1	61.3	yes	31
20 / 15:15	0.72	307	221.0	7.3	7.3	49.6	yes	31
21 / 10:45	0.71	307	218.0	7.5	7.7	56.4	yes	31
22 / 10:30	0.50	307	153.5	8.5	7.9	55.3	yes	31
23 / 10:30	0.49	307	150.4	8.0	7.9	57.2	yes	31
24 / 10:30	0.35	307	107.5	7.5	7.9	58.2	yes	31
25 / 10:45	0.29	307	89.0	6.8	7.9	60.6	yes	31
26 / 10:45	0.33	307	101.3	6.5	7.8	59.9	yes	31
27 / 18:00	0.37	307	113.6	7.6	7.9	57.9	yes	31
28 / 10:45	0.37	307	113.6	7.0	8.0	62.6	yes	31
29 / 10:45	0.38	307	116.7	7.2	8.0	61.8	yes	31
30 / 10:45	0.39	307	119.7	7.2	8.0	61.9	yes	31
31 / 10:45	0.41	307	125.9	7.3	8.0	61.6	yes	31

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012