


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy		ID#: 41 00250			WTP - :		Month/Year: October-21
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.13	0.13	0.14	0.20	0.25	0.13	0.25
2	0.13	0.13	0.13	0.14	0.21	0.13	0.21
3	0.13	0.13	0.13	off	off	off	0.13
4	off	off	off	off	off	off	off
5	off	off	off	off	off	0.20	0.20
6	0.21	0.22	0.15	0.17	0.17	0.18	0.22
7	0.23	0.23	0.16	0.17	0.17	0.19	0.23
8	0.22	0.23	0.15	0.15	0.18	0.20	0.23
9	0.22	0.25	0.28	0.15	0.16	0.15	0.28
10	0.17	0.16	0.16	0.16	0.18	0.23	0.23
11	0.18	0.16	0.16	0.16	0.16	0.15	0.18
12	0.15	0.14	0.14	0.14	0.15	0.15	0.15
13	0.14	0.14	0.14	0.17	0.16	0.16	0.17
14	0.16	0.16	0.16	0.17	0.17	0.16	0.17
15	0.17	0.19	0.20	0.21	0.16	0.16	0.21
16	0.16	0.17	0.18	0.17	0.17	0.15	0.18
17	0.15	0.15	0.16	0.18	0.18	0.17	0.18
18	0.18	0.18	0.12	0.14	0.14	0.14	0.18
19	0.16	0.17	0.16	0.16	0.16	0.16	0.17
20	0.16	0.16	0.16	0.16	0.16	0.17	0.17
21	0.16	0.16	0.16	0.19	0.20	0.16	0.20
22	0.16	0.15	0.15	0.16	0.18	0.23	0.23
23	off	off	off	off	off	off	off
24	off	off	0.21	off	off	0.17	0.21
25	0.16	0.16	0.15	0.14	0.15	0.15	0.16
26	0.15	0.14	0.13	0.13	0.13	0.16	0.16
27	0.13	0.13	0.13	off	0.18	0.15	0.18
28	0.15	0.14	0.14	0.14	0.14	0.14	0.15
29	0.14	0.14	0.16	0.19	off	off	0.19
30	0.21	0.16	0.15	0.19	0.19	0.15	0.21
31	off	off	off	off	off	off	off

95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Jeff Miller SIGNATURE:  PHONE #: (541) 825-3200 DATE: 11/10/21 CERT #: 8052	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Oct-21

System Name: Milo Academy		ID#: 41 00250		WTP :-		Disinfection Giardia Log Inactiv:		1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 17:45	0.60	307	184.2	15.5	8.5	43.8	yes	31
2/ 18:30	0.50	307	153.5	17.0	8.5	39.2	yes	31
3/ 18:00	0.44	307	135.1	16.3	off	off	yes	31
4/ off	1.10	307	337.7	off	off	off	yes	31
5/ 18:15	1.10	307	337.7	16.7	8.5	42.8	yes	31
6/ 8:00	0.74	307	227.2	14.6	8.6	49.0	yes	31
7/ 10:45	0.55	307	168.9	13.8	8.6	50.6	yes	31
8/ 1:45	0.50	307	153.5	12.4	8.6	54.7	yes	31
9/ 19:00	0.40	307	122.8	13.7	8.6	50.1	yes	31
10/ 18:00	0.40	307	122.8	14.1	8.6	48.8	yes	31
11/ 17:30	0.58	307	178.1	12.7	8.6	54.6	yes	31
12/ 18:30	0.63	307	193.4	13.1	8.6	53.5	yes	31
13/ 4:00	0.70	307	214.9	11.1	8.6	61.1	yes	31
14/ 16:15	0.72	307	221.0	10.1	8.6	65.6	yes	31
15/ 17:45	0.74	307	227.2	10.2	8.6	65.3	yes	31
16/ 18:00	0.75	307	230.3	10.0	8.6	66.3	yes	31
17/ 6:15	0.79	307	242.5	10.5	8.6	64.4	yes	31
18/ 10:42	0.59	307	181.1	10.6	8.6	62.4	yes	31
19/ 17:45	0.55	307	168.9	10.1	8.6	64.3	yes	31
20/ 18:30	0.48	307	147.4	11.9	8.6	56.5	yes	31
21/ 18:00	0.40	307	122.8	11.4	8.6	57.9	yes	31
22/ 10:15	0.43	307	132.0	11.6	8.6	57.3	yes	31
23/ 19:00	0.43	307	132.0	12.1	8.6	55.4	yes	31
24/ 2:45	0.55	307	168.9	11.7	8.6	57.7	yes	31
25/ 20:15	0.60	307	184.2	9.6	8.6	66.9	yes	31
26/ 11:00	0.79	307	242.5	10.1	7.6	46.2	yes	31
27/ 10:00	0.60	307	184.2	10.9	7.6	42.9	yes	31
28/ 8:30	0.90	307	276.3	11.2	7.6	43.5	yes	31
29/ 9:45	0.50	307	153.5	11.7	7.6	40.2	yes	31
30/ 19:05	0.38	307	116.7	11.8	7.6	39.4	yes	31
31/ 12:30	0.30	307	92.1	10.8	7.7	43.2	yes	31

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012