

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy ID#: 41 00250 WTP - : Month/Year: March-22

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.04	0.04	0.04	0.04	0.04	0.04	0.04
2	0.04	0.04	0.04	0.04	0.04	0.04	0.04
3	0.05	0.06	0.06	off	off	off	0.06
4	0.05	0.05	0.05	0.04	0.04	0.04	0.05
5	0.04	0.04	0.04	0.04	0.13	off	0.13
6	0.05	0.05	0.06	0.05	0.05	0.04	0.06
7	0.05	0.04	0.04	0.04	0.04	0.04	0.05
8	0.04	0.04	0.04	0.05	0.06	0.08	0.08
9	0.13	0.25	0.06	0.05	0.05	0.04	0.25
10	0.04	0.04	0.04	0.04	0.04	0.04	0.04
11	0.04	0.04	0.04	0.05	0.06	0.19	0.19
12	0.07	0.06	0.04	0.04	0.04	0.04	0.07
13	0.04	0.04	0.04	off	off	off	0.04
14	off	0.06	0.04	0.04	0.04	0.04	0.06
15	0.04	0.04	0.04	0.04	0.04	0.04	0.04
16	0.04	0.04	0.09	0.15	0.09	0.05	0.15
17	0.04	0.04	0.04	0.04	0.04	0.04	0.04
18	0.04	0.04	0.04	0.04	0.04	0.04	0.04
19	0.04	0.04	0.04	0.04	0.04	0.04	0.04
20	0.04	0.04	0.04	0.05	0.10	0.25	0.25
21	0.18	0.05	0.05	0.05	0.05	0.05	0.18
22	0.04	0.04	0.04	0.04	0.05	0.05	0.05
23	0.09	0.12	0.04	0.04	0.04	0.04	0.12
24	0.04	0.04	0.04	0.05	0.24	0.07	0.24
25	0.06	0.06	0.06	off	off	off	0.06
26	off	off	off	off	off	off	off
27	off	off	off	off	off	off	off
28	off	off	off	off	off	off	off
29	off	off	off	off	0.07	0.05	0.07
30	0.05	0.05	0.05	0.05	0.04	0.04	0.05
31	0.04	0.04	0.04	0.04	0.04	0.05	0.05

95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: Jeff Miller

SIGNATURE: *[Signature]* DATE: 4/8/22

PHONE #: (541) 825-3200 CERT #: 8052

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Mar-22

System Name: Milo Academy ID#: 41 00250 WTP -: Disinfection Giardia Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 12:00	0.58	307	178.1	8.5	7.3	45.1	yes	31
2/ 9:45	0.60	307	184.2	8.5	7.3	45.2	yes	31
3/ 11:25	0.68	307	208.8	8.7	7.4	46.6	yes	31
4/ 9:16	0.70	307	214.9	7.7	7.4	50.0	yes	31
5/ 18:00	0.68	307	208.8	7.5	7.4	50.5	yes	31
6/ 10:00	0.60	307	184.2	7.2	7.3	49.3	yes	31
7/ 9:30	0.60	307	184.2	7.5	7.4	50.1	yes	31
8/ 10:45	0.58	307	178.1	5.7	7.4	56.4	yes	31
9/ 10:00	0.57	307	175.0	6.4	7.5	55.7	yes	31
10/ 11:30	0.53	307	162.7	5.7	7.5	58.1	yes	31
11/ 9:15	0.50	307	153.5	5.3	7.5	59.5	yes	31
12/ 12:00	0.50	307	153.5	5.9	7.5	57.1	yes	31
13/ 12:30	0.60	307	184.2	6.1	7.5	57.0	yes	31
14/ 18:30	0.50	307	153.5	7.9	7.5	49.9	yes	31
15/ 10:15	0.50	307	153.5	8.1	7.5	49.3	yes	31
16/ 10:00	0.50	307	153.5	7.5	7.5	51.3	yes	31
17/ 9:45	0.50	307	153.5	7.0	7.5	53.0	yes	31
18/ 9:45	0.50	307	153.5	6.8	7.5	53.8	yes	31
19/ 10:00	0.53	307	162.7	6.8	7.5	53.9	yes	31
20/ 10:30	0.50	307	153.5	6.8	7.5	53.8	yes	31
21/ 11:00	0.51	307	156.6	6.9	7.5	53.5	yes	31
22/ 11:30	0.61	307	153.5	7.6	7.5	42.4	yes	31
23/ 11:30	0.62	307	153.5	7.6	7.5	44.6	yes	31
24/ 10:00	0.60	307	184.2	9.6	7.5	45.1	yes	31
25/ 9:30	0.53	307	162.7	9.2	7.5	46.0	yes	31
off	0.41	307	off	off	off	off	yes	31
off	0.41	307	off	off	off	off	yes	31
28/ 8:36	0.40	307	122.8	10.7	7.5	41.0	yes	31
29/ 10:00	0.51	307	156.6	9.6	7.5	44.7	yes	31
30/ 11:30	0.62	307	190.3	9.6	7.5	45.2	yes	31
31/ 11:00	0.65	307	199.6	9.5	7.5	45.7	yes	31

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012