


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy ID#: 41 00250 WTP - : Month/Year: February-23

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	0.17	0.18	0.18	0.18
2	0.14	0.15	0.20	0.23	0.25	0.28	0.28
3	0.25	0.17	0.15	0.15	0.14	0.14	0.25
4	0.14	0.14	0.14	0.14	0.14	0.14	0.14
5	0.18	0.19	0.15	0.15	0.14	0.14	0.19
6	0.14	0.14	0.14	0.14	0.15	0.20	0.20
7	0.16	0.15	0.15	0.15	0.14	0.14	0.16
8	0.14	0.14	0.14	0.14	0.14	off	0.14
9	0.14	0.14	0.14	0.14	0.14	0.15	0.15
10	0.16	0.15	0.15	0.14	0.14	0.14	0.16
11	0.14	0.15	0.18	0.20	0.16	0.16	0.20
12	0.15	0.15	0.15	0.15	0.15	0.15	0.15
13	0.14	0.14	0.14	0.15	0.20	0.14	0.20
14	0.14	0.14	0.14	0.14	0.14	0.14	0.14
15	0.14	0.14	0.14	0.14	0.14	0.14	0.14
16	0.15	0.15	0.15	0.18	off	off	0.18
17	off	off	off	off	off	off	off
18	0.18	0.17	0.14	0.14	0.14	0.15	0.18
19	0.14	0.14	0.14	0.17	0.14	0.14	0.17
20	0.15	0.14	0.14	0.14	0.14	0.14	0.15
21	0.14	0.14	0.14	0.14	0.14	0.14	0.14
22	0.14	0.14	0.15	0.15	0.14	0.15	0.15
23	0.16	0.21	0.20	0.17	0.17	0.17	0.21
24	0.18	0.27	0.17	0.17	0.17	0.17	0.27
25	0.18	0.23	0.18	0.17	0.16	0.16	0.23
26	0.17	0.18	0.19	0.17	0.17	0.17	0.19
27	0.16	0.18	0.18	off	off	off	0.18
28	off	off	off	off	off	0.18	0.18
29							
30							
31							

95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		
PRINTED NAME: Jeff Miller		
SIGNATURE: 		DATE: 2/06/23
PHONE #: (541) 825-3200		CERT #: 8052

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Feb-23

System Name:	Milo Academy	ID#: 41 00250	WTP -:	Disinfection Giardia Log Inactiv:	1
--------------	--------------	---------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 12:15	0.73	307	224.1	4.1	8.0	79.6	yes	31
2/ 18:15	0.73	307	224.1	4.3	8.0	78.5	yes	31
3/ 18:45	0.78	307	239.5	6.2	8.0	69.3	yes	31
4/ 19:30	0.78	307	239.5	6.8	8.0	66.5	yes	31
5/ 19:00	0.78	307	239.5	6.4	8.0	68.4	yes	31
6/ 20:00	0.76	307	233.3	7.0	8.0	65.5	yes	31
7/ 19:00	0.72	307	221.0	6.5	8.0	67.4	yes	31
8/ 6:30	0.70	307	214.9	6.4	8.0	67.7	yes	31
9/ 16:00	0.72	307	221.0	6.0	8.1	72.4	yes	31
10/ 15:30	0.72	307	221.0	6.2	8.1	71.4	yes	31
11/ 16:00	0.74	307	227.2	6.7	8.0	66.7	yes	31
12/ 16:30	0.78	307	239.5	6.4	8.0	68.4	yes	31
13/ 16:30	0.72	307	221.0	6.5	8.1	69.9	yes	31
14/ 17:30	0.72	307	221.0	5.1	8.1	77.0	yes	31
15/ 20:00	0.72	307	221.0	4.9	8.1	78.1	yes	31
16/ 20:30	0.70	307	214.9	4.6	8.1	79.5	yes	31
17/ 14:00	0.80	307	245.6	4.7	8.1	79.9	yes	31
18/ 15:00	0.81	307	248.7	4.5	8.1	81.1	yes	31
19/ 16:30	0.73	307	224.1	4.9	8.1	78.2	yes	31
20/ 15:00	0.75	307	230.3	4.8	8.1	78.9	yes	31
21/ 16:45	0.78	307	239.5	6.3	8.1	71.4	yes	31
22/ 16:00	0.78	307	239.5	5.1	8.1	77.6	yes	31
23/ 17:00	0.69	307	211.8	4.2	8.1	81.7	yes	31
24/ 17:00	0.72	307	221.0	4.3	8.1	81.4	yes	31
25/ 17:30	0.73	307	224.1	4.5	8.0	77.5	yes	31
26/ 18:45	0.71	307	218.0	4.7	8.0	76.2	yes	31
27/ 18:00	0.75	307	230.3	4.5	8.0	77.6	yes	31
28/ 20:00	0.77	307	236.4	4.7	8.0	76.8	yes	31

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012