

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy ID#: 41 00250 WTP - : Month/Year: March-23

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.17	0.17	0.17	0.18	0.17	0.18	0.18
2	0.18	0.19	0.19	0.18	0.19	0.23	0.23
3	0.20	0.19	0.18	0.18	0.18	0.17	0.20
4	0.17	0.17	0.17	0.17	0.17	0.17	0.17
5	0.18	0.26	0.20	0.20	0.20	0.24	0.26
6	0.20	0.19	0.18	0.19	0.19	0.27	0.27
7	0.20	0.17	0.17	0.18	0.20	0.24	0.24
8	0.19	0.19	0.19	0.21	off	0.24	0.24
9	off	off	off	off	off	off	off
10	0.16	0.15	0.15	0.15	off	off	0.16
11	off	off	off	off	off	off	off
12	off	off	off	off	off	off	off
13	off	off	off	off	off	off	off
14	off	off	off	off	off	off	off
15	off	off	off	off	off	off	off
16	off	off	off	off	off	off	off
17	off	off	off	off	off	off	off
18	off	off	off	off	off	off	off
19	off	off	off	off	off	off	off
20	off	off	off	off	off	off	off
21	off	0.27	0.24	0.24	0.22	0.20	0.27
22	0.12	0.09	0.10	0.08	0.09	off	0.12
23	0.15	0.12	0.16	0.08	0.08	off	0.16
24	0.15	0.10	0.10	0.10	off	off	0.15
25	off	off	off	off	off	off	off
26	off	off	off	off	off	0.28	0.28
27	0.13	0.14	0.13	0.15	0.19	0.23	0.23
28	0.18	0.15	0.11	0.10	0.09	0.09	0.18
29	0.09	0.09	0.09	0.13	off	off	0.13
30	0.15	0.16	0.18	0.19	0.24	off	0.24
31	off	0.27	0.24	0.27	0.16	0.17	0.27

95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Jeff Miller	
	SIGNATURE: <i>[Signature]</i>	DATE: 4/10/23
	PHONE #: (541) 825-3200	CERT #: 8052

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

