


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name:	Milo Academy	ID#:	41 00250	WTP - :		Month/Year:	July-23
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.09	0.09	0.09	0.10	0.12	0.13	0.13
2	0.15	0.20	off	0.24	0.06	0.06	0.24
3	0.07	0.06	0.06	0.07	0.07	0.06	0.07
4	0.06	0.06	0.06	0.06	0.06	0.07	0.07
5	0.06	0.08	0.09	0.10	0.11	0.11	0.11
6	0.06	0.06	0.08	0.08	0.08	0.08	0.08
7	0.09	0.09	0.10	0.13	0.15	0.06	0.15
8	0.06	0.06	0.06	0.06	0.06	0.06	0.06
9	0.06	0.06	0.06	0.06	0.07	0.10	0.10
10	0.08	0.08	0.08	0.09	0.12	0.14	0.14
11	0.12	0.11	0.10	0.09	0.09	0.07	0.12
12	0.09	0.09	0.09	0.12	0.14	0.15	0.15
13	0.06	0.06	0.06	0.07	0.06	0.06	0.07
14	0.09	0.06	0.06	0.06	0.06	0.06	0.09
15	0.06	0.06	0.06	0.06	0.05	0.06	0.06
16	0.06	0.06	0.06	0.07	0.08	0.09	0.09
17	0.06	0.07	0.07	0.08	0.07	0.07	0.08
18	0.08	0.07	0.07	0.09	0.07	0.08	0.09
19	0.08	0.08	0.09	0.09	0.09	0.08	0.09
20	0.07	0.07	0.08	0.09	0.09	0.09	0.09
21	0.08	0.07	0.07	0.07	0.08	0.07	0.08
22	0.07	0.07	0.09	0.11	0.12	0.10	0.12
23	0.11	0.12	0.14	0.19	0.22	0.07	0.22
24	0.07	0.07	0.07	0.07	0.08	0.07	0.08
25	0.07	0.06	0.07	0.07	0.07	0.09	0.09
26	0.07	0.07	0.07	0.07	0.07	0.08	0.08
27	0.08	0.07	0.07	0.08	0.07	0.20	0.20
28	0.23	0.20	0.20	0.20	0.20	0.21	0.23
29	0.23	0.21	0.21	0.23	0.21	0.23	0.23
30	0.24	0.25	0.25	0.24	0.24	0.25	0.25
31	0.22	0.21	0.21	0.18	0.16	0.18	0.22

95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Jeff Miller
	SIGNATURE:  DATE: 8/10/23
	PHONE #: (541) 825-3200 CERT #:8052

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Jul-23

System Name: Milo Academy ID#: 41 00250 WTP -: Disinfection Giardia Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/ 12:00	0.68	307	208.8	14.1	8.9	56.2	yes	31
2/ 11:30	0.70	307	214.9	14.0	8.9	56.7	yes	31
3/ 18:00	0.86	307	264.0	14.0	8.9	57.7	yes	31
4/ 20:30	0.50	307	153.5	16.3	8.9	47.6	yes	31
5/ 20:45	0.35	307	107.5	17.0	8.9	44.7	yes	31
6/ 21:00	0.28	307	86.0	16.9	8.9	44.6	yes	31
7/ 18:00	0.84	307	257.9	16.0	8.9	50.5	yes	31
8/ 20:30	1.10	307	337.7	15.7	8.9	53.0	yes	31
9/ 18:00	1.50	307	460.5	15.1	8.9	57.7	yes	31
10/ 19:30	1.40	307	429.8	15.5	8.9	55.6	yes	31
11/ 21:30	0.60	307	184.2	15.9	8.9	49.4	yes	31
12/ 21:15	0.30	307	92.1	16.4	8.9	46.2	yes	31
13/ 21:15	0.44	307	135.1	17.0	8.9	45.1	yes	31
14/ 18:30	0.50	307	153.5	17.3	8.9	44.6	yes	31
15/ 22:15	0.30	307	92.1	17.7	8.9	42.4	yes	31
16/ 20:45	0.44	307	135.1	17.8	8.9	42.8	yes	31
17/ 18:45	0.80	307	245.6	17.7	8.9	44.9	yes	31
18/ 17:30	1.00	307	307.0	17.0	8.9	48.1	yes	31
19/ 21:30	0.80	307	245.6	17.8	8.9	44.6	yes	31
20/ 18:00	1.20	307	368.4	11.4	8.9	70.8	yes	31
21/ 12:30	0.74	307	227.2	15.6	8.9	51.2	yes	31
22/ 20:40	0.20	307	61.4	17.6	8.9	42.2	yes	31
23/ 19:00	0.48	307	147.4	18.0	8.9	42.4	yes	31
24/ 17:30	0.43	307	132.0	16.7	8.9	46.0	yes	31
25/ 18:15	1.20	307	368.4	17.0	8.9	49.2	yes	31
26/ 18:00	0.67	307	205.7	17.3	8.9	45.4	yes	31
27/ 19:00	0.95	307	291.7	16.9	8.9	48.1	yes	31
28/ 19:40	0.60	307	184.2	25.6	8.9	25.9	yes	31
29/ 21:30	0.40	307	122.8	25.7	8.9	25.2	yes	31
30/ 21:00	0.72	307	221.0	25.0	8.9	27.4	yes	31
31/ 17:30	0.85	307	261.0	24.0	8.9	29.7	yes	31

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012