


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas

System Name:	Milo Academy	ID#:	41 00250	WTP - :		Month/Year:	September-23
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.20	0.20	0.18	0.18	0.17	0.18	0.20
2	0.18	0.18	0.18	0.17	0.17	0.17	0.18
3	0.18	0.17	0.17	0.17	0.16	0.15	0.18
4	0.14	0.14	0.13	0.13	0.12	0.12	0.14
5	0.12	0.11	0.11	0.11	0.11	0.11	0.12
6	0.20	0.16	0.16	0.15	0.15	0.15	0.20
7	0.14	0.14	0.14	0.15	0.14	0.14	0.15
8	0.15	0.15	0.14	0.14	0.15	0.15	0.15
9	0.15	0.15	0.14	0.14	0.14	0.14	0.15
10	0.14	0.14	0.15	0.15	0.14	0.14	0.15
11	0.14	0.14	0.13	0.13	0.14	0.14	0.14
12	0.15	0.15	0.14	0.14	0.13	0.13	0.15
13	0.13	0.14	0.14	0.13	0.13	0.17	0.17
14	0.16	0.15	0.15	0.16	0.15	0.14	0.16
15	0.14	0.14	0.15	0.15	0.16	0.16	0.16
16	0.15	0.15	0.15	0.15	0.14	0.14	0.15
17	0.14	0.15	0.15	0.15	0.14	0.16	0.16
18	0.17	0.17	0.18	0.17	0.17	0.23	0.23
19	0.21	0.21	0.22	0.20	0.18	0.17	0.22
20	0.17	0.15	0.15	0.15	0.16	off	0.17
21	off	off	off	off	off	off	off
22	off	off	off	0.20	0.21	0.21	0.21
23	0.22	0.22	0.21	0.21	0.21	0.21	0.22
24	0.21	0.21	0.21	0.22	0.21	0.20	0.22
25	0.21	0.21	0.21	0.20	0.20	0.20	0.21
26	0.20	0.21	0.21	0.21	0.20	0.20	0.21
27	0.17	0.18	0.18	0.18	0.17	0.17	0.18
28	0.17	0.16	0.16	0.16	0.15	0.17	0.17
29	0.17	0.16	0.17	0.17	0.17	0.16	0.17
30	0.15	0.15	0.15	0.16	0.15	0.15	0.16
31							

95% of daily turbidity readings ≤ 0.3 NTU? All daily turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	Yes / No <input checked="" type="checkbox"/> Yes / No <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:		PRINTED NAME: Jeff Miller	
		SIGNATURE: 	DATE: 11/19/23
		PHONE #: ( 541 ) 825-3200	CERT #:8052

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Efl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Sep-23

System Name: Milo Academy ID#: 41 00250 WTP -: Disinfection Giardia Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/ 17:00	1.20	307	368.4	20.0	9.0	41.8	yes	31
2/ 10:30	0.30	307	92.1	21.0	9.1	36.7	yes	31
3/ 19:30	0.80	307	245.6	21.0	9.1	38.8	yes	31
4/ 19:45	1.20	307	368.4	20.0	9.1	43.4	yes	31
5/ 20:15	0.67	307	205.7	20.0	9.0	39.4	yes	31
6/ 20:30	0.46	307	141.2	20.0	9.0	38.5	yes	31
7/ 20:15	0.37	307	113.6	20.1	9.0	37.8	yes	31
8/ 19:00	0.30	307	92.1	19.9	9.1	39.5	yes	31
9/ 18:30	1.20	307	368.4	20.1	9.2	44.7	yes	31
10/ 19:00	1.00	307	307.0	20.0	9.2	44.0	yes	31
11/ 18:30	0.80	307	245.6	19.3	9.1	43.5	yes	31
12/ 18:30	0.53	307	162.7	18.0	9.1	45.9	yes	31
13/ 13:15	0.26	307	79.8	19.0	9.1	41.7	yes	31
14/ 14:00	1.20	307	368.4	18.0	9.1	49.6	yes	31
15/ 14:00	0.40	307	122.8	19.0	9.1	42.4	yes	31
16/ 14:15	0.40	307	122.8	19.0	9.1	42.4	yes	31
17/ 19:30	0.30	307	92.1	21.1	9.1	36.4	yes	31
18/ 10:30	0.80	307	245.6	18.6	9.0	43.9	yes	31
19/ 9:45	0.30	307	92.1	18.7	9.0	41.2	yes	31
20/ 16:20	0.90	307	276.3	17.8	9.0	46.8	yes	31
off	off	off	off	off	off	off	off	off
22/ 19:15	1.90	307	583.3	17.3	9.3	60.4	yes	31
23/ 23:00	0.70	307	214.9	16.2	9.3	56.8	yes	31
24/ 15:00	0.37	307	113.6	15.0	9.3	59.2	yes	31
25/ 18:45	0.20	307	61.4	15.0	9.3	58.1	yes	31
26/ 15:30	0.67	307	205.7	15.0	9.3	61.2	yes	31
27/ 15:45	0.30	307	92.1	15.0	9.3	58.7	yes	31
28/ 14:00	0.70	307	214.9	14.5	9.3	63.5	yes	31
29/ 16:15	0.97	307	297.8	15.0	9.3	63.3	yes	31
30/ 19:00	0.66	307	202.6	15.0	9.3	61.2	yes	31

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012