


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy		ID#: 41 00250		WTP - :		Month/Year: October-23	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.12	0.11	0.13	0.14	0.13	0.15	0.15
2	0.14	0.13	0.13	0.18	0.13	0.13	0.18
3	0.17	0.16	0.17	0.17	0.17	0.17	0.17
4	0.19	0.18	0.18	0.18	0.19	0.18	0.19
5	0.16	0.16	0.16	0.15	0.15	0.15	0.16
6	0.19	0.18	0.17	0.17	0.17	0.18	0.19
7	0.16	0.16	0.16	0.16	0.16	0.16	0.16
8	0.15	0.15	0.15	0.15	0.15	0.15	0.15
9	0.19	0.19	0.18	0.18	0.18	0.18	0.19
10	0.17	0.17	0.17	0.17	0.18	0.17	0.18
11	0.17	0.17	0.17	0.17	0.17	0.17	0.17
12	off	off	off	off	off	off	off
13	0.08	0.07	0.07	0.07	0.07	0.07	0.08
14	off	off	off	0.07	0.09	off	0.09
15	off	off	off	off	off	0.28	0.28
16	0.27	0.20	0.20	0.20	0.20	0.20	0.27
17	0.17	0.18	0.17	0.11	0.07	0.07	0.18
18	0.07	0.07	0.07	0.07	0.07	0.09	0.09
19	0.07	0.07	0.07	0.07	0.10	0.07	0.10
20	0.07	0.07	0.07	0.08	0.10	0.08	0.10
21	0.08	0.08	0.07	0.08	0.08	0.08	0.08
22	0.08	0.08	0.08	0.08	0.09	0.10	0.10
23	0.07	0.08	0.07	0.07	0.07	0.07	0.08
24	0.07	0.07	0.07	0.08	0.10	0.12	0.12
25	0.13	0.16	0.27	0.27	0.10	0.12	0.27
26	0.10	0.07	0.07	0.07	0.06	0.06	0.10
27	0.07	0.06	0.06	0.06	0.06	0.07	0.07
28	0.07	0.23	0.07	0.07	0.07	0.07	0.23
29	0.07	0.07	0.07	0.07	0.07	0.10	0.10
30	0.07	0.07	0.07	0.07	0.07	0.07	0.07
31	0.07	0.07	0.07	0.07	0.07	0.07	0.07

95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE <sup>2</sup> triggers	Yes / No		

Notes:	PRINTED NAME: Jeff Miller	
	SIGNATURE: 	DATE: 10/4/23
	PHONE #: ( 541 ) 825-3200	CERT #: 8052

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))  
PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Oct-23

System Name: Milo Academy ID#: 41 00250 WTP -: Disinfection Giardia Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/ 18:30	0.70	307	214.9	14.5	9.5	68.3	yes	31
2/ 18:45	0.60	307	184.2	14.2	9.0	57.4	yes	31
3/ 20:30	0.44	307	135.1	15.5	9.5	62.1	yes	31
4/ 11:00	0.69	307	211.8	14.7	9.5	67.3	yes	31
5/ 17:30	0.60	307	184.2	15.7	9.4	60.2	yes	31
6/ 19:30	0.64	307	196.5	16.4	9.4	57.7	yes	31
7/ 20:30	0.59	307	181.1	17.1	9.0	47.3	yes	31
8/ 18:30	0.58	307	178.1	16.5	9.1	51.0	yes	31
9/ 19:45	0.63	307	193.4	15.6	9.2	56.5	yes	31
10/ 19:00	0.60	307	184.2	15.6	9.2	56.3	yes	31
11/ 19:00	0.58	307	178.1	14.8	9.2	59.2	yes	31
12/ 10:30	0.90	307	276.3	14.0	9.2	64.7	yes	31
13/ 15:00	0.70	307	214.9	13.0	9.2	67.6	yes	31
14/ 16:15	1.10	307	337.7	12.7	9.2	72.1	yes	31
15/ 20:00	1.30	307	399.1	14.1	9.2	67.2	yes	31
16/ 20:00	1.70	307	521.9	14.1	9.2	70.3	yes	31
17/ 10:15	1.20	307	368.4	14.3	9.2	65.6	yes	31
18/ 8:30	0.80	307	245.6	13.8	9.1	62.5	yes	31
19/ 9:20	0.53	307	162.7	14.1	9.3	63.9	yes	31
20/ 17:05	0.60	307	184.2	10.0	9.3	84.2	yes	31
21/ 17:30	0.60	307	184.2	15.0	9.3	60.7	yes	31
22/ 19:25	0.60	307	184.2	14.3	9.3	63.6	yes	31
23/ 11:45	0.58	307	178.1	14.0	8.9	55.9	yes	31
24/ 19:00	0.57	307	175.0	13.9	8.7	52.3	yes	31
25/ 1:00	0.51	307	156.6	12.9	8.7	55.4	yes	31
26/ 11:00	0.49	307	150.4	9.0	7.4	44.7	yes	31
27/ 15:45	0.74	307	227.2	9.7	7.4	44.0	yes	31
28/ 16:45	0.52	307	159.6	8.5	7.4	46.4	yes	31
29/ 19:45	0.76	307	233.3	8.0	7.6	53.0	yes	31
30/ 14:30	0.69	307	211.8	7.4	7.6	54.7	yes	31
31/ 17:20	0.68	307	208.8	5.0	8.7	96.4	yes	31

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012