

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County:

Douglas

System Name:		Milo Academy		ID#:		WTP - :		Month/Year:	December-24
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1		0.10	0.10	0.10	0.16	0.19	0.15	0.19	
2		0.14	0.12	0.11	0.11	0.10	0.16	0.16	
3		0.14	0.12	0.11	0.10	0.10	0.10	0.14	
4		0.10	0.11	0.18	0.22	0.20	0.13	0.22	
5		0.10	0.10	0.10	0.11	0.10	0.10	0.11	
6		0.10	0.11	off	off	0.23	0.19	0.23	
7		0.21	0.18	0.17	off	off	off	0.21	
8		0.11	0.12	0.12	0.11	0.12	0.12	0.12	
9		0.12	0.12	0.12	0.13	0.12	0.13	0.13	
10		0.12	0.11	0.11	0.11	0.11	0.11	0.12	
11		0.10	0.10	0.10	0.10	0.11	0.11	0.11	
12		0.10	0.13	0.18	0.14	0.11	0.10	0.18	
13		0.10	0.10	0.09	0.09	0.09	0.08	0.10	
14		0.08	0.08	0.08	0.08	0.07	0.07	0.08	
15		0.08	0.09	0.09	0.09	0.08	0.08	0.09	
16		0.08	0.08	0.08	0.08	0.08	0.12	0.12	
17		0.09	0.09	0.09	0.09	0.09	0.09	0.09	
18		0.09	0.09	0.09	0.09	0.09	0.10	0.10	
19		0.10	0.10	0.10	0.10	0.10	0.10	0.10	
20		0.09	0.09	0.10	0.10	0.10	0.10	0.10	
21		0.11	0.13	0.19	0.21	0.14	0.10	0.21	
22		0.10	0.10	0.10	0.10	0.09	0.09	0.10	
23		0.09	0.10	0.09	0.09	0.09	0.09	0.10	
24		0.09	0.11	off	off	off	0.14	0.14	
25		0.15	0.15	0.16	0.16	0.17	0.18	0.18	
26		0.20	0.10	0.11	0.11	0.11	0.11	0.20	
27		0.11	0.11	0.11	0.12	0.11	0.12	0.12	
28		0.12	0.12	0.12	0.13	0.17	0.23	0.17 .23	
29		0.16	0.15	off	off	off	off	0.16	
30		off	off	off	off	off	off	off	
31		off	off	off	off	off	off	off	
95% of daily turbidity readings ≤ 0.3 NTU?				Yes / No	CT's met everyday? (see back)		All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 1 NTU?				Yes / No	Yes / No		Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers				Yes / No					
Notes: Pipe broke on 11/4 emptying reservoir. System stayed pressurized with water that the plant was processing. We put higher NTU water into reservoir to do back wash to then process water lower than .3 ntu. Boiled				PRINTED NAME: Jeff Miller SIGNATURE:  DATE: 1/13/25 PHONE #: ( 541 ) 825-3200 CERT #: 8052					

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Dec-25

System Name:		Milo Academy			ID#: 41 00250		WTP :-	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1/ 12:00	0.30	307	92.1	4.6	7.5	60.9	yes	31	
2/ 13:00	0.50	307	153.5	4.7	7.3	57.6	yes	31	
3/ 16:30	0.90	307	276.3	4.9	7.3	59.6	yes	31	
4/ 10:00	1.00	307	307.0	5.7	7.0	51.3	yes	31	
5/ 11:00	0.92	307	282.4	6.1	6.9	47.7	yes	31	
6/ 10:00	0.83	307	254.8	6.3	6.7	43.4	yes	31	
7/ 11:00	0.63	307	193.4	7.8	6.8	39.9	yes	31	
8/ 12:00	0.51	307	156.6	5.4	6.8	46.1	yes	31	
9/ 15:45	0.40	307	122.8	5.3	6.5	41.2	yes	31	
10/ 13:45	0.38	307	116.7	5.0	6.5	41.9	yes	31	
11/ 11:30	0.41	307	125.9	4.0	6.6	46.6	yes	31	
12/ 12:30	0.40	307	122.8	7.0	6.6	38.2	yes	31	
13/ 11:30	0.38	307	116.7	7.8	6.6	36.2	yes	31	
14/ 10:00	0.36	307	110.5	7.5	6.6	36.8	yes	31	
15/ 16:20	0.32	307	98.2	6.9	6.6	38.1	yes	31	
16/ 14:45	0.33	307	101.3	7.5	6.6	36.7	yes	31	
17/ 11:00	0.32	307	98.2	7.7	6.6	36.2	yes	31	
18/ 17:37	0.30	307	92.1	7.8	6.6	35.9	yes	31	
19/ 17:45	0.35	307	107.5	7.9	6.6	35.8	yes	31	
20/ 18:00	0.36	307	110.5	7.8	6.6	36.1	yes	31	
21/ 17:00	0.37	307	113.6	7.5	6.6	36.9	yes	31	
22/ 18:00	0.38	307	116.7	7.8	6.6	36.2	yes	31	
23/ 18:00	0.35	307	107.5	8.6	6.6	34.3	yes	31	
24/ 12:15	0.36	307	110.5	8.1	6.8	37.9	yes	31	
25/ 18:15	0.39	307	119.7	8.2	6.6	35.3	yes	31	
26/ 10:45	0.40	307	122.8	8.5	6.7	35.9	yes	31	
27/ 15:15	0.40	307	122.8	9.0	6.7	34.7	yes	31	
28/ 12:15	0.40	307	122.8	9.1	6.6	33.4	yes	31	
29/ 10:00	0.38	307	116.7	off	off	#VALUE!	yes	31	
30/ 17:30	0.36	307	110.5	off	off	#VALUE!	yes	31	
31/ 17:30	0.40	307	122.8	off	off	#VALUE!	yes	31	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012