

System Name: Milo Academy		ID#: 41 00250		WTP - :		Month/Year: November-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.16	0.16	0.16	0.16	0.16	0.16	0.16
2	0.16	0.16	0.17	0.16	0.16	0.16	0.17
3	0.15	0.15	0.15	0.15	0.15	0.15	0.15
4	0.15	0.15	0.15	0.15	0.16	0.15	0.16
5	0.15	0.15	0.15	0.16	0.16	0.16	0.16
6	0.18	0.20	0.19	0.16	0.16	0.16	0.20
7	0.15	0.15	0.15	0.15	0.16	0.15	0.16
8	0.15	0.15	0.15	0.15	0.15	0.15	0.15
9	0.15	0.15	0.16	0.16	0.16	0.16	0.16
10	0.16	0.16	0.16	0.16	0.16	0.16	0.16
11	0.16	0.19	0.20	Off	0.18	0.16	0.20
12	0.16	0.16	0.16	0.16	0.16	0.16	0.16
13	0.16	0.16	0.16	0.16	0.16	0.16	0.16
14	0.16	off	off	off	off	off	0.16
15	off	off	off	off	off	off	off
16	off	off	off	off	off	off	off
17	off	off	off	0.16	0.16	0.17	0.17
18	0.17	0.16	0.16	0.16	0.16	0.16	0.16
19	0.16	0.16	0.16	0.16	0.16	0.16	0.16
20	0.16	0.16	0.16	0.16	0.16	0.16	0.16
21	0.16	0.16	0.16	0.16	0.16	0.16	0.16
22	0.16	0.16	0.16	0.16	0.20	0.16	0.20
23	0.17	0.16	0.16	0.17	0.17	0.17	0.17
24	0.18	0.18	0.18	0.18	0.18	0.18	0.18
25	0.18	0.18	0.19	0.19	0.20	0.18	0.20
26	0.17	0.17	0.17	0.17	0.16	0.16	0.17
27	0.16	0.16	0.16	0.16	0.16	0.16	0.16
28	0.16	0.16	0.16	0.16	0.16	0.16	0.16
29	0.16	0.17	0.18	0.17	0.17	0.17	0.18
30	0.17	0.17	0.17	0.17	0.17	0.17	0.17

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE2 triggers	Yes / No		

Notes:		PRINTED NAME: Jeff Miller	
		SIGNATURE: 	DATE: 12/1/25
		PHONE #: (541) 825-3200	CERT #: 8052

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Nov-25

System Name: Milo Academy		ID#: 41 00250		WTP :-		Disinfection Giardia Log Inactiv:		1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 19:00	0.6	100.9	60.5	11.0	7.80	45.7	yes	31
2 / 16:22	0.6	100.9	60.5	11.0	7.80	45.7	yes	31
3 / 8:45	0.6	100.9	60.5	10.0	7.80	48.8	yes	31
4 / 9:00	0.8	100.9	80.7	10.0	7.80	50.0	yes	31
5 / 7:45	0.8	100.9	80.7	10.0	7.80	50.0	yes	31
6 / 8:40	0.6	100.9	60.5	10.0	7.80	48.8	yes	31
7 / 9:56	0.8	100.9	80.7	10.0	7.80	50.0	yes	31
8 / 17:53	0.7	100.9	70.6	10.0	7.80	49.4	yes	31
9 / 13:01	0.5	100.9	50.5	10.0	7.80	48.3	yes	31
10 / 8:40	0.7	100.9	70.6	10.0	7.80	49.4	yes	31
11 / 11:40	0.7	100.9	70.6	10.0	7.80	49.4	yes	31
12 / 7:46	0.7	100.9	70.6	10.0	7.50	44.4	yes	31
13 / 7:40	0.5	100.9	50.5	10.0	7.50	43.4	yes	31
14 / OFF	off	100.9	off	Off	off	off	yes	31
15 / OFF	off	100.9	off	Off	off	off	yes	31
16 / OFF	off	100.9	off	Off	off	off	yes	31
17 / 7:36	0.7	100.9	70.6	11.0	7.50	41.6	yes	31
18 / 17:08	0.7	100.9	70.6	11.0	7.50	41.6	yes	31
19 / 15:09	0.7	100.9	70.6	8.0	7.50	50.8	yes	31
20 / 8:18	0.6	100.9	60.5	9.0	7.50	46.9	yes	31
21 / 18:58	0.7	100.9	70.6	8.0	7.50	50.8	yes	31
22 / 16:09	0.7	100.9	70.6	9.5	7.50	45.9	yes	31
23 / 18:00	0.7	100.9	70.6	7.1	7.50	53.9	yes	31
24 / 11:45	0.8	100.9	80.7	8.0	7.50	51.3	yes	31
25 / 18:00	0.8	100.9	80.7	8.0	7.50	51.3	yes	31
26 / 15:45	0.7	100.9	70.6	8.0	7.50	50.8	yes	31
27 / 20:30	0.7	100.9	70.6	8.0	7.50	50.8	yes	31
28 / 17:00	0.6	100.9	60.5	8.0	7.50	50.2	yes	31
29 / 19:00	0.6	100.9	60.5	8.0	7.50	50.2	yes	31
30 / 21:45	0.7	100.9	70.6	8.0	7.50	50.8	yes	31

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012