


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas

System Name: Milo Academy ID#: 41 00250 WTP - : Month/Year: August-21

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.09	0.09	0.09	0.08	0.09	0.09	0.09
2	0.09	0.09	0.09	0.08	0.08	0.09	0.09
3	0.09	0.09	0.09	0.09	0.08	0.09	0.09
4	0.09	0.09	0.09	0.10	0.11	0.09	0.11
5	0.10	0.10	0.09	0.09	0.10	0.09	0.10
6	0.09	0.09	0.09	0.09	0.09	0.09	0.09
7	0.09	0.09	0.10	0.11	0.12	0.10	0.12
8	0.10	0.17	0.10	0.10	0.10	0.10	0.17
9	0.10	0.10	0.10	0.10	0.09	0.09	0.10
10	0.09	0.09	0.09	0.08	0.09	0.09	0.09
11	0.09	0.09	0.09	0.09	0.09	0.09	0.09
12	0.09	0.09	0.09	0.10	0.11	0.11	0.11
13	0.10	0.10	0.21	0.13	0.11	0.11	0.21
14	0.11	0.11	0.09	0.10	0.12	0.10	0.12
15	0.10	0.10	0.10	0.09	0.20	0.10	0.20
16	0.10	0.10	0.11	0.12	0.10	0.11	0.12
17	0.11	0.12	0.11	0.11	0.11	0.11	0.12
18	0.12	0.12	0.12	0.13	0.13	0.13	0.13
19	0.10	0.11	0.12	0.11	0.13	off	0.13
20	off	0.10	0.11	0.09	0.10	off	0.11
21	0.10	0.10	0.11	0.11	0.12	0.10	0.12
22	0.10	0.10	0.11	0.10	0.14	0.10	0.14
23	0.10	0.10	0.10	0.10	0.12	0.10	0.12
24	0.10	0.10	0.10	0.10	0.10	0.10	0.10
25	0.10	0.10	0.10	0.10	0.11	0.11	0.11
26	0.16	0.10	0.10	0.10	0.10	0.10	0.16
27	0.10	0.10	0.10	0.10	0.10	0.10	0.10
28	0.11	0.12	0.12	0.11	0.10	0.10	0.12
29	0.10	0.11	0.10	0.10	0.10	0.10	0.11
30	0.10	0.10	0.10	0.11	0.10	0.10	0.11
31	0.10	0.12	0.10	0.11	0.11	0.11	0.12

95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Jeff Miller	
	SIGNATURE: 	DATE: 8/10/21
	PHONE #: ( 541 ) 825-3200	CERT #: 8052

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Month/Year: Aug-21

System Name: Milo Academy	ID#: 41 00250	WTP -:	Disinfection Giardia Log Inactiv: 1
---------------------------	---------------	--------	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/ 14:45	4.00	307	1228.0	25.8	8.6	33.7	yes	31
2/ 15:15	4.00	307	1228.0	25.5	9.0	39.9	yes	31
3/ 10:00	4.00	307	1228.0	26.1	9.0	38.3	yes	31
4/ 18:45	3.31	307	1016.2	26.2	9.0	35.2	yes	31
5/ 19:20	0.74	307	227.2	24.3	9.3	33.3	yes	31
6/ 12:00	0.70	307	214.9	21.8	9.3	39.2	yes	31
7/ 19:00	0.57	307	175.0	26.5	9.3	28.2	yes	31
8/ 22:30	0.61	307	187.3	25.4	9.1	28.3	yes	31
9/ 22:00	0.65	307	199.6	24.4	9.1	30.4	yes	31
10/ 16:00	0.73	307	224.1	23.3	9.3	35.6	yes	31
11/ 20:36	0.80	307	245.6	24.2	8.8	28.1	yes	31
12/ 22:00	0.69	307	211.8	24.1	8.9	29.0	yes	31
13/ 18:15	0.70	307	214.9	24.3	8.8	27.6	yes	31
14/ 18:00	0.69	307	211.8	24.2	8.7	26.7	yes	31
15/ 16:30	0.53	307	162.7	24.4	8.7	25.9	yes	31
16/ 16:30	0.54	307	165.8	24.5	8.7	25.7	yes	31
17/ 19:00	0.52	307	159.6	24.2	8.8	27.2	yes	31
18/ 19:15	0.62	307	190.3	23.8	8.8	28.3	yes	31
19/ 20:30	0.70	307	214.9	24.1	8.8	27.9	yes	31
20/ 18:30	0.70	307	214.9	22.6	8.8	30.9	yes	31
21/ 20:15	7.00	307	2149.0	22.9	8.8	61.8	yes	31
22/ 20:00	7.30	307	2241.1	22.1	8.8	67.3	yes	31
23/ 18:14	6.90	307	2118.3	21.0	8.8	69.2	yes	31
24/ 18:14	6.90	307	2118.3	20.6	8.8	71.1	yes	31
25/ 19:45	1.10	307	337.7	21.1	8.8	35.7	yes	31
26/ 17:00	1.10	307	337.7	20.0	8.8	38.4	yes	31
27/ 14:00	1.00	307	307.0	19.5	8.6	36.5	yes	31
28/ 15:00	0.78	307	239.5	19.0	8.6	36.8	yes	31
29/ 14:30	0.68	307	208.8	20.1	8.6	33.8	yes	31
30/ 8:15	0.67	307	205.7	19.5	8.6	35.2	yes	31
31/ 18:30	0.59	307	181.1	20.6	8.6	32.4	yes	31

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012