

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

Feb-2021 County: Lincoln  
 Month/Year: Feb-21

System Name: City of Depoe Bay ID#: 4100254 WTP : TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> (NTU)
1	OFF	OFF	OFF	0.036	0.047	OFF	0.047
2	OFF	OFF	OFF	0.039	OFF	OFF	0.039
3	OFF	OFF	OFF	0.035	0.033	OFF	0.035
4	OFF	OFF	OFF	0.032	0.027	OFF	0.032
5	OFF	OFF	OFF	0.027	0.027	OFF	0.027
6	OFF	OFF	OFF	0.027	OFF	0.029	0.029
7	OFF	OFF	OFF	0.041	OFF	OFF	0.041
8	OFF	OFF	OFF	0.028	0.037	0.059	0.059
9	OFF	OFF	OFF	0.029	0.027	OFF	0.029
10	OFF	OFF	OFF	0.027	0.026	OFF	0.027
11	OFF	OFF	OFF	0.027	0.026	OFF	0.027
12	OFF	OFF	OFF	0.027	0.027	OFF	0.027
13	OFF	OFF	OFF	0.031	0.027	OFF	0.031
14	OFF	OFF	OFF	0.027	0.027	OFF	0.027
15	OFF	OFF	OFF	0.028	0.031	OFF	0.031
16	OFF	OFF	OFF	0.035	0.037	OFF	0.037
17	OFF	OFF	OFF	0.037	OFF	OFF	0.037
18	OFF	OFF	OFF	0.039	0.051	0.034	0.051
19	OFF	OFF	OFF	0.026	OFF	OFF	0.026
20	OFF	OFF	OFF	0.026	0.026	0.026	0.026
21	OFF	OFF	OFF	0.026	OFF	OFF	0.026
22	OFF	OFF	OFF	0.028	0.028	OFF	0.028
23	OFF	OFF	OFF	0.027	0.029	0.034	0.034
24	OFF	OFF	OFF	0.027	0.027	OFF	0.027
25	OFF	OFF	OFF	0.028	0.027	OFF	0.028
26	OFF	OFF	OFF	0.026	0.026	OFF	0.026
27	OFF	OFF	0.026	0.025	0.025	0.025	0.026
28	OFF	OFF	OFF	0.026	0.025	OFF	0.026
29	OFF	OFF	OFF	OFF	OFF	OFF	0.000
30	OFF	OFF	OFF	OFF	OFF	OFF	0.000
31	OFF	OFF	OFF	OFF	OFF	OFF	0.000

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? **Yes** / No  
 All 4-hour turbidity readings ≤ 1 NTU? **Yes** / No  
 All turbidity readings < IFE<sup>2</sup> triggers **Yes** / No

CF S met everyday? (see back) **Yes** / No

All GIZ residual at entry point > 0.2 mg/l? **Yes** / No

Notes:

PRINTED NAME: Brady Weidner  
 SIGNATURE: *Brady Weidner* DATE: 3-5-21  
 PHONE #: (541) 765-3005 CERT #: 3753

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Feb-2021

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Feb-21	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula		Yes / No
1/17:54	1.2	290	346	9.6	7.1	21	YES	372
2/9:21	1.1	290	322	9.4	7.1	21	YES	303
3/8:33	0.9	290	264	9.6	7.3	22	YES	270
4/12:20	1.1	290	319	8.9	7.8	28	YES	273
5/11:27	1.0	290	290	9.0	7.1	21	YES	278
6/10:31	1.1	290	316	9.0	7.7	27	YES	329
7/9:24	1.1	290	314	9.0	7.8	28	YES	323
8/17:25	1.0	290	302	8.4	7.5	25	YES	300
9/10:4	1.1	290	320	8.5	7.6	26	YES	268
10/10:29	1.0	290	300	7.6	7.5	27	YES	280
11/10:11	1.1	290	318	7.8	7.5	27	YES	254
12/9:58	1.0	290	302	7.3	7.5	27	YES	281
13/13:39	1.0	290	302	8.3	7.7	28	YES	300
14/10:29	1.0	290	280	8.6	7.1	22	YES	295
15/10:45	1.0	290	298	9.0	7.1	21	YES	306
16/10:7	1.0	290	296	9.6	7.1	20	YES	258
17/10:4	1.0	290	302	9.2	7.2	22	YES	279
18/20:5	1.0	290	304	9.1	7.4	23	YES	258
19/13:5	1.1	290	322	9.5	7.4	23	YES	269
20/9:51	1.0	290	298	8.9	7.4	24	YES	309
21/11:0	1.1	290	310	9.3	7.5	25	YES	309
22/10:11	1.0	290	302	9.5	7.5	24	YES	297
23/11:26	1.0	290	284	9.9	7.1	20	YES	334
24/10:17	1.0	290	300	10.1	7.3	21	YES	278
25/10:43	1.0	290	298	8.8	7.3	23	YES	278
26/10:34	1.0	290	294	8.7	7.3	24	YES	317
27/8:52	1.0	290	290	8.7	7.4	25	YES	316
28/10:33	1.0	290	300	9.4	7.5	24	YES	331
29	#N/A	290	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
30	#N/A	290	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
31	#N/A	290	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.