

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Lincoln  
 Month/Year: Nov-24

System Name: City of Depoe Bay ID#: 4100254 WTP : TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> (NTU)
1	OFF	OFF	OFF	0.022	0.023	OFF	0.023
2	OFF	OFF	OFF	0.026	0.019	0.019	0.026
3	OFF	OFF	OFF	0.019	OFF	OFF	0.019
4	OFF	OFF	OFF	0.022	0.028	0.000	0.028
5	OFF	OFF	0.026	0.028	OFF	OFF	0.028
6	OFF	OFF	OFF	0.036	OFF	OFF	0.036
7	OFF	OFF	OFF	0.036	0.028	OFF	0.036
8	OFF	OFF	OFF	0.028	0.034	OFF	0.034
9	OFF	OFF	OFF	0.030	0.024	OFF	0.030
10	OFF	OFF	OFF	0.020	0.018	OFF	0.020
11	OFF	OFF	0.017	0.017	OFF	OFF	0.017
12	OFF	OFF	OFF	0.047	0.018	OFF	0.047
13	OFF	OFF	OFF	0.020	OFF	OFF	0.020
14	OFF	OFF	OFF	0.035	0.018	OFF	0.035
15	OFF	OFF	OFF	0.019	0.019	OFF	0.019
16	OFF	OFF	OFF	0.021	0.033	0.028	0.033
17	OFF	OFF	OFF	0.016	0.017	OFF	0.017
18	OFF	OFF	OFF	0.018	OFF	OFF	0.018
19	OFF	OFF	OFF	0.019	0.017	OFF	0.019
20	OFF	OFF	OFF	OFF	OFF	OFF	0.000
21	OFF	OFF	OFF	0.025	0.029	0.039	0.039
22	0.042	0.038	OFF	0.055	OFF	OFF	0.055
23	OFF	OFF	OFF	0.017	0.017	0.016	0.017
24	OFF	OFF	OFF	0.017	OFF	OFF	0.017
25	OFF	OFF	OFF	0.017	0.016	OFF	0.017
26	OFF	OFF	OFF	0.020	0.017	OFF	0.020
27	OFF	OFF	OFF	0.019	OFF	OFF	0.019
28	OFF	OFF	OFF	0.018	0.018	OFF	0.018
29	OFF	OFF	OFF	0.016	0.016	OFF	0.016
30	OFF	OFF	OFF	0.019	0.018	OFF	0.019
31	OFF	OFF	OFF	OFF	OFF	OFF	0.000

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?  Yes  No  
 All 4-hour turbidity readings ≤ 1 NTU?  Yes  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes  No

0.5 met everyday?  
 (see back)  
 Yes  No

All GZ residual at entry point  
 > 0.2 mg/l?  
 Yes  No

Notes:

PRINTED NAME: BRADY WEIDNER

SIGNATURE: *Brady Weidner*

DATE:

PHONE #: (541) 765-3005

CERT #: 3753

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Nov-24	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/8:59	1.3	290	377	12.5	7.4	19	YES	328
2/10:23	1.2	290	348	13.1	7.3	18	YES	323
3	1.4	290	406	12.9	7.1	17	YES	238
4/0:0	1.4	290	406	13.2	7.4	19	YES	169
5/0:0	1.5	290	435	12.9	7.2	18	YES	155
6/11:54	1.4	290	406	12.7	7.6	21	YES	316
7/9:11	1.5	290	435	12.7	7.8	23	YES	293
8/10:15	1.4	290	406	12.1	7.6	22	YES	321
9/9:57	1.4	290	406	12.1	7.6	22	YES	324
10/18:7	1.4	290	406	13.4	7.3	18	YES	357
11/7:58	1.3	290	377	12.6	7.3	19	YES	321
12/10:0	1.3	290	377	12.9	7.6	20	YES	280
13/9:9	1.3	290	377	12.8	7.4	19	YES	277
14/8:49	1.2	290	348	13.1	7.5	19	YES	304
15/10:35	1.4	290	406	12.8	7.1	17	YES	333
16/13:55	1.2	290	348	13.1	7.7	20	YES	369
17/18:20	1.3	290	377	12.4	7.6	21	YES	355
18/11:40	1.3	290	377	12.3	7.2	18	YES	481
19/9:8	1.4	290	406	12.1	7.1	18	YES	284
20/0:0	1.3	290	377	12.2	7.2	19	YES	301
21/22:30	1.2	290	348	12.4	7.1	17	YES	284
22/2:51	1.3	290	377	12.5	7.6	21	YES	306
23/17:47	1.2	290	348	12.2	7.2	18	YES	362
24/9:46	1.1	290	319	12.1	7.1	18	YES	358
25/8:47	1.2	290	348	12.3	7.5	20	YES	328
26/12:55	1.3	290	377	11.9	7.6	22	YES	363
27/9:58	1.1	290	319	11.7	7.1	18	YES	306
28/11:9	1.2	290	348	10.9	7.6	23	YES	364
29/15:20	1.2	290	348	10.3	7.6	24	YES	348
30/19:14	1.2	290	348	9.8	7.2	21	YES	362
31	#N/A		#N/A	#N/A	#N/A	#N/A	#N/A	#N/A

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.