

OHA - Drinking Water Services -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Lincoln
 Month/Year: Dec-24

System Name: City of Depoe Bay ID#: 4100254 WTP : TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	0.019	0.025	OFF	0.025
2	OFF	OFF	OFF	0.016	0.016	OFF	0.016
3	OFF	OFF	OFF	0.017	0.016	OFF	0.017
4	OFF	OFF	OFF	0.020	0.019	0.018	0.020
5	0.017	0.017	0.017	0.017	0.017	0.017	0.017
6	0.017	0.017	0.017	0.018	OFF	0.019	0.019
7	0.018	0.018	0.018	0.019	0.018	0.029	0.029
8	0.056	0.048	OFF	OFF	OFF	OFF	0.056
9	OFF	OFF	OFF	0.044	0.032	0.022	0.044
10	0.020	0.020	OFF	OFF	OFF	OFF	0.020
11	OFF	OFF	OFF	0.019	OFF	OFF	0.019
12	OFF	OFF	OFF	0.023	0.018	0.017	0.023
13	OFF	OFF	OFF	0.020	OFF	OFF	0.020
14	OFF	OFF	OFF	0.018	0.018	0.019	0.019
15	OFF	OFF	OFF	0.020	OFF	OFF	0.020
16	OFF	OFF	OFF	0.021	0.018	OFF	0.021
17	OFF	OFF	OFF	0.019	OFF	OFF	0.019
18	OFF	OFF	OFF	0.021	0.019	0.018	0.021
19	OFF	OFF	OFF	0.019	OFF	OFF	0.019
20	OFF	OFF	OFF	0.019	0.019	OFF	0.019
21	OFF	OFF	OFF	0.021	OFF	OFF	0.021
22	OFF	OFF	OFF	0.018	0.018	OFF	0.018
23	OFF	OFF	OFF	0.017	OFF	OFF	0.017
24	OFF	OFF	OFF	0.018	0.018	0.018	0.018
25	OFF	OFF	OFF	OFF	OFF	OFF	0.000
26	OFF	OFF	OFF	0.034	0.020	0.017	0.034
27	0.017	OFF	OFF	OFF	OFF	OFF	0.017
28	OFF	OFF	OFF	0.019	0.018	0.017	0.019
29	0.017	0.017	OFF	OFF	OFF	OFF	0.017
30	OFF	OFF	OFF	0.019	0.019	0.019	0.019
31	0.019	0.020	OFF	OFF	OFF	OFF	0.020

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE ² triggers	CFS met everyday? (see back) Yes/No	All Cl ₂ residual at entry point > 0.2 mg/l? Yes/No

Notes:

PRINTED NAME: Brady Weidner
 SIGNATURE: *Brady Weidner* DATE: 1-3-24
 PHONE #: 343-992-0980 CERT #: 3793

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

DEC, 2024

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Dec-24	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/10:31	1.2	290	348	9.3	7.2	22	YES	334
2/8:56	1.2	290	348	9.1	7.4	24	YES	353
3/10:20	1.3	290	377	8.7	7.6	27	YES	294
4/11:43	1.2	290	348	10.3	7.3	22	YES	308
5/21:11	1.1	290	319	12.8	7.2	17	YES	280
6/7:1	1.2	290	348	12.5	7.1	17	YES	284
7/11:33	1.1	290	319	9.8	7.2	21	YES	310
8/3:49	1.2	290	348	10.1	7.1	20	YES	365
9/13:8	1.3	290	377	11.6	7.5	21	YES	283
10/4:43	1.1	290	319	10.0	7.2	21	YES	273
11/14:56	1.1	290	319	10.3	7.2	21	YES	281
12/11:55	1.1	290	319	9.5	7.1	21	YES	278
13/10:1	1.1	290	319	9.7	7.3	22	YES	305
14/9:56	1.1	290	319	9.9	7.2	21	YES	325
15/9:32	1.0	290	290	10.1	7.2	21	YES	354
16/14:5	1.1	290	319	10.0	7.2	21	YES	304
17/9:54	1.1	290	319	10.3	7.6	24	YES	260
18/8:40	1.2	290	348	10.8	7.1	19	YES	266
19/13:53	1.1	290	319	12.2	7.4	19	YES	280
20/9:5	1.2	290	348	12.3	7.1	18	YES	279
21/9:50	1.3	290	377	12.7	7.6	21	YES	323
22/10:41	1.2	290	348	12.4	7.2	18	YES	312
23/9:41	1.3	290	377	12.2	7.4	20	YES	308
24/11:17	1.1	290	319	12.2	7.3	19	YES	304
25/0:0	1.2	290	348	12.1	7.3	19	YES	322
26/8:39	1.2	290	348	12.1	7.2	18	YES	324
27/3:6	1.2	290	348	13.1	7.2	17	YES	354
28/11:24	1.2	290	348	12.2	7.1	18	YES	380
29/4:7	1.2	290	348	12.2	7.3	19	YES	393
30/9:23	1.3	290	377	12.2	7.3	19	YES	491
31/4:51	1.2	290	348	11.8	7.3	19	YES	353

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.