

System Name: **City of Depoe Bay** ID#: **4100254** WTP : **TP - Depoe Bay**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> (NTU)
1	OFF	OFF	OFF	0.021	0.022	OFF	0.022
2	OFF	OFF	OFF	0.024	0.023	OFF	0.024
3	OFF	OFF	OFF	0.020	0.019	OFF	0.020
4	OFF	OFF	OFF	0.021	0.019	0.019	0.021
5	OFF	OFF	OFF	0.020	OFF	OFF	0.020
6	OFF	OFF	OFF	OFF	0.020	0.019	0.020
7	0.018	OFF	OFF	OFF	0.021	0.021	0.021
8	OFF	OFF	OFF	OFF	OFF	OFF	0.000
9	OFF	OFF	0.027	0.020	0.019	0.019	0.027
10	0.019	OFF	OFF	0.023	0.018	OFF	0.023
11	OFF	OFF	OFF	0.020	0.022	OFF	0.022
12	OFF	OFF	OFF	0.020	0.025	0.031	0.031
13	OFF	OFF	OFF	0.021	0.018	OFF	0.021
14	OFF	OFF	OFF	0.021	0.019	OFF	0.021
15	OFF	OFF	OFF	0.025	0.023	0.024	0.025
16	0.023	OFF	OFF	OFF	OFF	OFF	0.023
17	OFF	OFF	OFF	0.026	0.032	0.024	0.032
18	0.045	0.033	0.029	OFF	OFF	OFF	0.045
19	OFF	OFF	OFF	0.022	0.020	0.020	0.022
20	0.036	OFF	OFF	0.030	OFF	OFF	0.036
21	OFF	OFF	OFF	0.040	0.022	0.019	0.040
22	OFF	OFF	OFF	0.026	0.018	OFF	0.026
23	OFF	OFF	OFF	0.025	0.027	OFF	0.027
24	OFF	OFF	OFF	0.025	0.020	OFF	0.025
25	OFF	OFF	0.019	0.030	0.021	OFF	0.030
26	OFF	OFF	OFF	0.021	0.019	0.019	0.021
27	OFF	OFF	OFF	0.021	OFF	OFF	0.021
28	OFF	OFF	OFF	0.021	0.017	0.018	0.021
29	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	
31	OFF	OFF	OFF	OFF	OFF	OFF	

**Conventional or Direct Filtration**

95% of 4-hour turbidity readings ≤ 0.3 NTU?  Yes  No  
 All 4-hour turbidity readings ≤ 1 NTU?  Yes  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes  No

**Monthly Summary (Answer Yes or No)**

CF's met everyday? (see back)  Yes  No  
 All GZ residual at entry point > 0.2 mg/l?  Yes  No

Notes:

PRINTED NAME: *Brady Weidner*  
 SIGNATURE: *[Signature]* DATE: *2-3-25*  
 PHONE #: *(941) 765-3005* CERT #: *3758*

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))  
 PAGE 1 of 2

FEB. 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Feb-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/18:13	1.2	290	348	8.4	7.1	23	YES	341
2/13:42	1.2	290	348	8.7	7.1	22	YES	333
3/9:31	1.2	290	348	8.8	7.4	25	YES	931
4/21:38	1.2	290	348	8.1	7.2	24	YES	324
5/9:34	1.1	290	319	8.0	7.2	24	YES	320
6/12:16	1.1	290	319	8.2	7.3	24	YES	345
7/14:59	0.9	290	261	8.4	7.3	24	YES	452
8/0:0	1.1	290	319	8.6	7.3	24	YES	355
9/6:33	1.2	290	348	8.5	7.4	25	YES	364
10/11:45	1.1	290	319	13.3	7.4	18	YES	366
11/12:16	1.2	290	348	14.0	7.4	17	YES	350
12/13:7	1.2	290	348	13.5	7.4	18	YES	351
13/10:32	1.2	290	348	6.9	7.4	28	YES	331
14/9:28	1.3	290	377	6.9	7.5	29	YES	336
15/11:37	1.2	290	348	7.4	7.3	26	YES	351
16/1:43	1.2	290	348	8.4	7.2	24	YES	398
17/8:22	1.1	290	319	8.5	7.1	22	YES	349
18/8:43	1.2	290	348	11.1	7.1	19	YES	355
19/9:0	1.3	290	377	10.1	7.3	22	YES	719
20/10:28	1.2	290	348	10.4	7.2	21	YES	371
21/9:3	1.4	290	406	10.6	7.5	23	YES	380
22/11:18	1.2	290	348	10.6	7.3	21	YES	385
23/10:7	1.2	290	348	11.0	7.5	22	YES	391
24	1.2	290	348	11.5	7.1	19	YES	#N/A
25/7:55	1.2	290	348	11.5	7.1	18	YES	367
26/11:24	1.3	290	377	13.3	7.4	18	YES	373
27/9:19	1.4	290	406	11.4	7.3	20	YES	361
28/18:43	1.4	290	394	11.9	7.2	19	YES	413
29	#N/A		#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
30	#N/A		#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
31	#N/A		#N/A	#N/A	#N/A	#N/A	#N/A	#N/A

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.