

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

APRIL 2025 Month/Year: Apr-25

System Name: City of Depoe Bay ID#: 4100254 WTP : TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	0.028	0.025	0.033	0.033
2	0.052	OFF	OFF	0.027	OFF	OFF	0.052
3	OFF	OFF	OFF	0.027	0.026	0.026	0.027
4	OFF	OFF	OFF	0.032	0.027	OFF	0.032
5	OFF	OFF	OFF	0.028	0.027	OFF	0.028
6	OFF	OFF	OFF	0.029	0.028	0.028	0.029
7	OFF	OFF	OFF	0.029	0.049	OFF	0.049
8	OFF	OFF	OFF	0.024	0.026	OFF	0.026
9	OFF	OFF	OFF	0.026	0.026	OFF	0.026
10	OFF	OFF	OFF	OFF	OFF	OFF	0.000
11	OFF	OFF	OFF	0.027	0.024	0.025	0.027
12	0.025	0.026	OFF	OFF	OFF	OFF	0.026
13	OFF	OFF	0.029	0.025	0.028	OFF	0.029
14	OFF	OFF	OFF	0.028	0.027	0.026	0.028
15	0.025	OFF	OFF	OFF	OFF	OFF	0.025
16	OFF	OFF	OFF	OFF	OFF	OFF	0.000
17	OFF	OFF	OFF	OFF	OFF	OFF	0.000
18	OFF	OFF	OFF	0.047	0.036	0.038	0.047
19	0.051	0.047	0.041	0.039	0.040	0.038	0.051
20	0.033	0.033	0.032	OFF	OFF	OFF	0.033
21	OFF	OFF	OFF	0.030	0.028	0.028	0.030
22	0.028	OFF	OFF	0.037	OFF	OFF	0.037
23	OFF	OFF	OFF	0.030	0.029	0.028	0.030
24	OFF	OFF	OFF	0.029	0.025	OFF	0.029
25	OFF	OFF	OFF	0.025	0.025	0.027	0.027
26	OFF	OFF	OFF	0.025	0.027	OFF	0.027
27	OFF	OFF	OFF	0.030	0.027	0.027	0.030
28	OFF	OFF	OFF	OFF	OFF	OFF	0.000
29	OFF	OFF	0.031	0.029	0.029	0.030	0.031
30	0.031	OFF	OFF	OFF	OFF	OFF	0.031
31	OFF	OFF	OFF	OFF	OFF	OFF	0.000

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No
 All 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All turbidity readings < IFE² triggers ☒ Yes / ☐ No

CFS met everyday?
(see back)☒ Yes / ☐ NoAll GZ residual at entry point
> 0.2 mg/l?☒ Yes / ☐ No

Notes:

PRINTED NAME: Brady Weigher

SIGNATURE: *Brady Weigher*

DATE: 5-5-25

PHONE #: (541) 765-3005

CERT #: 5753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Apr 2025

WTP - : Depoe Bay

System Name: City of Depoe Bay ID#: 4100254 Month/Year: Apr-25 Disinfection *Giardia* Log Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/10:3	1.0	290	280	11.1	7.5	21	YES	365
2/9:44	1.0	290	290	11.1	7.5	21	YES	342
3/11:1	1.1	290	316	11.3	7.5	21	YES	364
4/16:26	1.0	290	278	13.6	7.7	19	YES	364
5/10:12	1.0	290	304	11.2	7.7	23	YES	427
6/9:42	1.0	290	280	11.6	7.6	21	YES	372
7/10:42	1.1	290	319	11.8	7.5	21	YES	325
8/9:9	1.0	290	288	11.9	7.4	20	YES	322
9/10:10	1.1	290	308	11.8	7.3	19	YES	383
10/0:0	1.2	290	348	11.7	7.4	20	YES	324
11/8:35	1.1	290	308	12.0	7.2	18	YES	392
12/1:46	1.1	290	318	11.8	7.4	20	YES	386
13/7:14	1.0	290	290	11.8	7.5	20	YES	390
14/9:36	1.1	290	310	11.4	7.4	20	YES	336
15/2:7	1.1	290	306	11.7	7.4	20	YES	363
16/0:0	1.0	290	290	12.3	7.3	18	YES	337
17/11:12	1.2	290	348	15.7	7.2	14	YES	500
18/23:55	1.1	290	320	12.2	7.8	22	YES	355
19/23:46	1.0	290	294	12.5	7.5	19	YES	351
20/8:4	1.1	290	319	12.5	7.4	19	YES	367
21/9:20	1.0	290	290	12.5	7.3	18	YES	355
22/11:26	1.1	290	319	12.4	7.2	18	YES	320
23/10:23	1.0	290	288	12.7	7.2	17	YES	323
24/9:50	1.2	290	348	12.1	7.3	19	YES	307
25/19:50	1.1	290	326	12.2	7.2	18	YES	381
26/9:55	1.1	290	310	12.2	7.2	18	YES	367
27/12:20	1.1	290	332	12.4	7.2	18	YES	422
28/0:0	1.2	290	348	12.5	7.3	18	YES	381
29/6:50	1.0	290	300	12.7	7.2	17	YES	318
30/1:10	1.1	290	322	13.3	7.1	16	YES	324
31	#N/A	290	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.