

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

 County: Lincoln
 Month/Year: May-25
 WTP : TP - Depoe Bay

System Name: City of Depoe Bay ID#: 4100254

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	0.031	0.032	0.030	0.031	0.032
2	0.029	OFF	OFF	OFF	OFF	OFF	0.029
3	OFF	OFF	OFF	0.030	0.025	0.025	0.030
4	0.024	0.024	OFF	OFF	OFF	OFF	0.024
5	OFF	OFF	OFF	0.030	0.029	0.028	0.030
6	0.028	0.028	OFF	OFF	OFF	OFF	0.028
7	OFF	OFF	OFF	0.025	0.029	0.028	0.029
8	0.028	0.028	OFF	OFF	OFF	OFF	0.028
9	OFF	OFF	OFF	0.031	0.030	0.031	0.031
10	0.030	OFF	OFF	OFF	OFF	OFF	0.030
11	OFF	OFF	OFF	0.032	0.032	0.032	0.032
12	0.033	0.032	OFF	OFF	OFF	OFF	0.033
13	OFF	OFF	OFF	0.034	0.031	0.025	0.034
14	0.025	OFF	OFF	OFF	OFF	OFF	0.025
15	OFF	OFF	OFF	0.029	0.032	0.031	0.032
16	0.030	OFF	OFF	OFF	OFF	OFF	0.030
17	OFF	OFF	OFF	0.033	0.033	0.033	0.033
18	0.033	0.034	OFF	OFF	OFF	OFF	0.034
19	OFF	OFF	OFF	0.039	0.032	0.032	0.039
20	0.031	OFF	OFF	OFF	0.033	0.032	0.033
21	OFF	OFF	OFF	0.030	0.028	OFF	0.030
22	OFF	OFF	OFF	0.029	0.028	OFF	0.029
23	OFF	OFF	OFF	OFF	OFF	OFF	0.000
24	OFF	OFF	OFF	0.034	0.028	0.025	0.034
25	0.024	0.023	0.023	0.023	0.024	0.024	0.024
26	0.026	OFF	OFF	OFF	OFF	OFF	0.026
27	OFF	OFF	OFF	OFF	0.032	OFF	0.032
28	OFF	OFF	OFF	0.031	0.029	OFF	0.031
29	OFF	OFF	OFF	0.033	0.029	0.032	0.033
30	0.032	0.031	0.033	0.032	0.039	0.038	0.039
31	OFF	OFF	OFF	0.033	OFF	OFF	0.033

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes ☐ No
 All 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes ☐ No
 All turbidity readings < IFE² triggers ☒ Yes ☐ No

 CFS met everyday?
 (see back)
☒ Yes ☐ No
 All Cl₂ residual at entry point
 > 0.2 mg/l?
☒ Yes ☐ No

Notes:

PRINTED NAME: Brady Weidner

SIGNATURE: 

DATE: 6-6-25

PHONE #: ()

CERT #: 3753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

MAY 2025

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	May-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/6:32	1.0	290	290	12.7	7.2	17	YES	608
2/0:12	1.1	290	316	13.1	7.3	17	YES	407
3/9:6	1.2	290	348	12.7	7.2	17	YES	367
4/3:48	1.1	290	306	13.3	7.4	18	YES	415
5/8:55	1.1	290	319	12.8	7.2	17	YES	350
6/1:32	1.0	290	290	13.0	7.2	17	YES	341
7/11:36	1.2	290	348	13.8	7.3	17	YES	377
8/4:30	1.0	290	276	13.3	7.1	16	YES	353
9/8:37	1.0	290	276	13.2	7.2	16	YES	385
10/2:14	1.0	290	290	13.3	7.2	16	YES	398
11/11:2	1.1	290	319	13.6	7.2	16	YES	368
12/1:58	1.0	290	290	13.9	7.1	15	YES	323
13/8:43	1.2	290	348	13.6	7.2	16	YES	323
14/1:6	1.1	290	332	13.8	7.4	17	YES	340
15/9:11	1.1	290	319	13.8	7.2	16	YES	307
16/2:27	1.2	290	354	14.3	7.2	16	YES	350
17/17:44	1.0	290	290	14.3	7.3	16	YES	358
18/4:4	1.2	290	354	14.6	7.1	15	YES	363
19/14:20	1.1	290	319	15.0	7.2	15	YES	332
20/1:37	1.2	290	354	14.5	7.3	16	YES	349
21/14:31	1.2	290	348	14.7	7.7	18	YES	335
22/15:51	1.1	290	319	14.7	7.2	15	YES	318
23/0:0	1.0	290	290	15.1	7.4	16	YES	345
24/13:55	1.0	290	290	15.2	7.2	15	YES	408
25/4:43	1.1	290	319	14.6	7.1	15	YES	376
26/14:43	1.0	290	290	16.7	7.5	15	YES	436
27/15:34	1.2	290	348	16.3	7.5	15	YES	361
28/8:52	1.2	290	348	15.7	7.3	15	YES	330
29/9:18	1.2	290	348	15.6	7.6	17	YES	311
30/2:21	1.0	290	290	15.8	7.3	14	YES	368
31/9:31	1.1	290	319	15.6	7.2	14	YES	369

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.