

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Lincoln

Month/Year: Jun-25

System Name:	City of Depoe Bay			ID#: 4100254	WTP : TP - Depoe Bay		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	0.030	OFF	OFF	0.030
2	OFF	OFF	OFF	0.024	0.029	0.030	0.030
3	0.027	0.026	OFF	OFF	OFF	OFF	0.027
4	OFF	OFF	OFF	0.028	0.027	0.027	0.028
5	0.027	0.028	OFF	OFF	OFF	OFF	0.028
6	OFF	OFF	OFF	0.035	0.044	0.026	0.044
7	0.025	0.024	0.024	0.036	OFF	OFF	0.036
8	OFF	OFF	0.032	OFF	0.028	OFF	0.032
9	OFF	OFF	OFF	0.027	0.026	0.027	0.027
10	0.027	0.028	0.026	0.025	OFF	OFF	0.028
11	OFF	OFF	OFF	0.039	0.036	0.035	0.039
12	0.034	0.033	OFF	OFF	OFF	OFF	0.034
13	OFF	OFF	OFF	0.040	0.039	0.039	0.040
14	0.039	0.028	0.024	0.026	0.025	OFF	0.039
15	OFF	OFF	OFF	0.035	0.039	0.038	0.039
16	OFF	OFF	OFF	0.042	0.042	0.042	0.042
17	0.042	0.043	OFF	OFF	OFF	OFF	0.043
18	OFF	OFF	OFF	0.046	0.039	0.033	0.046
19	0.033	0.033	0.031	OFF	OFF	OFF	0.033
20	OFF	OFF	OFF	0.045	0.040	0.038	0.045
21	0.039	0.041	0.044	0.035	0.035	0.034	0.044
22	0.034	0.032	0.031	0.030	0.030	0.040	0.040
23	OFF	OFF	OFF	OFF	OFF	OFF	0.000
24	OFF	OFF	OFF	0.038	0.043	0.042	0.043
25	0.037	0.036	0.040	0.040	0.039	0.031	0.040
26	0.031	OFF	OFF	OFF	OFF	OFF	0.031
27	OFF	OFF	OFF	0.038	0.040	0.035	0.040
28	0.033	0.032	0.032	0.031	0.031	0.035	0.035
29	0.034	0.036	OFF	OFF	OFF	OFF	0.036
30	OFF	OFF	OFF	0.036	0.035	0.039	0.039
31	OFF	OFF	OFF	OFF	OFF	OFF	0.000

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes ☐ NoAll turbidity readings < IFE² triggers☒ Yes ☐ No

Monthly Summary (Answer Yes or No)

CFS met everyday?
(see back)☒ Yes ☐ NoAll GZ residual at entry point
> 0.2 mg/l?☒ Yes ☐ No

Notes:

PRINTED NAME: Brady Weidner

SIGNATURE: *Brady Weidner*

DATE:

PHONE #: (541) - 765-3005

CERT #: 3753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Jun-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
---------------------	--------------------------	---------------------	--------------------	---------------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/13:0	1.2	290	348	16.0	7.3	14	YES	424
2/11:34	1.3	290	377	15.4	7.3	15	YES	364
3/3:0	1.1	290	319	15.8	7.1	14	YES	343
4/12:55	1.1	290	319	17.0	7.2	13	YES	304
5/3:0	1.0	290	290	16.7	7.2	13	YES	335
6/11:27	1.1	290	319	16.1	7.1	13	YES	325
7/7:28	1.1	290	319	16.6	7.1	13	YES	399
8/11:32	1.0	290	290	17.9	7.2	12	YES	403
9/10:34	1.2	290	348	16.9	7.2	13	YES	764
10/4:34	1.1	290	319	17.4	7.1	12	YES	397
11/14:4	1.1	290	319	18.8	7.5	13	YES	380
12/7:56	1.2	290	348	17.4	7.4	14	YES	638
13/8:55	1.1	290	319	17.0	7.3	13	YES	376
14/9:20	1.0	290	290	17.4	7.8	16	YES	425
15/9:26	1.0	290	290	16.9	7.3	13	YES	448
16/10:8	1.0	290	290	16.8	7.2	13	YES	376
17/7:10	1.0	290	290	17.2	7.2	13	YES	418
18/9:1	1.1	290	319	17.2	7.1	12	YES	514
19/3:51	1.1	290	319	17.7	7.1	12	YES	400
20/9:11	1.0	290	290	17.3	7.3	13	YES	437
21/23:53	1.0	290	290	17.4	7.1	12	YES	406
22/16:56	1.0	290	290	18.4	7.2	12	YES	401
23/0:0	1.0	290	290	17.4	7.1	12	YES	375
24/10:13	1.2	290	348	16.8	7.2	13	YES	352
25/9:22	1.1	290	319	17.8	7.2	12	YES	456
26/1:31	1.1	290	319	16.7	7.1	13	YES	393
27/14:33	1.1	290	319	18.9	7.1	11	YES	412
28/8:6	1.0	290	290	17.2	7.2	13	YES	439
29/7:27	1.1	290	319	17.5	7.3	13	YES	449
30/10:49	1.2	290	348	17.2	7.2	13	YES	386
31	#N/A	290	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.