

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Lincoln**
 Month/Year: **Jul-25**

System Name: **City of Depoe Bay** ID#: **4100254** WTP : TP - **Depoe Bay**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	0.029	0.031	0.032	0.033	0.033	0.033	0.033
2	0.033	OFF	OFF	OFF	OFF	OFF	0.033
3	OFF	OFF	OFF	0.042	0.041	0.038	0.042
4	0.039	0.040	0.041	0.038	OFF	0.041	0.041
5	OFF	OFF	OFF	0.039	0.034	0.034	0.039
6	0.035	OFF	OFF	0.037	0.041	0.038	0.041
7	0.037	0.038	0.036	0.036	OFF	OFF	0.038
8	OFF	OFF	OFF	0.040	0.037	0.035	0.040
9	0.035	0.036	OFF	OFF	OFF	OFF	0.036
10	OFF	OFF	OFF	0.036	0.038	0.033	0.038
11	0.028	0.027	0.026	0.026	0.029	0.029	0.029
12	0.029	OFF	OFF	OFF	OFF	OFF	0.029
13	OFF	OFF	OFF	0.035	0.027	0.025	0.035
14	0.026	0.027	0.030	0.028	0.025	OFF	0.030
15	0.026	0.025	OFF	0.034	0.033	OFF	0.034
16	OFF	OFF	OFF	0.032	0.030	0.030	0.032
17	0.031	OFF	OFF	OFF	0.033	0.032	0.033
18	0.029	OFF	OFF	0.033	0.029	0.027	0.033
19	OFF	OFF	OFF	0.029	0.030	0.034	0.034
20	OFF	OFF	OFF	0.037	0.035	0.032	0.037
21	0.032	OFF	OFF	0.033	0.031	0.030	0.033
22	OFF	OFF	OFF	0.034	0.033	0.031	0.034
23	0.030	OFF	OFF	OFF	OFF	OFF	0.030
24	OFF	OFF	OFF	0.035	0.039	0.036	0.039
25	0.036	0.037	0.037	0.038	0.037	0.035	0.038
26	0.034	0.034	0.028	OFF	OFF	OFF	0.034
27	OFF	OFF	0.027	0.030	0.032	0.032	0.032
28	0.031	0.032	0.035	0.033	0.030	0.032	0.035
29	0.033	0.032	OFF	0.038	0.032	0.033	0.038
30	OFF	OFF	OFF	0.039	0.036	0.036	0.039
31	0.038	OFF	OFF	0.044	0.042	0.041	0.044

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	OT's met everyday? (see back)	All Ciz residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: <i>Brady Weidner</i>	
		SIGNATURE: <i>Brady Weidner</i>	DATE: <i>8-4-25</i>
		PHONE #: <i>(341) 745-3005</i>	CERT #: <i>3753</i>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

July 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/4:22	1.0	290	290	17.8	7.6	14	YES	364
2/3:30	1.0	290	290	17.4	7.2	12	YES	470
3/8:51	1.1	290	319	17.1	7.5	14	YES	414
4/11:6	1.1	290	319	17.9	7.1	12	YES	428
5/18:5	1.1	290	319	18.3	7.3	12	YES	429
6/11:50	1.0	290	290	17.8	7.3	13	YES	396
7/0:43	1.2	290	348	17.2	7.4	14	YES	349
8/9:8	1.0	290	290	17.6	7.3	13	YES	423
9/5:20	1.1	290	319	17.7	7.2	12	YES	519
10/9:57	1.0	290	290	17.4	7.2	13	YES	369
11/6:1	1.0	290	290	17.6	7.1	12	YES	426
12/1:25	1.0	290	290	17.8	7.4	13	YES	427
13/8:12	1.0	290	290	17.7	7.5	14	YES	371
14/9:40	1.0	290	290	17.6	7.2	12	YES	395
15/9:14	1.1	290	319	17.1	7.1	12	YES	393
16/8:45	1.1	290	319	17.4	7.1	12	YES	401
17/12:29	1.2	290	348	17.4	7.2	13	YES	396
18/12:25	1.0	290	290	19.5	7.1	10	YES	433
19/10:20	1.1	290	319	18.0	7.2	12	YES	372
20/17:8	1.2	290	348	18.4	7.4	13	YES	438
21/8:42	1.0	290	290	18.2	7.1	11	YES	585
22/8:52	1.0	290	290	18.1	7.2	12	YES	1053
23/0:15	1.1	290	319	18.9	7.4	12	YES	717
24/20:0	1.1	290	319	19.0	7.3	12	YES	421
25/5:32	1.1	290	319	18.9	7.3	12	YES	562
26/9:7	1.0	290	290	19.4	7.2	11	YES	463
27/7:7	1.0	290	290	18.8	7.3	12	YES	473
28/2:27	1.1	290	319	19.1	7.2	11	YES	1062
29/11:36	1.0	290	290	18.8	7.1	11	YES	409
30/10:0	1.2	290	348	18.8	7.2	12	YES	518
31/10:18	1.1	290	319	18.8	7.3	12	YES	584

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.