

OCT-2025

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Lincoln

Month/Year:

Oct-25

System Name:

City of Depoe Bay

ID#: 4100254

WTP : TP -

Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	0.032	0.031	0.029	0.046	0.031	0.030	0.046
2	OFF	OFF	OFF	0.031	0.030	0.030	0.031
3	OFF	OFF	OFF	0.034	0.034	0.033	0.034
4	0.033	OFF	OFF	OFF	0.036	0.035	0.036
5	OFF	OFF	OFF	OFF	OFF	OFF	0.000
6	OFF	OFF	OFF	0.031	OFF	OFF	0.031
7	OFF	OFF	OFF	0.033	0.038	0.039	0.039
8	0.040	0.040	0.041	0.035	OFF	OFF	0.041
9	OFF	OFF	OFF	0.028	0.029	0.030	0.030
10	0.030	OFF	OFF	0.027	OFF	OFF	0.030
11	OFF	OFF	OFF	0.032	0.033	0.031	0.033
12	0.032	OFF	OFF	OFF	OFF	OFF	0.032
13	OFF	OFF	OFF	0.038	0.038	0.039	0.039
14	0.039	0.039	0.040	0.038	OFF	OFF	0.040
15	OFF	OFF	OFF	0.028	0.026	0.024	0.028
16	OFF	OFF	OFF	0.030	0.027	OFF	0.030
17	OFF	OFF	OFF	0.028	OFF	OFF	0.028
18	OFF	OFF	OFF	0.028	0.028	0.027	0.028
19	OFF	OFF	OFF	OFF	OFF	OFF	0.000
20	OFF	OFF	OFF	0.029	0.028	0.027	0.029
21	0.027	0.025	OFF	OFF	OFF	OFF	0.027
22	OFF	OFF	OFF	0.031	0.030	0.028	0.031
23	0.028	OFF	OFF	0.033	OFF	OFF	0.033
24	OFF	OFF	OFF	0.029	0.028	0.029	0.029
25	OFF	OFF	OFF	0.035	OFF	OFF	0.035
26	OFF	OFF	OFF	0.037	0.034	0.029	0.037
27	OFF	OFF	OFF	OFF	OFF	OFF	0.000
28	OFF	OFF	OFF	0.031	0.035	0.039	0.039
29	0.038	OFF	OFF	OFF	OFF	OFF	0.038
30	OFF	OFF	OFF	0.045	0.046	0.045	0.046
31	OFF	OFF	OFF	0.038	OFF	OFF	0.038

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes/No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings < IFE² triggers

Yes/No

Monthly Summary (Answer Yes or No)

CFS met everyday?
(see back)

Yes/No

Air Oz residual at entry point
> 0.2 mg/l?

Yes/No

Notes:

PRINTED NAME: Brady Weicher

SIGNATURE: *Brady Weicher*

DATE: 11-9-25

PHONE #: (541) 765-3005

CERT #: 5753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OCT. 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name: City of Depoe Bay ID#: 4100254 Month/Year: Oct-25 Disinfection *Giardia* Log Inactive: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/11:31	1.1	290	319	15.2	7.1	14	YES	327
2/10:0	1.0	290	290	15.2	7.1	14	YES	313
3/11:27	1.1	290	319	15.4	7.1	14	YES	368
4/12:57	1.1	290	319	15.6	7.1	14	YES	337
5/0:0	1.0	290	290	15.7	7.2	14	YES	355
6/12:14	1.1	290	319	17.2	7.2	13	YES	529
7/9:35	1.1	290	319	15.8	7.3	15	YES	414
8/8:28	1.2	290	348	14.9	7.1	15	YES	402
9/10:20	1.2	290	348	15.1	7.5	17	YES	389
10/13:3	1.2	290	348	14.6	7.6	18	YES	349
11/9:27	1.0	290	290	17.7	7.3	13	YES	319
12/0:13	1.1	290	319	21.0	7.3	10	YES	357
13/9:12	1.0	290	290	14.2	7.4	17	YES	556
14/9:37	1.1	290	319	13.2	7.1	16	YES	362
15/8:48	1.0	290	290	13.5	7.3	17	YES	497
16/8:50	1.0	290	290	12.6	7.4	19	YES	312
17/15:33	0.9	290	261	14.9	7.1	14	YES	328
18/8:29	0.9	290	261	12.8	7.3	17	YES	320
19/0:0	1.0	290	290	12.8	7.2	17	YES	342
20/9:11	0.9	290	261	12.8	7.5	19	YES	376
21/5:22	1.0	290	290	12.8	7.3	18	YES	376
22/9:13	0.9	290	261	12.9	7.2	17	YES	277
23/10:48	0.9	290	261	12.8	7.1	16	YES	351
24/11:12	1.1	290	319	13.2	7.3	17	YES	312
25/9:47	1.1	290	319	13.4	7.7	20	YES	346
26/9:57	1.2	290	348	13.4	7.7	20	YES	341
27/0:0	1.0	290	290	12.9	7.3	17	YES	298
28/8:47	1.0	290	290	13.0	7.4	18	YES	1129
29/2:16	1.1	290	319	12.7	7.3	18	YES	369
30/8:32	1.2	290	348	12.7	7.6	20	YES	368
31/9:10	1.1	290	319	12.2	7.2	18	YES	374

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.