

Nov. 2025

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

 County: Lincoln
 Month/Year: Nov-25

System Name:	City of Depoe Bay			ID#: 4100254	WTP : TP - Depoe Bay		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	0.064	0.061	0.059	0.064
2	OFF	OFF	OFF	OFF	OFF	OFF	0.000
3	OFF	OFF	0.045	0.047	0.040	0.048	0.048
4	OFF	OFF	OFF	0.050	0.043	OFF	0.050
5	OFF	OFF	OFF	OFF	OFF	OFF	0.000
6	OFF	OFF	OFF	0.050	0.043	0.051	0.051
7	0.040	0.039	0.045	0.039	OFF	OFF	0.045
8	OFF	OFF	OFF	OFF	OFF	OFF	0.000
9	OFF	OFF	0.042	0.049	0.048	0.045	0.049
10	OFF	OFF	OFF	0.054	0.055	0.050	0.055
11	0.044	0.043	OFF	OFF	0.044	OFF	0.044
12	OFF	OFF	OFF	0.032	0.037	OFF	0.037
13	OFF	OFF	OFF	0.048	OFF	OFF	0.048
14	OFF	OFF	OFF	0.039	0.034	0.038	0.039
15	OFF	OFF	OFF	0.035	0.036	OFF	0.036
16	OFF	OFF	OFF	OFF	OFF	OFF	0.000
17	OFF	OFF	OFF	0.041	OFF	OFF	0.041
18	OFF	OFF	OFF	0.036	0.036	0.038	0.038
19	0.040	0.045	0.041	OFF	OFF	OFF	0.045
20	OFF	OFF	OFF	0.036	0.038	0.033	0.038
21	OFF	OFF	OFF	0.050	OFF	OFF	0.050
22	OFF	OFF	OFF	0.052	0.047	0.045	0.052
23	OFF	OFF	OFF	0.044	0.042	OFF	0.044
24	OFF	OFF	OFF	0.042	0.043	OFF	0.043
25	OFF	OFF	OFF	0.048	0.048	OFF	0.048
26	OFF	OFF	0.041	0.047	0.053	0.052	0.053
27	0.043	0.044	0.043	OFF	OFF	OFF	0.044
28	OFF	OFF	0.032	0.030	0.031	0.040	0.040
29	0.039	OFF	OFF	OFF	OFF	OFF	0.039
30	OFF	OFF	OFF	0.046	0.041	0.049	0.049
31	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CFS met everyday?
(see back)

Yes / No

All GZ residual at entry point
> 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Brady Weidner

SIGNATURE: *Brady Weidner*

DATE: 11-5-25

PHONE #: (541) - 745-3005

CERT #: 3753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

Nov 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Nov-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/11:15	1.1	290	319	12.6	7.2	17	YES	355
2	1.1	290	319	13.7	7.1	16	YES	#N/A
3/0:0	1.0	290	290	12.9	7.1	16	YES	132
4/0:0	1.2	290	348	13.3	7.5	19	YES	134
5/0:0	1.1	290	319	13.1	7.4	18	YES	372
6/8:35	1.1	290	319	13.1	7.5	19	YES	334
7/8:31	1.1	290	319	13.4	7.2	17	YES	418
8/0:0	1.0	290	290	13.3	7.3	17	YES	433
9/6:32	1.2	290	348	13.5	7.5	19	YES	449
10/9:57	1.1	290	319	13.0	7.3	18	YES	398
11/10:19	1.0	290	290	13.0	7.5	19	YES	380
12/9:55	1.0	290	290	13.2	7.2	17	YES	351
13/9:59	1.1	290	319	13.2	7.5	19	YES	400
14/20:9	1.0	290	290	13.4	7.6	19	YES	364
15/13:27	1.0	290	290	14.2	7.6	18	YES	438
16/9:55	0.9	290	261	13.6	7.5	18	YES	391
17/9:15	1.1	290	319	13.5	7.3	17	YES	331
18/10:12	0.9	290	261	13.1	7.4	18	YES	345
19/9:39	1.2	290	348	11.9	7.2	19	YES	367
20/9:21	1.2	290	348	11.9	7.3	19	YES	846
21/10:19	1.1	290	319	11.3	7.4	21	YES	401
22/8:37	1.2	290	348	11.5	7.3	20	YES	370
23/11:48	1.1	290	319	11.0	7.1	19	YES	382
24/10:44	1.1	290	319	11.0	7.2	20	YES	676
25/12:0	1.1	290	319	10.9	7.1	19	YES	1988
26/6:38	1.2	290	348	10.9	7.1	19	YES	1639
27/10:1	1.1	290	319	12.0	7.1	18	YES	409
28/10:26	1.1	290	319	12.0	7.2	18	YES	416
29/0:29	1.1	290	319	12.7	7.2	17	YES	456
30/9:31	1.2	290	348	12.5	7.4	19	YES	414
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.