OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Lincoln
Month/Year: Jan-26

System Name: City of Depoe Bay **ID#:** 4100254 **WTP : TP -** Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day[1] (NTU)
1	OFF	OFF	0.024	0.024	0.025	0.042	0.042
2	0.034	0.029	0.051	0.030	0.025	0.024	0.051
3	0.023	OFF	OFF	0.024	0.023	OFF	0.024
4	OFF	OFF	0.025	0.039	0.024	0.023	0.039
5	0.023	0.023	OFF	OFF	OFF	OFF	0.023
6	OFF	OFF	OFF	0.025	0.024	0.023	0.025
7	0.024	0.026	0.024	OFF	OFF	OFF	0.026
8	OFF	OFF	OFF	0.026	0.024	0.026	0.026
9	0.025	0.023	OFF	0.023	0.023	0.022	0.025
10	0.022	OFF	OFF	OFF	OFF	OFF	0.022
11	OFF	OFF	OFF	0.023	0.023	0.025	0.025
12	0.026	0.038	0.035	0.030	0.023	0.023	0.038
13	0.022	OFF	OFF	OFF	0.022	0.022	0.022
14	0.022	OFF	OFF	0.022	0.022	0.022	0.022
15	OFF	OFF	OFF	0.023	0.022	0.023	0.023
16	OFF	OFF	OFF	0.024	0.024	0.024	0.024
17	0.023	OFF	OFF	0.023	0.024	0.026	0.026
18	0.040	OFF	OFF	0.025	0.027	0.053	0.053
19	0.030	OFF	OFF	0.039	0.044	0.030	0.044
20	OFF	OFF	OFF	0.031	0.030	0.030	0.031
21	0.032	OFF	OFF	0.031	0.023	0.023	0.032
22	OFF	OFF	OFF	0.030	0.038	OFF	0.038
23	OFF	OFF	OFF	0.024	0.026	OFF	0.026
24	OFF	OFF	OFF	0.025	0.032	0.058	0.058
25	OFF	OFF	OFF	0.025	0.028	OFF	0.028
26	OFF	OFF	OFF	0.024	0.024	OFF	0.024
27	OFF	OFF	OFF	0.024	OFF	OFF	0.024
28	OFF	OFF	OFF	0.030	0.024	OFF	0.030
29	OFF	OFF	OFF	0.024	0.023	OFF	0.024
30	OFF	OFF	OFF	0.023	0.023	OFF	0.023
31	OFF	OFF	OFF	0.025	0.024	0.024	0.025

Conventional or Direct Filtration	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No
All turbidity readings < IFE[2] triggers	Yes / No

Monthly Summary (Answer Yes or No)	
CT's met everyday?	All Cl2 residual at entry point
Yes / No	Yes / No

Notes:

PRINTED NAME: PAUL CARVER
SIGNATURE: [signature] **DATE:** 2-5-26
PHONE #: (541) 765-3005 **CERT #:** T-09093

[1] Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. [2] IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay						
System Name:	**City of Depoe Bay**	**ID#: 4100254**	**Month/Year:**	**Jan-26**	**Disinfection *Giardia* Log Inactive:**	0.5

Date / Time	Minimum Cl_2 Residual at 1st User (**C**) [3]	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? [3]	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	**C X T**	[° C]		formula	Yes / No	[GPM]
1/6:26	1.0	290	290	9.5	8.0	28	YES	438
2/11:20	1.0	290	290	11.8	7.3	19	YES	441
3/11:23	1.1	290	319	10.8	7.2	20	YES	435
4/6:47	1.0	290	290	11.1	7.2	19	YES	439
5/1:44	1.0	290	290	11.3	7.2	19	YES	365
6/8:38	1.0	290	290	10.9	7.2	19	YES	481
7/6:30	1.1	290	319	10.9	7.3	20	YES	366
8/11:19	1.3	290	377	11.2	7.1	19	YES	347
9/22:53	1.3	290	377	11.3	7.6	23	YES	566
10/2:51	1.2	290	348	11.5	7.4	21	YES	408
11/9:54	1.2	290	348	11.3	7.5	22	YES	450
12/6:58	1.2	290	348	11.2	7.6	22	YES	425
13/13.50	1.1	290	319	11.2	7.6	22	YES	688
14/23:50	1.3	290	377	11.2	8.0	26	YES	620
15/10:2	0.9	290	261	10.7	7.1	19	YES	382
16/23:59	1.1	290	319	10.2	7.5	23	YES	385
17/23:59	1.3	290	377	10.8	7.2	20	YES	440
18/0:12	1.1	290	319	10.9	7.2	20	YES	434
19/11:47	1.0	290	290	9.9	7.1	20	YES	439
20/9:41	0.9	290	261	9.2	7.4	23	YES	460
21/12:23	1.3	290	377	9.4	7.6	26	YES	421
22/12:0	1.2	290	348	8.4	7.3	24	YES	421
23/10:12	1.2	290	348	8.3	7.5	26	YES	362
24/11:52	1.2	290	348	8.2	7.6	27	YES	373
25/10:00	1.2	290	344	7.7	7.4	26	YES	388
26/10:13	1.2	290	352	7.4	7.4	27	YES	398
27/10:51	1.4	290	406	8.0	7.3	26	YES	353
28/8:32	1.3	290	366	8.2	7.1	23	YES	335
29/18:48	1.2	290	336	9.0	7.3	23	YES	427
30/10:18	1.2	290	348	8.6	7.5	26	YES	330
31/22:35	1.2	290	348	10.2	7.3	21	YES	365

[3] If Cl_2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.