

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Lincoln  
 Month/Year: Feb-26

System Name: City of Depoe Bay ID#: 4100254 WTP : TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> (NTU)
1	OFF	OFF	0.024	0.024	0.024	OFF	0.024
2	OFF	OFF	OFF	0.024	0.023	0.023	0.024
3	0.023	0.021	OFF	OFF	0.023	OFF	0.023
4	OFF	OFF	0.024	0.025	0.025	OFF	0.025
5	OFF	OFF	0.024	0.024	0.023	OFF	0.024
6	OFF	OFF	0.023	0.024	0.025	OFF	0.025
7	OFF	OFF	0.023	0.023	0.023	OFF	0.023
8	OFF	OFF	0.024	0.024	0.023	OFF	0.024
9	OFF	OFF	OFF	0.024	0.024	0.024	0.024
10	0.025	0.034	OFF	OFF	0.024	0.035	0.035
11	OFF	OFF	0.024	0.024	0.023	OFF	0.024
12	OFF	OFF	0.023	0.024	0.024	OFF	0.024
13	OFF	OFF	0.023	0.024	0.024	OFF	0.024
14	OFF	OFF	0.023	0.023	0.024	OFF	0.024
15	OFF	OFF	0.023	0.024	0.025	OFF	0.025
16	OFF	OFF	0.022	0.024	0.025	OFF	0.025
17	OFF	OFF	0.024	0.023	0.025	OFF	0.025
18	OFF	OFF	0.025	0.023	0.018	OFF	0.025
19	OFF	OFF	0.024	0.023	0.016	OFF	0.024
20	OFF	OFF	0.023	0.024	0.024	OFF	0.024
21	OFF	OFF	OFF	0.019	0.020	OFF	0.020
22	OFF	OFF	OFF	0.017	0.017	OFF	0.017
23	OFF	OFF	OFF	0.016	0.016	0.016	0.016
24	OFF	OFF	OFF	0.020	0.020	OFF	0.020
25	OFF	OFF	OFF	0.016	0.016	OFF	0.016
26	OFF	OFF	OFF	0.017	0.017	OFF	0.017
27	OFF	OFF	0.020	0.020	OFF	OFF	0.020
28	OFF	OFF	OFF	0.019	0.019	0.019	0.019
29	OFF	OFF	OFF	OFF	OFF	OFF	0.000
30	OFF	OFF	OFF	OFF	OFF	OFF	0.000
31	OFF	OFF	OFF	OFF	OFF	OFF	0.000

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?  Yes  No  
 All 4-hour turbidity readings ≤ 1 NTU?  Yes  No  
 All turbidity readings < IFE<sup>2</sup> triggers  Yes  No

CF's met everyday? (see back)  Yes  No

Air Oz residual at entry point > 0.2 mg/l?  Yes  No

Notes:

PRINTED NAME: Brady Weidner  
 SIGNATURE: *Brady Weidner*  
 PHONE #: (941) 765-3005  
 DATE: 3-8-26  
 CERT #: 3753

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Feb-2026

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Feb-26	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/10:12	1.2	290	348	10.3	7.2	21	YES	421
2/8:54	1.2	290	348	10.3	7.2	21	YES	380
3/13:35	1.2	290	348	11.2	7.3	20	YES	368
4/15:20	1.3	290	377	11.5	7.1	19	YES	400
5/18:27	1.5	290	435	11.2	8.0	27	YES	320
6/10:26	1.2	290	348	11.2	7.6	22	YES	315
7/9:38	0.9	290	261	11.0	7.4	21	YES	370
8/10:13	0.9	290	261	11.1	7.3	20	YES	374
9/9:23	1.0	290	290	11.3	7.4	20	YES	326
10/15:7	0.9	290	261	11.2	7.1	18	YES	418
11/8:15	0.9	290	261	10.5	7.3	20	YES	401
12/11:51	1.1	290	319	11.0	7.8	24	YES	399
13/13:23	1.0	290	290	11.1	7.6	22	YES	376
14/9:48	1.0	290	290	10.8	7.4	21	YES	370
15/8:14	1.2	290	348	10.5	7.7	24	YES	349
16/9:32	1.1	290	319	9.8	7.6	24	YES	352
17/9:08	1.1	290	319	10.8	8.1	27	YES	366
18/10:29	1.1	290	319	9.4	7.4	23	YES	344
19/8:40	1.1	290	319	9.8	7.4	23	YES	401
20/9:56	1.1	290	319	8.4	7.4	25	YES	337
21/9:43	1.0	290	290	8.8	7.3	23	YES	345
22/9:40	1.0	290	304	9.5	7.4	23	YES	438
23/11:27	1.0	290	284	11.1	7.6	22	YES	373
24/9:54	0.8	290	240	10.5	7.5	22	YES	345
25/8:57	0.9	290	260	10.6	7.5	22	YES	321
26/8:55	0.9	290	260	11.0	7.2	19	YES	365
27/9:02	1.0	290	290	10.4	7.6	23	YES	342
28/8:26	1.0	290	284	10.7	7.6	23	YES	327
29								
30								
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013