

REC'D APR 08 2026 MARCH 26

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Lincoln
 Month/Year: Mar-26

System Name: City of Depoe Bay ID#: 4100254 WTP: TP - Depoe Bay

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	0.018	0.017	0.020	OFF	0.020
2	OFF	OFF	0.019	0.019	0.019	0.020	0.020
3	OFF	OFF	0.019	0.020	0.021	OFF	0.021
4	OFF	OFF	0.020	0.019	0.019	OFF	0.020
5	OFF	OFF	0.018	0.018	0.017	OFF	0.018
6	OFF	OFF	0.018	0.017	0.017	0.016	0.018
7	OFF	OFF	0.020	0.018	0.018	OFF	0.020
8	OFF	OFF	0.020	0.019	0.018	0.019	0.020
9	OFF	OFF	0.021	0.021	0.021	0.021	0.021
10	OFF	OFF	0.021	0.021	0.022	OFF	0.022
11	OFF	OFF	0.022	0.017	0.017	OFF	0.022
12	OFF	OFF	0.020	0.026	0.024	OFF	0.026
13	OFF	OFF	0.020	0.021	0.020	0.020	0.021
14	OFF	OFF	0.023	0.020	0.020	OFF	0.023
15	OFF	OFF	0.021	0.021	0.022	OFF	0.022
16	OFF	OFF	0.025	0.022	0.028	0.036	0.036
17	OFF	OFF	0.028	0.023	0.021	OFF	0.028
18	OFF	OFF	0.021	0.028	0.018	0.017	0.028
19	OFF	OFF	0.022	0.021	0.019	OFF	0.022
20	OFF	OFF	0.021	0.019	0.019	0.019	0.021
21	OFF	OFF	0.022	0.020	0.020	OFF	0.022
22	OFF	OFF	0.022	0.021	0.022	0.020	0.022
23	OFF	OFF	0.021	0.021	0.020	OFF	0.021
24	OFF	OFF	0.019	0.018	0.019	OFF	0.019
25	OFF	OFF	0.022	0.020	0.021	OFF	0.022
26	OFF	OFF	0.023	0.022	0.022	0.021	0.023
27	OFF	OFF	0.023	0.023	0.023	0.022	0.023
28	OFF	OFF	0.020	0.021	0.020	0.020	0.021
29	OFF	OFF	0.020	0.024	0.020	0.020	0.024
30	OFF	OFF	0.021	0.019	0.020	OFF	0.021
31	OFF	OFF	0.022	0.020	0.021	OFF	0.022

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No
 All 4-hour turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? Yes / No
 All Cl₂ residual at entry point Yes / No

Notes:

PRINTED NAME: Brady Weidner
 SIGNATURE: *[Signature]* DATE: 4-8-20
 PHONE #: (541) 765-3005 CERT #: 3753

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

4-9-26
 To file
 WATER REPORT
[Signature]

MARCH 26

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Depoe Bay

System Name:	City of Depoe Bay	ID#: 4100254	Month/Year:	Mar-26	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-------------------	--------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/9:09	1.1	290	319	10.3	7.7	24	YES	366
2/8:22	0.9	290	261	11.1	7.5	21	YES	374
3/9:04	1.1	290	319	11.2	7.4	21	YES	340
4/9:53	1.1	290	319	11.6	7.4	20	YES	344
5/9:45	1.2	290	348	11.5	7.4	21	YES	332
6/9:44	1.0	290	290	11.3	7.2	19	YES	327
7/9:46	1.1	290	319	13.3	7.2	17	YES	329
8/9:12	1.2	290	348	12.4	7.3	19	YES	373
9/8:35	1.1	290	319	11.3	7.3	20	YES	335
10/8:55	1.0	290	290	10.7	7.2	20	YES	473
11/8:29	1.0	290	290	10.2	7.3	21	YES	372
12/9:15	0.9	290	261	10.7	7.1	19	YES	334
13/9:44	1.0	290	290	11.1	7.1	19	YES	360
14/9:59	1.1	290	314	11.7	7.1	18	YES	374
15/9:56	1.2	290	334	11.8	7.1	18	YES	350
16/9:32	1.1	290	319	11.4	7.3	20	YES	341
17/8:29	1.2	290	348	11.6	7.4	20	YES	385
18/8:52	1.1	290	319	11.7	7.4	20	YES	417
19/8:33	1.0	290	290	11.8	7.3	19	YES	356
20/9:10	0.9	290	261	12.9	7.1	16	YES	506
21/9:24	1.2	290	348	12.0	7.3	19	YES	413
22/9:23	1.1	290	319	11.6	7.4	20	YES	414
23/10:10	1.1	290	319	11.0	7.2	19	YES	385
24/9:28	1.1	290	319	10.8	7.3	21	YES	371
25/8:47	1.2	290	348	11.2	7.3	20	YES	393
26/8:48	1.0	290	290	10.7	7.2	20	YES	409
27/9:05	1.1	290	319	10.6	7.2	20	YES	425
28/10:47	1.0	290	290	10.8	7.1	19	YES	405
29/9:50	0.9	290	261	11.1	7.2	19	YES	408
30/9:49	1.1	290	319	10.7	7.3	21	YES	347
31/10:10	1.2	290	348	10.6	7.3	21	YES	359

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.