

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Maricopa
Month/Year: March 2025
WTP: TP -

System Name:

ID#: 41

SKID 2

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01		0.01	0.01		0.01	0.01
4		0.01					0.01
5							
6							
7							
8		0.01		0.01	0.01	0.01	0.01
9	0.01	0.01		0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01		0.01	0.01
11	0.01	0.01	0.01		0.01	0.01	0.01
12	0.01	0.01	0.01	0.01		0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14		0.01	0.01		0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01		0.01
17	0.01	0.01	0.01	0.01	0.01		0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01		0.01	0.01		0.01	0.01
20		0.01	0.01		0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01		0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	*	0.01	0.01	0.01	0.01
24	0.01		0.01	0.01		0.01	0.01
25	0.01	0.01	0.01		0.01	0.01	0.01
26		0.01	0.01		0.01	0.01	0.01
27	0.01	0.01	0.01		0.01	0.01	0.01
28	0.01		0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01		0.01	0.01	0.01	0.01	0.01
31	0.01	0.01		0.01	0.01	0.01	0.01

Slow Sand/Membrane/DE Filtration/Unfiltered

95% of daily turbidity readings $\leq$ 1 NTU?²

Yes No

All daily turbidity readings $\leq$ 5 NTU?

Yes No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

Yes No

Notes:

PRINTED NAME: Robert Bruce

SIGNATURE: Robert Bruce

DATE: 4-2-24

PHONE #: (503) 854-3496

CERT #: 7134

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:
 Month/Year: **MARCH 25**
 WTP: TP -

System Name:

ID#: 41

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4			0.01	0.01	0.01	0.01	0.01
5	0.01			0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01					0.01
8							0.01
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered

95% of daily turbidity readings $\leq$ 1 NTU? ²

Yes / No

All daily turbidity readings $\leq$ 5 NTU?

Yes / No

Notes:

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

Yes / No

PRINTED NAME: Robert Bruce

SIGNATURE: Robert Bruce

DATE: 4.2.25

PHONE #: (503) 854-3496

CERT #: 7136

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

MARCH 25

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

System Name: Detroit

ID#: 41

Month/Year: Mar 25Disinfection *Giardia* Log

Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.3	66	85	12.7	5.9	13	Yes	155
2	1.8	66	119	18.5	6.9	14	Yes	135
3	1.8	66	119	19.2	7.2	16	Yes	120
4	1.3	66	85	19.8	7.5	15	Yes	80
5	1.2	66	79	19.8	7.5	15	Yes	80
6	1.2	66	79	19.9	7.5	15	Yes	80
7	1.2	66	79	17.3	7.9	15	Yes	100
8	1.0	66	66	17.3	7.9	18	Yes	100
9	1.0	66	66	17.3	8.0	18	Yes	110
10	1.0	66	66	17.5	8.0	18	Yes	180
11	1.0	66	66	17.4	8.0	18	Yes	100
12	1.0	66	66	17.4	8.1	22	Yes	80
13	1.1	66	72	17.7	8.1	22	Yes	80
14	1.2	66	79	17.3	7.7	19	Yes	80
15	1.1	66	72	17.2	7.8	22	Yes	85
16	1.1	66	72	17.0	7.8	22	Yes	95
17	.9	66	60	8.3	7.2	24	Yes	130
18	1.0	66	66	12.5	7.5	18	Yes	80
19	1.1	66	72	17.1	7.8	22	Yes	80
20	1.2	66	79	17.0	7.9	19	Yes	80
21	1.2	66	79	17.2	8.0	19	Yes	80
22	1.1	66	72	17.2	7.9	22	Yes	120
23	1.1	66	72	17.6	7.9	22	Yes	115
24	1.0	66	66	17.2	7.9	22	Yes	110
25	1.0	66	66	17.4	8.0	22	Yes	115
26	1.0	66	66	17.4	7.9	22	Yes	110
27	1.2	66	79	17.4	7.9	19	Yes	130
28	1.3	66	85	17.8	8.0	19	Yes	105
29	1.2	66	79	17.7	8.1	19	Yes	100
30	1.2	66	79	17.7	8.1	19	Yes	120
31	1.2	66	79	17.9	8.1	19	Yes	120

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@oha.oregon.gov; 971-673-0604; Drinking Water Services, PO Box 14350, Portland, OR 97219.