OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

Month/Year: May-25

System Name: City of Drain ID#: 41 00260 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [1] [NTU]
1	0.03	OFF	OFF	OFF	OFF	OFF	0.05
2	OFF	OFF	0.04	0.02	0.03	0.03	0.07
3	0.03	OFF	OFF	OFF	OFF	OFF	0.06
4	OFF	OFF	OFF	OFF	OFF	OFF	0.07
5	0.03	0.02	0.03	0.03	0.03	OFF	0.06
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	0.02	0.02	OFF	0.03	0.06
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	0.02	0.02	0.03	0.03	0.06
10	0.03	OFF	OFF	OFF	OFF	OFF	0.04
11	OFF	OFF	OFF	OFF	0.02	0.02	0.05
12	0.03	0.03	OFF	OFF	OFF	OFF	0.04
13	OFF	OFF	OFF	OFF	0.02	0.03	0.03
14	0.02	OFF	OFF	OFF	OFF	OFF	0.04
15	OFF	OFF	OFF	0.03	0.03	0.03	0.04
16	0.02	OFF	OFF	OFF	OFF	OFF	0.05
17	OFF	OFF	OFF	0.03	0.02	0.02	0.04
18	0.02	OFF	OFF	OFF	OFF	OFF	0.05
19	OFF	OFF	OFF	0.02	0.02	0.03	0.04
20	0.03	OFF	OFF	OFF	OFF	OFF	0.03
21	OFF	OFF	0.04	0.03	0.02	0.02	0.07
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	0.03	0.03	0.03	0.05
24	0.02	0.02	OFF	OFF	OFF	OFF	0.04
25	OFF	0.03	0.03	0.03	0.02	0.03	0.06
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	0.03	0.02	0.03	0.02	0.03	0.05
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	0.02	0.02	0.02	0.05
30	0.02	OFF	OFF	OFF	OFF	OFF	0.04
31	OFF	OFF	OFF	OFF	0.03	0.02	0.05

Conventional or Direct Filtration

95% of daily turbidity readings ≤ 0.3 NTU? (Yes) / No

All daily turbidity readings ≤ 1 NTU? (Yes) / No

All turbidity readings < IFE[2] triggers (Yes) / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) (Yes) / No

All Cl2 residual at entry point ≥ 0.2 mg/l? (Yes) / No

PRINTED NAME: Harold Burris

SIGNATURE: Harold Burris DATE:06-05-25

PHONE #: (541) 836-7301 CERT #:5248 FE

[1] Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. [2] IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A	
System Name: City of Drain	ID#: 41 00260
Month/Year: May-25	Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl_2 Residual at 1st User (C) [3]	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? [3]	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.14	130	148.2	16.0	7.62	32.6	YES	450
2	1.13	130	146.9	17.0	7.81	32.7	YES	450
3	0.97	130	126.1	17.0	7.73	31.1	YES	450
4	0.90	130	117.0	16.0	7.69	32.5	YES	450
5	1.11	130	144.3	16.0	7.94	36.5	YES	450
6	0.93	130	120.9	17.0	7.82	32.0	OFF	OFF
7	1.18	130	153.4	17.0	7.79	32.6	YES	450
8	1.00	130	130.0	18.0	7.81	30.1	OFF	OFF
9	1.07	130	139.1	18.0	7.82	30.5	YES	450
10	1.16	130	150.8	18.0	7.85	31.1	YES	450
11	1.09	130	141.7	17.0	7.82	32.6	YES	450
12	0.89	130	115.7	17.0	7.81	31.8	YES	450
13	1.23	130	159.9	17.0	7.84	33.4	YES	450
14	1.09	130	141.7	17.0	7.81	32.5	YES	450
15	0.87	130	113.1	16.0	7.84	34.3	YES	450
16	1.15	130	149.5	17.0	7.69	31.3	YES	450
17	0.91	130	118.3	17.0	7.93	33.3	YES	450
18	0.89	130	115.7	17.0	7.73	30.9	YES	450
19	0.85	130	110.5	18.0	8.07	32.6	YES	450
20	0.92	130	119.6	17.0	7.81	31.9	YES	450
21	0.85	130	110.5	16.0	7.77	33.3	OFF	450
22	1.05	130	136.5	17.0	7.67	30.7	OFF	OFF
23	1.03	130	133.9	17.0	7.69	30.9	YES	450
24	1.03	130	133.9	17.0	7.79	32.1	YES	450
25	1.24	130	161.2	18.0	7.72	29.9	YES	450
26	1.08	130	140.4	18.0	7.69	29.1	OFF	OFF
27	1.12	130	145.6	19.0	7.86	29.1	YES	450
28	1.00	130	130.0	18.0	7.70	28.9	OFF	OFF
29	1.14	130	148.2	20.0	7.68	25.5	YES	450
30	1.02	130	132.6	20.0	7.72	25.5	YES	450
31	0.91	130	118.3	19.0	7.72	27.0	YES	450

[3] If Cl_2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012