

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Douglas**  
 Month/Year: **Dec-25**

System Name: **City of Drain** ID#: **41 00260** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.03	0.03	OFF	OFF	OFF	OFF	0.05
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	0.03	0.03	0.03	0.03	0.03	0.06
5	0.03	OFF	OFF	OFF	OFF	OFF	0.04
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	0.03	0.03	0.03	0.03	0.05
9	0.03	OFF	OFF	OFF	OFF	OFF	0.05
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	0.05	OFF	0.03	0.07
13	0.03	0.03	OFF	OFF	OFF	OFF	0.04
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.05	0.04	0.03	0.09
17	0.03	OFF	OFF	0.02	0.03	OFF	0.10
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	0.02	0.06
21	0.02	0.02	OFF	0.03	OFF	OFF	0.16
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	0.03	0.03	OFF	0.16
25	0.03	0.03	OFF	OFF	OFF	OFF	0.06
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	0.04	0.17
29	0.03	0.05	0.02	0.03	OFF	OFF	0.17
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No

PRINTED NAME: **Harold Burris**  
 SIGNATURE: *Harold Burris* DATE: **01-07-26**  
 PHONE #: **( 541) 836-7301** CERT #: **5248 FE**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -- A

System Name: City of Drain	ID#: 41 00260	Month/Year: Dec-25	Disinfection Giardia Log Inactiv: 1.0
----------------------------	---------------	--------------------	---------------------------------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.07	145	155.2	13.0	7.74	41.2	YES	450
2	1.00	145	145.0	13.0	7.75	41.1	YES	OFF
3	0.97	145	140.7	13.0	7.80	41.7	YES	OFF
4	1.47	145	213.2	11.0	7.71	48.9	YES	450
5	1.19	145	172.6	12.0	7.78	45.4	YES	450
6	1.07	145	155.2	12.0	7.63	42.5	YES	OFF
7	0.81	145	117.5	13.0	7.68	39.2	YES	OFF
8	1.33	145	192.9	12.0	7.73	45.3	YES	450
9	1.14	145	165.3	13.0	7.58	39.2	YES	450
10	0.98	145	142.1	14.0	7.72	37.9	YES	OFF
11	0.81	145	117.5	14.0	7.70	36.9	YES	OFF
12	0.79	145	114.6	13.0	7.69	39.2	YES	450
13	0.76	145	110.2	13.0	7.64	38.4	YES	450
14	1.10	145	159.5	13.0	7.67	40.3	YES	OFF
15	0.80	145	116.0	14.0	7.64	36.1	YES	OFF
16	0.75	145	108.8	13.0	7.80	40.7	YES	450
17	1.19	145	172.6	12.0	7.81	45.9	YES	450
18	1.13	145	163.9	13.0	7.82	42.8	YES	OFF
19	0.93	145	134.9	13.0	7.76	40.9	YES	OFF
20	0.91	145	132.0	13.0	7.82	41.7	YES	450
21	1.64	145	237.8	11.0	7.74	50.4	YES	450
22	1.34	145	194.3	13.0	7.93	45.6	YES	OFF
23	1.04	145	150.8	12.0	7.72	43.7	YES	OFF
24	1.05	145	152.3	13.0	7.78	41.8	YES	450
25	1.46	145	211.7	13.0	7.07	33.7	YES	450
26	1.12	145	162.4	13.0	7.64	40.0	YES	OFF
27	1.10	145	159.5	12.0	7.65	42.9	YES	OFF
28	0.72	145	104.4	12.0	7.79	43.2	YES	450
29	1.27	145	184.2	12.0	7.96	48.8	YES	450
30	1.02	145	147.9	11.0	7.84	48.6	YES	OFF
31	1.13	145	163.9	12.0	7.80	45.4	YES	OFF

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012