


OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jan-26

System Name:	City of Drain	ID#: 41 00260					WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	0.03	0.02	0.02	0.17
2	OFF	0.03	0.03	OFF	OFF	OFF	0.15
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	0.04	0.05	0.02	0.15
6	0.02	0.02	0.12	0.02	OFF	OFF	0.16
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	0.04	0.02	0.02	0.10
10	0.02	0.02	0.08	OFF	OFF	OFF	0.16
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	0.02	0.03	0.02	0.15
13	0.02	OFF	OFF	OFF	OFF	OFF	0.03
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	0.03	0.02	0.09	0.20
16	0.16	OFF	OFF	0.02	0.02	0.02	0.27
17	0.02	0.03	0.02	OFF	OFF	OFF	0.07
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	0.03	0.02	OFF	0.05
20	0.02	0.02	0.02	0.05	0.03	0.02	0.14
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	0.03	0.02	0.12
23	0.03	0.02	0.02	0.03	0.17	0.02	0.24
24	0.02	0.02	OFF	OFF	OFF	OFF	0.04
25	OFF	OFF	OFF	OFF	OFF	OFF	0.09
26	0.04	0.02	0.02	0.03	0.03	0.02	0.18
27	0.02	0.08	0.03	0.02	0.02	0.13	0.25
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	0.03	0.03	0.07
30	0.06	0.03	0.03	0.03	OFF	0.02	0.30
31	0.02	OFF	OFF	OFF	OFF	OFF	0.06

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
PRINTED NAME: Harold Burris		DATE: 02-05-2026
SIGNATURE: 		CERT #: 5248 FE
PHONE #: ( 541) 836-7301		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -- A

System Name: City of Drain	ID#: 41 00260	Month/Year: Jan-26	Disinfection <i>Giardia</i> Log Inactiv: 1.0
----------------------------	---------------	--------------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	295	309.8	12.0	7.73	43.9	YES	200
2	1.42	295	418.9	10.0	7.65	50.9	YES	200
3	1.23	295	362.9	12.0	7.67	43.9	YES	OFF
4	0.93	295	274.4	12.0	7.63	41.8	YES	OFF
5	0.94	295	277.3	12.0	7.66	42.3	YES	200
6	1.20	295	354.0	10.0	7.91	54.4	YES	200
7	1.13	295	333.4	12.0	7.96	48.1	YES	OFF
8	1.00	295	295.0	12.0	7.86	45.7	YES	OFF
9	1.40	295	413.0	12.0	7.69	45.1	YES	200
10	1.33	295	392.4	11.0	7.71	48.1	YES	200
11	1.06	295	312.7	13.0	7.72	40.9	YES	OFF
12	1.33	295	392.4	10.0	7.61	49.6	YES	200
13	1.20	295	354.0	11.0	7.83	49.5	YES	200
14	1.06	295	312.7	11.0	7.74	47.1	YES	OFF
15	1.04	295	306.8	12.0	7.69	43.3	YES	200
16	1.24	295	365.8	11.0	7.59	45.6	YES	200
17	1.19	295	351.1	9.0	7.69	53.7	YES	200
18	0.89	295	262.6	11.0	7.70	45.6	YES	OFF
19	0.85	295	250.8	10.0	7.78	49.9	YES	200
20	1.14	295	336.3	9.0	7.87	57.0	YES	200
21	0.98	295	289.1	10.0	7.61	47.7	OFF	OFF
22	1.12	295	330.4	11.0	7.73	47.3	YES	200
23	1.17	295	345.2	10.0	7.64	49.2	YES	200
24	1.05	295	309.8	9.0	7.67	52.5	YES	200
25	1.01	295	298.0	10.0	7.64	48.4	YES	200
26	1.02	295	300.9	10.0	7.69	49.3	YES	200
27	1.49	295	439.6	7.0	7.62	62.1	YES	200
28	0.96	295	283.2	10.0	7.54	46.4	OFF	OFF
29	0.84	295	247.8	9.0	7.65	50.9	YES	200
30	1.13	295	333.4	7.0	7.67	60.6	YES	200
31	1.03	295	303.9	8.0	7.63	55.2	YES	200

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012