

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jul-25

System Name:	City of Elkton			ID#: 41 00276	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.06	0.08	0.40	0.04	0.09	0.04	0.78
2	0.05	0.07	0.08	0.04	0.04	0.04	0.31
3	0.06	0.07	0.04	0.04	0.08	0.04	0.30
4	0.06	0.07	0.04	0.04	0.08	0.04	0.14
5	0.06	0.07	0.04	0.06	0.04	0.04	0.22
6	0.04	0.07	0.05	0.04	0.03	0.04	0.18
7	0.06	0.04	0.05	0.04	0.04	0.04	0.20
8	0.06	0.04	0.07	0.04	0.04	0.06	0.25
9	0.07	0.04	0.05	0.17	0.04	0.06	0.25
10	0.07	0.05	0.07	0.05	0.04	0.07	0.25
11	0.04	0.06	0.08	0.04	0.08	0.05	0.37
12	0.05	0.08	0.09	0.05	0.04	0.07	0.48
13	0.05	0.07	0.09	0.05	0.04	off	0.78
14	off	0.04	0.19	0.06	0.05	0.04	0.64
15	0.04	0.07	0.08	0.04	0.04	0.07	0.19
16	0.04	0.06	0.04	0.08	0.03	0.03	0.35
17	0.06	0.03	0.04	0.07	0.03	0.04	0.16
18	0.05	0.08	0.06	0.05	0.05	0.04	0.30
19	0.07	0.08	0.04	0.04	0.04	0.04	0.18
20	0.05	0.07	0.08	0.03	0.03	0.10	0.30
21	0.06	0.04	0.06	0.07	0.05	0.07	0.13
22	0.05	0.06	0.08	0.05	0.04	0.04	0.24
23	0.06	0.08	0.08	0.05	0.05	0.05	0.34
24	0.05	0.07	0.08	0.05	0.04	0.04	0.27
25	0.06	0.10	0.05	0.04	0.06	0.05	0.35
26	0.08	0.09	0.04	0.08	0.04	0.06	0.13
27	0.07	0.08	0.04	0.04	0.04	0.04	0.19
28	0.07	0.08	0.04	0.03	0.09	0.03	0.14
29	0.03	0.07	0.08	0.08	0.04	0.04	0.19
30	0.06	0.04	0.05	0.07	0.04	0.04	0.13
31	0.07	0.08	0.04	0.07	0.04	0.04	0.19

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Gary Trout

SIGNATURE:

8/8/2025

PHONE #: (541)584-2547

CERT #: 5316

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Elkton	ID#: 41 00276	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	----------------	---------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.1	50	55.0	24.0	7.00	7.5	YES	107
2	0.6	50	30.0	24.0	7.00	7.1	YES	107
3	0.8	50	40.0	23.0	7.00	7.7	YES	107
4	0.7	50	35.0	23.0	7.00	7.7	YES	108
5	0.7	50	35.0	22.0	7.00	8.2	YES	108
6	0.8	50	40.0	23.0	7.00	7.7	YES	108
7	0.8	50	40.0	23.0	7.00	7.7	YES	108
8	1	50	50.0	24.0	7.00	7.4	YES	108
9	1	50	50.0	24.0	7.00	7.4	YES	108
10	0.7	50	35.0	24.0	7.00	7.2	YES	108
11	0.7	50	35.0	24.0	7.00	7.2	YES	108
12	0.7	50	35.0	25.0	7.00	6.7	YES	108
13	0.8	50	40.0	25.0	7.00	6.8	YES	107
14	1	50	50.0	26.0	7.00	6.5	YES	108
15	0.7	50	35.0	26.0	7.00	6.2	YES	107
16	0.9	50	45.0	25.0	7.00	6.8	YES	107
17	1	50	50.0	25.0	7.00	6.9	YES	107
18	0.8	50	40.0	25.0	7.00	6.8	YES	108
19	0.6	50	30.0	25.0	7.00	6.6	YES	107
20	0.7	50	35.0	25.0	7.00	6.7	YES	107
21	0.4	50	20.0	24.0	7.00	6.9	YES	108
22	0.5	50	25.0	23.0	6.90	7.2	YES	107
23	0.4	50	20.0	25.0	7.00	6.4	YES	108
24	0.4	50	20.0	25.0	7.00	6.4	YES	108
25	1	50	50.0	25.0	7.00	6.9	YES	108
26	1	50	50.0	24.0	7.00	7.4	YES	108
27	0.7	50	35.0	24.0	7.00	7.2	YES	108
28	1	50	50.0	23.0	7.00	7.9	YES	108
29	1	50	50.0	23.0	7.00	7.9	YES	108
30	0.9	50	45.0	23.0	7.00	7.8	YES	108
31	1	50	50.0	24.0	7.00	7.4	YES	108

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350