

OHA - Drinking Water Program  
Turbidity Monitoring Report Form

County: Clackamas


System Name: City of Estacada PWS ID #: 4100279A WTP:-WTP-A Month/Year: Apr-21

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	
1	0.02	OFF	OFF	0.02	0.02	OFF	8:33 PM	0.03
2	0.02	OFF	OFF	0.02	0.02	0.02	10:50 PM	0.32
3	0.04	OFF	OFF	0.02	0.02	0.02	9:16 AM	0.03
4	0.02	OFF	OFF	0.03	0.02	0.02	2:09 PM	0.03
5	OFF	OFF	0.02	OFF	0.02	0.02	2:36 PM	0.03
6	OFF	0.02	OFF	0.03	0.02	0.02	11:33 AM	0.03
7	0.03	OFF	OFF	0.02	0.02	0.02	9:42 AM	0.03
8	OFF	OFF	0.02	0.02	0.02	0.02	3:48 PM	0.06
9	0.02	0.03	0.02	OFF	0.02	OFF	7:17 AM	0.03
10	0.02	0.02	OFF	0.03	0.02	0.02	7:44 PM	0.04
11	0.02	OFF	0.02	0.02	0.02	0.02	8:44 AM	0.03
12	OFF	0.03	OFF	0.03	0.03	0.02	11:52 AM	0.04
13	0.02	OFF	0.03	0.03	0.02	OFF	7:04 AM	0.04
14	0.02	OFF	OFF	OFF	0.02	0.02	11:26 AM	0.21
15	0.02	OFF	0.02	0.04	0.02	OFF	12:31 AM	0.03
16	0.02	OFF	0.02	0.02	0.05	OFF	3:21 PM	0.12
17	0.11	OFF	OFF	0.03	OFF	OFF	12:20 AM	0.25
18	0.03	OFF	0.03	0.03	0.03	OFF	9:29 AM	0.04
19	0.03	OFF	OFF	OFF	0.03	OFF	10:14 AM	0.04
20	OFF	OFF	OFF	0.04	OFF	OFF	10:50 PM	0.12
21	0.03	OFF	0.03	0.03	0.03	0.03	7:20 AM	0.10
22	OFF	0.03	OFF	0.03	OFF	OFF	7:47 AM	0.08
23	0.03	OFF	0.03	0.03	OFF	0.03	9:07 AM	0.13
24	OFF	OFF	0.04	OFF	0.04	OFF	8:09 AM	0.32
25	0.03	OFF	OFF	0.04	OFF	0.03	9:53 AM	0.02
26	OFF	OFF	0.03	0.03	0.03	0.03	7:15 AM	0.06
27	0.03	OFF	0.03	0.03	0.03	OFF	7:34 AM	0.04
28	0.03	OFF	0.03	0.03	0.03	0.03	5:07 AM	0.05
29	0.03	OFF	0.03	0.03	0.03	0.03	9:13 AM	0.05
30	0.03	0.03	0.03	0.03	0.03	0.03	3:38 AM	0.06
31								

Conventional or Direct Filtration <input type="checkbox"/>		Monthly Summary	
95% of Turbidity readings < MCL YES	CT's met every day YES	CI Residual at entry point always greater than or equal to .2 mg/l YES	CI measured in 95% of distribution samples YES
All Turbidity readings < 5 NTU YES	(see back of sheet)		
All Turbidity readings < IFE trigger YES			

**MCL:**

0.5 = Conventional and direct filtration  
1 = Slow sand and diatomaceous earth filters

Signature:   
Print Name: Chris Lewis  
Date: 5-3-2021  
Cert. #: T-6933

