

OHA - Drinking Water Program
Turbidity Monitoring Report Form

County: Clackamas

System Name: City of Estacada PWS ID #: 4100279A WTP-:WTP-A Month/Year: **Sep-22**

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	
1	0.05	OFF	0.05	0.05	OFF	0.05	5:05 PM	0.11
2	OFF	0.05	0.05	0.05	0.05	0.05	3:08 PM	0.09
3	OFF	0.05	0.05	OFF	OFF	0.05	1:12 AM	0.09
4	0.05	OFF	0.05	0.05	0.05	0.05	6:07 PM	0.10
5	0.05	OFF	0.05	0.05	0.05	0.05	4:40 AM	0.11
6	OFF	0.05	0.05	0.05	0.06	OFF	3:42 AM	0.10
7	0.05	OFF	0.05	0.05	0.07	OFF	5:28 AM	0.08
8	0.05	0.06	0.07	0.05	0.05	0.07	2:34 AM	0.10
9	0.05	OFF	0.05	0.05	0.05	0.06	7:07 PM	0.10
10	0.06	OFF	0.05	0.06	0.05	0.06	4:58 AM	0.10
11	0.06	OFF	0.05	0.06	0.06	0.06	6:53 PM	0.09
12	0.06	OFF	0.06	0.05	0.05	OFF	2:17 PM	0.10
13	0.06	OFF	0.06	0.07	0.06	OFF	3:24 PM	0.08
14	0.06	OFF	0.05	0.05	0.05	OFF	6:27 AM	0.08
15	0.06	OFF	0.06	0.05	OFF	OFF	7:49 AM	0.09
16	0.05	OFF	0.05	0.05	OFF	0.06	10:08 AM	0.08
17	0.06	0.06	0.05	0.05	0.05	OFF	11:00 AM	0.08
18	0.05	0.06	0.05	OFF	0.05	OFF	1:56 PM	0.10
19	0.07	0.06	0.05	OFF	0.04	OFF	5:16 PM	0.11
20	0.04	OFF	0.05	0.04	OFF	0.04	9:11 AM	0.10
21	0.04	OFF	0.04	0.05	OFF	0.04	5:33 AM	0.08
22	0.04	0.05	0.04	OFF	0.04	OFF	9:13 PM	0.09
23	0.04	OFF	0.04	0.04	0.07	OFF	3:02 PM	0.11
24	0.04	OFF	0.04	OFF	0.04	0.08	1:14 PM	0.08
25	0.04	0.04	0.04	OFF	0.04	OFF	10:45 PM	0.09
26	0.04	OFF	0.04	0.04	0.04	OFF	8:46 AM	0.07
27	0.05	OFF	0.04	0.04	OFF	OFF	8:34 PM	0.09
28	0.04	OFF	0.04	0.05	OFF	OFF	9:39 PM	0.11
29	0.05	OFF	0.04	0.04	OFF	0.04	7:27 AM	0.10
30	0.04	OFF	0.05	0.04	0.04	OFF	6:38 AM	0.12
31	OFF	OFF	OFF	OFF	OFF	OFF	12:00 AM	0.00

Conventional or Direct Filtration <input type="checkbox"/>		Monthly Summary	
95% of Turbidity readings < MCL YES	CT's met every day YES	CI Residual at entry point always greater than or equal to .2 mg/l YES	CI measured in 95% of distribution samples YES
All Turbidity readings < 5 NTU YES	(see back of sheet)		
All Turbidity readings < IFE trigger YES			

MCL:

0.5 = Conventional and direct filtration
1 = Slow sand and diatomaceous earth filters

Signature: 

Print Name: Chris Lewis

Date: 10-6-2022 Cert. #: T-6933

