

Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

System Name: City of Falls City

ID #: 4100797

Month/Year: May 2025

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							.05	375
2							.05	369
3							.05	365
4							.05	366
5							.05	384
6							.05	367
7							.05	376
8							.05	370
9							.05	376
10							.05	377
11							.05	368
12							.05	375
13							.05	359
14							.05	364
15							.05	357
16							.05	369
17							.05	345
18							.05	367
19							.05	365
20							.05	360
21							.05	362
22							.05	367
23							.05	377
24							.05	368
25							.05	379
26							.05	364
27							.05	380
28							.05	365
29							.05	369
30							.05	354
31							.05	375

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)		
95% of turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?	Cl ₂ residual measured in 95% of distribution samples?
All turbidity readings < 1 NTU?	Yes / No	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE triggers?	Yes / No ¹			
- OR -		PRINTED NAME: <u>Jonathan Creekmore</u>		
Slow Sand/Cartridge/Membrane/DE Filtration		SIGNATURE: <u>[Signature]</u>		DATE: <u>5-31-25</u>
95% of turbidity readings $\leq$ 1 NTU?	Yes / No	PHONE #: <u>(503) 767-3631</u>		CERT #:
All turbidity readings < 5 NTU?	Yes / No			

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name: City of Falls City ID #: 41 00297 Month/Year: May 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / No
1/	1.3	127	165	12	6.7	38	Yes
2/	1.3	127	165	12	6.7	38	Yes
3/	1.2	127	152	12	6.7	38	Yes
4/	1.3	127	165	12	6.7	38	Yes
5/	1.0	127	127	12	6.7	37	Yes
6/	1.2	127	152	12	6.7	38	Yes
7/	1.0	127	127	13	6.8	37	Yes
8/	1.2	127	152	12	6.8	38	Yes
9/	1.1	127	140	12	6.8	38	Yes
10/	1.3	127	165	12	6.8	38	Yes
11/	1.2	127	152	13	6.9	38	Yes
12/	1.3	127	165	12	6.9	38	Yes
13/	1.4	127	178	12	6.8	39	Yes
14/	1.5	127	191	12	6.9	39	Yes
15/	1.2	127	152	12	6.9	38	Yes
16/	1.1	127	140	12	6.9	38	Yes
17/	1.2	127	152	12	6.9	38	Yes
18/	1.3	127	165	12	6.9	38	Yes
19/	1.3	127	165	12	6.9	38	Yes
20/	1.4	127	178	12	6.9	39	Yes
21/	1.2	127	152	12	6.9	38	Yes
22/	1.2	127	152	12	7.0	38	Yes
23/	1.1	127	140	12	7.0	37	Yes
24/	1.4	127	178	12	7.0	39	Yes
25/	1.1	127	140	13	7.0	37	Yes
26/	1.0	127	127	13	6.9	37	Yes
27/	1.1	127	140	13	7.0	38	Yes
28/	1.2	127	152	14	7.0	38	Yes
29/	1.3	127	165	14	6.9	38	Yes
30/	1.2	127	152	15	6.9	25	Yes
31/	1.1	127	140	15	7.0	25	Yes