

Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: City of Falls City ID #: 41 00297 Month/Year: 2-26

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							0.06	422
2							0.07	430
3							0.07	425
4							0.07	428
5							0.06	434
6							0.06	429
7							0.06	430
8							0.07	438
9							0.07	450
10							0.07	438
11							0.06	444
12							0.06	440
13							0.06	440
14							0.06	438
15							0.06	433
16							0.06	425
17							0.06	42.3
18							0.06	438
19							0.06	434
20							0.06	434
21							0.06	440
22							0.06	440
23							0.06	440
24							0.06	438
25							0.07	440
26							0.07	425
27							0.06	439
28							0.06	437
29								
30								
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)		
95% of turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	Cl ₂ residual measured in 95% of distribution samples?
All turbidity readings < 1 NTU?	Yes / No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE triggers?	Yes / No ¹			
- OR -		PRINTED NAME: <u>Jonathan Creekmore</u>		
Slow Sand/Cartridge/Membrane/DE Filtration		SIGNATURE: <u>[Signature]</u>	DATE: <u>3-1-2026</u>	
95% of turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PHONE #: <u>503 1787-3631</u>	CERT #:	
All turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No			

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name: City of Falls City ID #: 41 00297 Month/Year: 2-26

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	Yes / No
1/	1.2	127	152	9	7.0	51	yes
2/	1.0	127	127	9	6.9	50	yes
3/	0.9	127	114	9	6.9	50	yes
4/	0.9	127	114	9	6.9	50	yes
5/	1.1	127	140	9	6.9	51	yes
6/	1.2	127	152	9	6.9	51	yes
7/	1.4	127	178	9	6.9	52	yes
8/	1.3	127	165	9	6.9	52	yes
9/	0.90	127	114	9	6.9	49	yes
10/	1.2	127	152	9	7.0	51	yes
11/	1.3	127	165	9	7.0	52	yes
12/	1.6	127	203	9	7.0	53	yes
13/	1.3	127	165	9	7.0	52	yes
14/	1.2	127	152	8	7.0	51	yes
15/	1.7	127	215	9	7.0	53	yes
16/	1.4	127	178	8	7.0	52	yes
17/	1.0	127	127	8	7.0	50	yes
18/	1.0	127	127	8	7.0	50	yes
19/	1.1	127	140	8	7.0	50	yes
20/	1.2	127	152	7	7.0	51	yes
21/	1.2	127	152	7	7.0	51	yes
22/	1.2	127	152	7	7.0	51	yes
23/	1.2	127	152	8	7.0	51	yes
24/	1.1	127	140	8	7.0	50	yes
25/	1.4	127	178	8	7.0	52	yes
26/	1.2	127	152	8	7.0	51	yes
27/	1.2	127	152	8	7.0	51	yes
28/	1.3	127	165	8	7.0	52	yes
29/							
30/							
31/							