


OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Feb-22

System Name:	Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.03	0.04	0.04	off	0.08
2	off	0.04	off	0.04	0.04	off	0.04
3	off	off	off	0.04	off	off	0.04
4	0.04	off	off	0.04	off	0.04	0.04
5	0.04	0.04	0.04	off	0.04	off	0.04
6	off	off	0.03	0.04	off	off	0.05
7	off	0.04	off	0.04	off	off	0.05
8	0.03	off	0.03	off	0.04	0.04	0.05
9	0.04	off	0.04	0.04	off	off	0.06
10	0.04	off	off	0.04	0.04	off	0.06
11	off	0.04	0.04	0.04	off	off	0.05
12	0.04	off	off	0.04	off	off	0.05
13	0.04	off	0.04	0.04	off	0.04	0.05
14	off	off	0.04	off	0.04	0.04	0.08
15	0.04	0.04	0.04	off	0.04	off	0.05
16	off	off	off	off	0.04	off	0.05
17	0.04	off	0.04	0.04	off	off	0.05
18	0.04	off	0.04	0.04	off	0.04	0.05
19	0.05	0.04	off	0.04	off	off	0.05
20	0.04	off	0.04	0.04	off	off	0.05
21	0.05	off	off	0.05	off	off	0.06
22	0.05	off	0.05	0.06	0.06	off	0.07
23	off	0.06	0.07	0.04	0.04	off	0.07
24	0.04	off	0.04	0.04	0.04	off	0.07
25	0.04	off	off	0.04	off	0.04	0.05
26	0.04	0.04	0.04	off	0.04	0.04	0.04
27	off	off	0.04	off	0.03	off	0.05
28	0.03	0.04	0.04	0.04	0.04	0.04	0.04
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	Carl Neville	
	SIGNATURE: 	DATE: 3-1-2022
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name: Heceta WPUD ID#: 41 00301A Month/Year: 2/1/2022

Disinfection *Giardia*
Log Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	78	78.0	8.5	6.30	16.7	Yes	553
2	1	78	78.0	8.7	6.50	17.7	yes	580
3	1	78	78.0	8.8	6.40	17.0	yes	595
4	1	78	78.0	8.6	6.40	17.2	yes	602
5	1	78	78.0	8.8	6.90	20.2	yes	543
6	1	78	78.0	8.8	6.40	17.0	yes	606
7	1.01	78	78.8	9.3	6.40	16.5	yes	594
8	1.02	78	79.6	8.9	6.40	16.9	yes	510
9	1.06	78	82.7	9.1	6.50	17.3	yes	543
10	1.01	78	78.8	9.3	6.60	17.6	yes	599
11	1.05	78	81.9	9.3	6.30	16.0	yes	578
12	0.95	78	74.1	9.7	6.50	16.5	yes	495
13	0.95	78	74.1	9.7	6.70	17.6	yes	536
14	0.91	78	71.0	9.6	6.50	16.0	yes	581
15	0.98	78	76.4	9.3	6.90	19.5	yes	507
16	0.94	78	73.3	9.9	6.50	16.3	yes	577
17	0.91	78	71.0	9.5	6.60	17.2	yes	697
18	0.94	78	73.3	9.4	6.80	18.6	yes	607
19	0.94	78	73.3	9.6	6.70	17.7	yes	535
20	0.94	78	73.3	9.6	6.50	16.6	yes	611
21	0.91	78	71.0	9.6	6.70	17.7	yes	540
22	0.9	78	70.2	9.3	6.50	16.8	yes	515
23	0.92	78	71.8	9.1	6.60	17.7	yes	525
24	0.91	78	71.0	9.0	6.60	17.8	yes	520
25	0.91	78	71.0	9.0	6.30	16.0	yes	494
26	0.93	78	72.5	9.2	6.20	15.3	yes	500
27	0.9	78	70.2	9.2	6.30	15.8	yes	498
28	0.97	78	75.7	9.5	6.10	14.6	yes	646
29			0.0			4.2		
30			0.0			4.2		
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.