


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Lane**
 Month/Year: **Nov-22**

System Name:	Haceta WPUD		ID#: 41	00301A			WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	off	off	0.06	off	off	0.06	0.08	
2	0.06	off	0.06	0.06	off	off	0.08	
3	0.06	off	off	off	0.05	0.06	0.08	
4	off	off	0.06	off	off	0.06	0.08	
5	0.06	off	0.06	0.06	off	off	0.07	
6	0.05	off	off	0.05	off	off	0.07	
7	0.05	off	off	off	0.05	off	0.07	
8	off	off	0.05	0.05	0.05	off	0.08	
9	off	off	0.05	off	0.05	off	0.07	
10	off	off	0.05	0.05	0.05	0.05	0.07	
11	off	0.05	0.05	off	off	0.05	0.06	
12	off	off	off	0.05	off	off	0.07	
13	off	0.04	off	0.05	0.04	off	0.07	
14	off	0.05	off	off	off	0.04	0.06	
15	0.05	off	0.05	off	off	0.05	0.06	
16	off	off	off	0.04	off	off	0.06	
17	0.04	off	off	0.04	off	off	0.06	
18	0.04	off	off	0.04	0.04	off	0.06	
19	0.04	0.04	0.04	off	0.04	off	0.05	
20	off	off	0.04	off	off	0.04	0.06	
21	off	off	0.04	0.04	off	off	0.06	
22	0.04	off	0.04	off	off	off	0.05	
23	0.05	off	0.04	0.04	0.04	0.04	0.06	
24	0.04	off	0.04	0.04	0.04	off	0.06	
25	off	0.04	0.04	0.04	off	0.05	0.20	
26	0.04	off	0.05	0.04	off	off	0.05	
27	0.04	off	off	0.04	off	0.04	0.06	
28	0.04	0.04	0.04	off	off	0.04	0.06	
29	0.04	off	off	0.04	0.04	off	0.06	
30	off	off	0.04	0.04	0.04	0.04	0.07	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		
Notes:	Carl Neville	
	SIGNATURE: 	DATE: 12-1-2022
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	11/1/2022	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------	---------	--------	-------------	-----------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	78	68.6	17.5	6.80	10.5	yes	667
2	0.94	78	73.3	17.1	7.00	11.7	yes	662
3	0.89	78	69.4	16.6	6.80	11.2	yes	613
4	0.89	78	69.4	16.4	7.00	12.2	yes	672
5	0.97	78	75.7	16.3	7.00	12.4	yes	671
6	0.85	78	66.3	16.0	6.70	11.2	yes	625
7	0.93	78	72.5	15.4	6.10	9.4	yes	694
8	0.9	78	70.2	15.0	6.10	9.6	yes	666
9	0.9	78	70.2	14.9	6.60	11.7	yes	669
10	0.92	78	71.8	14.6	6.50	11.5	yes	661
11	0.88	78	68.6	14.7	6.40	11.0	yes	608
12	0.84	78	65.5	14.4	6.40	11.1	yes	622
13	0.88	78	68.6	14.2	6.50	11.8	yes	670
14	0.89	78	69.4	13.9	6.40	11.6	yes	658
15	0.93	78	72.5	13.8	6.80	13.6	yes	673
16	0.86	78	67.1	13.7	6.50	12.1	yes	592
17	0.87	78	67.9	13.5	6.50	12.3	yes	652
18	0.9	78	70.2	13.0	6.70	13.8	yes	655
19	0.89	78	69.4	12.8	6.60	13.4	yes	608
20	0.83	78	64.7	12.5	6.70	14.1	yes	618
21	0.88	78	68.6	12.7	6.50	13.0	yes	612
22	1.02	78	79.6	12.6	6.40	12.8	yes	619
23	1.09	78	85.0	12.7	6.30	12.4	yes	583
24	0.96	78	74.9	12.6	6.90	15.3	yes	658
25	0.8	78	62.4	12.5	6.60	13.6	yes	617
26	0.89	78	69.4	12.3	6.60	14.4	yes	654
27	1	78	78.0	12.4	6.80	15.5	yes	664
28	0.97	78	75.7	12.3	6.50	14.0	yes	605
29	0.9	78	70.2	12.1	6.50	14.1	yes	617
30	0.82	78	64.0	12.2	6.50	13.9	yes	577
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012