


OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Lane
Month/Year: Jun-23

System Name:	Haceta WPUD		ID#: 41	00301A			WTP: TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	off	off	0.03	0.03	0.03	off	0.04	
2	0.03	off	0.03	0.03	0.03	0.03	0.04	
3	0.03	0.03	0.03	0.03	0.03	off	0.04	
4	0.03	off	0.03	0.03	0.03	off	0.04	
5	0.03	off	0.03	0.03	0.03	0.03	0.06	
6	0.03	0.03	0.03	0.03	0.03	off	0.04	
7	0.03	off	0.03	0.03	0.03	0.03	0.04	
8	off	off	0.03	0.03	0.03	off	0.05	
9	0.03	off	0.03	0.03	off	0.03	0.05	
10	0.03	0.04	0.03	0.03	0.03	off	0.04	
11	0.03	off	0.03	0.03	0.03	0.03	0.05	
12	off	off	0.03	0.03	0.03	0.03	0.05	
13	0.03	0.03	0.03	0.03	0.03	off	0.04	
14	off	off	0.04	0.03	0.03	0.03	0.04	
15	off	off	0.03	0.03	0.03	0.03	0.05	
16	off	off	0.03	0.03	0.03	0.03	0.05	
17	0.03	0.03	0.03	0.03	0.03	off	0.04	
18	off	off	0.03	0.03	0.03	0.03	0.05	
19	off	0.03	0.04	0.03	off	0.03	0.05	
20	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
21	off	0.03	0.04	0.03	0.03	0.03	0.04	
22	off	off	0.03	0.03	0.03	0.03	0.05	
23	off	0.03	0.03	0.03	0.03	0.03	0.05	
24	0.03	off	0.03	0.03	0.03	0.03	0.04	
25	off	0.03	off	0.03	0.03	0.03	0.04	
26	off	off	0.03	0.03	0.03	0.03	0.04	
27	0.03	0.03	0.03	0.03	0.03	off	0.04	
28	off	off	0.03	0.03	0.03	0.03	0.04	
29	0.03	off	0.03	0.04	0.03	0.03	0.04	
30	0.03	off	0.03	0.03	0.03	0.03	0.04	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		
Notes:	Carl Neville	
	SIGNATURE: 	DATE: 7-3-23
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Jun-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------	---------	--------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.93	78	72.5	19.8	6.60	8.4	yes	633
2	0.9	78	70.2	19.8	6.50	8.1	yes	638
3	0.99	78	77.2	20.1	6.10	6.9	yes	666
4	0.91	78	71.0	20.0	6.50	8.0	yes	649
5	0.86	78	67.1	20.0	6.30	7.3	yes	653
6	0.92	78	71.8	20.2	6.10	6.8	yes	677
7	0.84	78	65.5	20.4	6.70	8.3	yes	639
8	0.89	78	69.4	20.3	6.30	7.2	yes	628
9	0.91	78	71.0	20.5	6.30	7.1	yes	678
10	0.9	78	70.2	20.7	6.50	7.6	yes	626
11	0.86	78	67.1	20.9	6.20	6.6	yes	654
12	0.85	78	66.3	21.1	6.20	6.5	yes	590
13	0.93	78	72.5	21.6	6.00	5.9	yes	663
14	0.84	78	65.5	21.4	6.20	6.4	yes	663
15	0.83	78	64.7	21.4	6.10	6.2	yes	647
16	0.89	78	69.4	21.4	6.10	6.2	yes	683
17	0.86	78	67.1	21.6	6.20	6.3	yes	674
18	0.82	78	64.0	21.7	6.30	6.5	yes	659
19	0.83	78	64.7	21.3	6.40	7.0	yes	678
20	0.86	78	67.1	21.3	6.00	6.0	yes	668
21	0.81	78	63.2	21.1	6.40	7.0	yes	660
22	0.85	78	66.3	21.6	6.20	6.3	yes	596
23	0.85	78	66.3	21.6	6.20	6.3	yes	596
24	0.88	78	68.6	21.8	6.90	8.2	yes	670
25	0.96	78	74.9	21.8	6.00	5.8	yes	670
26	0.88	78	68.6	22.0	6.50	6.9	yes	621
27	0.98	78	76.4	22.3	6.10	5.9	yes	648
28	0.98	78	76.4	22.2	6.10	5.9	yes	673
29	0.9	78	70.2	22.4	6.80	7.6	yes	655
30	0.9	78	70.2	22.6	6.40	6.4	yes	658
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012