


OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:	Lane
Month/Year:	Jul-24

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	0.03	0.03	0.03	0.03	off	0.04
2	0.03	off	0.03	0.03	0.03	0.03	0.05
3	off	0.03	0.03	0.03	0.03	0.03	0.04
4	0.03	off	0.03	0.03	0.03	0.03	0.05
5	off	off	0.03	0.03	0.03	0.03	0.05
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.04
8	off	off	0.03	0.03	0.03	0.03	0.04
9	0.03	0.03	0.03	0.03	0.03	off	0.04
10	off	off	0.03	0.03	0.03	0.03	0.06
11	off	0.03	0.03	0.03	0.03	0.03	0.04
12	off	off	0.03	0.03	0.03	0.03	0.05
13	0.03	0.03	0.03	0.03	0.03	off	0.04
14	0.03	off	0.03	0.03	0.03	off	0.04
15	off	off	0.03	0.03	0.03	0.03	0.05
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	off	0.03	0.03	0.03	0.03	off	0.04
18	0.03	off	0.03	0.03	0.03	off	0.04
19	0.03	off	0.03	0.03	off	0.03	0.04
20	0.03	0.03	0.03	0.03	off	0.03	0.04
21	off	0.03	off	0.03	0.03	0.03	0.04
22	0.03	off	0.03	0.03	0.03	0.03	0.06
23	0.03	off	0.03	0.03	0.03	0.03	0.04
24	0.03	0.03	0.03	0.03	0.03	0.03	0.04
25	off	0.03	0.03	0.03	0.03	off	0.04
26	0.03	off	0.03	0.03	0.03	0.03	0.04
27	0.03	off	0.03	0.03	0.03	0.03	0.04
28	off	0.03	off	0.03	0.03	0.03	0.04
29	0.03	off	0.03	0.03	0.03	off	0.04
30	off	0.04	0.03	0.03	0.03	off	0.04
31	0.03	off	0.03	0.03	off	0.03	0.04

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 0.3 NTU?			Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?			Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers			Yes / No	Yes / No	Yes / No

Notes:	Carl Neville				
	SIGNATURE: 				
	DATE: 8-1-24				
PHONE #: (541) 997-2446					
CERT #: FE0103					

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	0301A
Disinfection Giardia Log Inactiv:	0.5

System Name: Heceta WPUD ID#: 41 00301A Month/Year: Jul-24

Date / Time	' Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.97	78	75.7	23.4	6.10	5.4	Yes	660
2	0.88	78	68.6	23.4	6.20	5.6	Yes	633
3	0.94	78	73.3	23.6	6.20	5.6	yes	656
4	0.9	78	70.2	23.6	6.10	5.3	yes	636
5	0.9	78	70.2	23.8	6.20	5.5	yes	618
6	0.95	78	74.1	24.3	6.00	4.9	yes	689
7	0.91	78	71.0	24.9	6.10	4.9	yes	640
8	0.88	78	68.6	24.9	6.20	5.0	yes	609
9	0.93	78	72.5	25.5	6.00	4.5	yes	655
10	0.85	78	66.3	25.3	6.20	4.9	yes	675
11	0.96	78	74.9	25.4	6.00	4.5	yes	689
12	0.91	78	71.0	24.9	6.00	4.7	yes	687
13	1	78	78.0	25.0	6.00	4.7	yes	664
14	0.98	78	76.4	27.8	6.00	3.8	yes	652
15	0.92	78	71.8	24.6	6.00	4.8	yes	690
16	0.99	78	77.2	25.0	6.00	4.7	yes	687
17	0.97	78	75.7	24.5	6.00	4.8	yes	689
18	0.95	78	74.1	24.2	6.00	4.9	yes	612
19	0.96	78	74.9	24.2	6.00	4.9	yes	688
20	0.93	78	72.5	24.8	6.80	6.4	yes	638
21	0.9	78	70.2	24.6	6.00	4.8	yes	526
22	0.85	78	66.3	24.5	6.10	5.0	yes	567
23	0.96	78	74.9	24.1	6.00	5.0	yes	693
24	0.95	78	74.1	24.1	6.00	5.0	yes	665
25	0.89	78	69.4	23.9	6.00	5.0	yes	649
26	0.91	78	71.0	23.8	5.90	4.9	yes	635
27	0.99	78	77.2	23.9	6.00	5.1	yes	686
28	0.99	78	77.2	23.8	6.00	5.1	yes	693
29	0.98	78	76.4	24.0	6.00	5.0	yes	673
30	0.93	78	72.5	23.5	6.10	5.4	yes	660
31	0.97	78	75.7	23.6	6.00	5.2	yes	586

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012