

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Lane**
 Month/Year: **Aug-24**

System Name: **Haceta WPUD** ID#: **41** **00301A** WTP : **TP - 00301A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	0.03	0.03	0.03	0.03	0.04	0.05
2	off	0.03	off	0.03	0.03	0.03	0.04
3	0.03	off	0.03	0.03	0.03	0.04	0.04
4	off	off	0.03	0.03	0.03	0.03	0.04
5	off	0.03	0.03	0.03	0.03	0.03	0.04
6	off	0.03	0.03	0.03	off	0.03	0.04
7	off	0.03	0.03	0.03	0.03	0.03	0.04
8	off	0.03	off	0.03	0.03	0.03	0.04
9	0.03	off	0.03	0.03	0.03	0.03	0.04
10	0.03	0.03	0.03	0.03	0.03	off	0.04
11	off	off	0.03	0.03	0.03	off	0.04
12	off	off	0.04	0.03	0.03	0.03	0.04
13	0.03	0.03	0.03	0.03	0.03	off	0.04
14	off	0.04	0.03	0.03	0.03	off	0.04
15	0.03	off	0.03	0.03	0.03	off	0.06
16	off	off	0.03	0.03	0.03	0.03	0.05
17	0.03	off	0.03	0.04	off	0.03	0.04
18	off	0.03	off	0.03	0.03	off	0.04
19	off	0.03	off	0.03	0.03	0.03	0.04
20	off	0.03	off	0.03	0.03	0.03	0.04
21	0.03	0.03	0.03	0.04	0.03	off	0.04
22	0.03	off	0.03	0.03	0.03	off	0.04
23	0.03	off	0.03	0.03	0.03	0.03	0.05
24	off	0.03	0.03	off	0.03	0.03	0.04
25	off	0.03	off	0.03	0.03	off	0.04
26	0.03	off	0.03	0.04	off	0.03	0.04
27	off	0.03	0.03	off	0.03	0.03	0.04
28	0.03	0.04	0.03	0.03	0.03	off	0.05
29	0.03	off	0.03	off	0.03	0.04	0.04
30	off	off	0.03	0.03	0.03	0.03	0.04
31	0.04	off	0.03	0.03	0.03	0.03	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No

Notes:	Carl Neville	
	SIGNATURE: 	DATE: 9-3-24
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	0301A
Disinfection <i>Giardia</i> Log Inactiv:	0.5

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Aug-24
--------------	-------------	---------	--------	-------------	--------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.92	78	71.8	23.8	6.10	5.3	yes	640
2	0.95	78	74.1	24.3	6.00	4.9	yes	691
3	0.93	78	72.5	24.3	6.20	5.3	yes	641
4	0.93	78	72.5	24.2	6.00	4.9	yes	635
5	0.88	78	68.6	24.0	6.30	5.6	yes	603
6	0.92	78	71.8	23.9	6.60	6.3	yes	624
7	0.88	78	68.6	23.7	6.10	5.3	yes	633
8	0.97	78	75.7	24.1	6.10	5.2	yes	678
9	0.95	78	74.1	23.9	6.30	5.7	yes	608
10	0.97	78	75.7	23.9	6.10	5.3	yes	646
11	0.99	78	77.2	23.8	6.10	5.3	yes	650
12	0.98	78	76.4	23.7	6.10	5.3	yes	654
13	0.99	78	77.2	23.8	6.10	5.3	yes	675
14	0.95	78	74.1	23.7	6.10	5.3	yes	694
15	0.95	78	74.1	23.9	6.40	5.9	yes	632
16	0.96	78	74.9	23.8	6.20	5.5	yes	692
17	0.95	78	74.1	24.0	6.30	5.6	yes	637
18	0.95	78	74.1	23.7	6.30	5.7	yes	647
19	0.92	78	71.8	23.4	6.20	5.6	yes	679
20	0.96	78	74.9	23.6	6.30	5.8	yes	632
21	0.95	78	74.1	23.8	6.40	5.9	yes	662
22	0.92	78	71.8	23.7	6.40	6.0	yes	605
23	0.86	78	67.1	23.4	6.30	5.8	yes	666
24	0.93	78	72.5	23.2	7.00	7.8	yes	619
25	0.93	78	72.5	22.9	6.20	5.8	yes	606
26	0.93	78	72.5	23.2	6.30	5.9	yes	669
27	0.93	78	72.5	23.4	6.20	5.6	yes	669
28	0.91	78	71.0	23.2	6.30	5.9	yes	648
29	0.91	78	71.0	23.1	6.00	5.3	yes	654
30	0.9	78	70.2	23.2	6.00	5.3	yes	695
31	0.91	78	71.0	23.2	6.20	5.7	yes	624

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012