


OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Lane
 Month/Year: Sep-24

Conventional or Direct Filtration

System Name:	Haceta WPUD			ID#: 41	00301A	WTP : TP - 00301A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	0.03	off	0.03	0.03	off	0.04
2	off	0.03	off	0.03	0.03	off	0.04
3	0.03	0.03	0.03	off	0.03	off	0.04
4	0.03	off	0.03	off	0.03	0.03	0.04
5	off	off	0.03	0.03	0.03	0.03	0.04
6	off	off	0.03	0.03	0.03	0.03	0.04
7	0.03	0.03	0.03	0.03	off	0.03	0.04
8	off	off	0.03	0.03	off	0.03	0.04
9	off	0.03	0.03	0.03	0.03	0.03	0.04
10	off	off	0.03	0.03	0.03	0.03	0.05
11	0.03	0.03	0.03	0.03	off	off	0.04
12	off	0.03	0.03	off	off	0.03	0.04
13	off	off	0.03	0.03	0.03	off	0.04
14	0.03	0.03	off	0.03	off	off	0.04
15	0.03	off	0.03	0.03	0.03	off	0.06
16	0.03	off	0.03	0.03	0.03	0.03	0.06
17	0.03	off	0.03	0.03	off	off	0.04
18	off	0.03	0.03	0.03	off	off	0.05
19	0.04	off	0.03	0.03	off	off	0.05
20	0.03	off	0.03	0.04	0.04	0.04	0.04
21	off	0.03	0.03	0.03	off	off	0.04
22	0.04	off	0.03	0.04	0.04	off	0.05
23	off	0.03	0.04	0.04	0.04	off	0.05
24	off	off	0.03	0.04	0.04	off	0.04
25	off	0.03	off	0.04	0.03	off	0.05
26	0.03	off	0.03	0.03	off	off	0.05
27	off	off	0.03	0.03	0.03	off	0.04
28	0.03	0.03	0.03	off	0.03	off	0.04
29	off	0.03	off	0.03	0.03	off	0.05
30	0.03	off	0.03	0.03	0.03	off	0.04
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		
Notes:	Carl Neville	
	SIGNATURE: 	DATE: 10.22.24
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Sep-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------	---------	--------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	78	68.6	23.0	6.10	5.5	Yes	616
2	0.87	78	67.9	22.8	6.10	5.6	Yes	674
3	0.91	78	71.0	22.7	6.20	5.9	Yes	649
4	0.86	78	67.1	22.7	6.50	6.6	Yes	645
5	0.86	78	67.1	22.8	6.40	6.3	Yes	614
6	0.93	78	72.5	23.1	6.40	6.2	Yes	644
7	1.03	78	80.3	23.2	6.60	6.7	Yes	648
8	1.1	78	85.8	23.0	6.20	5.9	Yes	643
9	1.02	78	79.6	22.9	6.50	6.6	yes	642
10	0.97	78	75.7	23.0	6.60	6.8	yes	608
11	1	78	78.0	23.1	6.30	6.0	yes	635
12	0.91	78	71.0	22.7	6.00	5.5	yes	622
13	0.88	78	68.6	22.3	6.00	5.6	yes	622
14	0.98	78	76.4	22.5	6.10	5.8	yes	628
15	1.04	78	81.1	22.3	5.90	5.5	yes	637
16	1.06	78	82.7	22.0	6.30	6.6	yes	667
17	1	78	78.0	22.2	6.20	6.2	yes	634
18	1.02	78	79.6	21.8	6.30	6.6	yes	618
19	0.99	78	77.2	21.7	6.30	6.6	yes	660
20	0.92	78	71.8	21.4	6.10	6.2	yes	622
21	0.94	78	73.3	21.5	6.20	6.4	yes	679
22	0.98	78	76.4	21.3	5.90	5.8	yes	630
23	0.92	78	71.8	21.4	6.00	6.0	yes	658
24	0.91	78	71.0	19.7	6.70	8.8	yes	640
25	0.91	78	71.0	19.8	6.70	8.7	yes	681
26	0.94	78	73.3	19.2	6.70	9.1	yes	639
27	0.95	78	74.1	19.2	6.70	9.1	yes	665
28	0.93	78	72.5	19.4	6.60	8.6	yes	613
29	0.92	78	71.8	18.9	6.60	8.9	yes	663
30	0.9	78	70.2	18.7	6.60	9.0	yes	641
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012