

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Lane

Conventional or Direct Filtration

Month/Year: Oct-24

System Name:	Haceta WPUD		ID#: 41	00301A			WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	off	0.04	0.03	0.03	off	0.04	
2	off	0.03	0.03	0.03	off	off	0.04	
3	0.03	off	0.03	0.03	0.03	off	0.04	
4	0.03	off	0.03	0.03	0.03	off	0.04	
5	0.03	0.03	0.03	off	0.03	0.03	0.05	
6	off	0.03	off	0.03	0.03	off	0.04	
7	0.03	off	0.03	0.03	0.03	off	0.04	
8	off	0.03	0.03	0.03	0.03	off	0.04	
9	0.03	off	0.03	0.03	off	off	0.04	
10	0.03	off	0.03	0.03	off	off	0.06	
11	0.03	off	0.03	0.03	0.03	0.03	0.04	
12	off	0.03	0.03	0.03	off	0.03	0.04	
13	off	off	0.03	0.03	0.03	off	0.05	
14	0.03	off	0.03	0.03	off	off	0.05	
15	0.03	off	0.03	0.03	0.04	0.03	0.13	
16	off	off	0.03	0.03	off	off	0.05	
17	0.03	off	0.03	off	off	0.03	0.05	
18	off	off	0.03	0.03	0.03	0.03	0.05	
19	0.03	off	0.03	0.03	off	off	0.05	
20	0.03	off	off	0.03	0.04	off	0.05	
21	off	0.03	off	0.03	0.03	off	0.05	
22	off	off	off	0.03	0.03	off	0.04	
23	0.03	off	0.03	0.03	off	0.03	0.04	
24	off	off	0.03	0.03	off	0.04	0.05	
25	off	off	0.03	0.03	off	0.03	0.05	
26	0.03	0.03	0.03	off	0.03	off	0.05	
27	off	off	0.04	off	0.03	0.03	0.05	
28	off	off	0.04	0.04	off	off	0.05	
29	0.03	off	0.03	off	off	0.03	0.05	
30	off	off	0.04	0.04	off	off	0.05	
31	0.03	off	0.03	off	off	0.03	0.05	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 11-1-2024
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Oct-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
---------------------	-------------	----------------	--------	--------------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.92	78	71.8	18.7	6.50	8.7	Yes	634
2	0.92	78	71.8	18.8	6.50	8.7	Yes	633
3	0.89	78	69.4	18.4	6.50	8.9	Yes	662
4	0.88	78	68.6	18.3	6.50	8.9	Yes	652
5	0.92	78	71.8	18.2	6.50	9.0	Yes	605
6	0.9	78	70.2	18.0	6.50	9.1	yes	640
7	0.88	78	68.6	18.1	6.50	9.0	yes	666
8	0.92	78	71.8	18.2	6.60	9.4	Yes	638
9	0.9	78	70.2	18.2	6.50	9.0	Yes	654
10	0.86	78	67.1	17.8	6.50	9.2	Yes	628
11	0.93	78	72.5	17.7	6.50	9.3	yes	689
12	0.91	78	71.0	17.9	6.70	9.9	yes	657
13	0.91	78	71.0	17.8	6.50	9.3	yes	678
14	0.86	78	67.1	17.9	6.60	9.5	Yes	650
15	0.86	78	67.1	17.9	6.60	9.5	Yes	627
16	0.88	78	68.6	17.8	6.50	9.2	Yes	602
17	0.88	78	68.6	17.5	6.50	9.4	Yes	615
18	0.87	78	67.9	17.1	6.50	9.7	Yes	614
19	0.94	78	73.3	17.3	6.60	10.0	Yes	646
20	0.89	78	69.4	17.1	6.50	9.7	Yes	677
21	0.91	78	71.0	17.0	6.60	10.1	yes	681
22	0.91	78	71.0	16.6	6.50	10.0	yes	616
23	0.9	78	70.2	16.4	6.40	9.8	yes	634
24	0.87	78	67.9	16.0	6.40	10.0	yes	626
25	0.89	78	69.4	15.8	6.50	10.6	yes	660
26	0.92	78	71.8	16.1	6.50	10.4	yes	605
27	0.92	78	71.8	15.8	6.40	10.2	yes	591
28	0.9	78	70.2	15.6	6.40	10.3	Yes	598
29	0.88	78	68.6	15.3	6.50	10.9	Yes	589
30	0.85	78	66.3	15.1	6.50	11.0	Yes	622
31	0.86	78	67.1	14.9	6.50	11.2	Yes	605

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012