

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:	Lane
Month/Year:	Nov-24

System Name:	Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.03	0.04	off	0.03	0.05
2	0.03	0.03	0.03	off	0.04	0.03	0.04
3	off	off	0.03	0.03	off	0.03	0.05
4	off	off	off	off	0.03	0.03	0.06
5	off	off	0.03	off	off	0.03	0.05
6	0.03	off	0.03	0.03	0.04	off	0.05
7	off	0.03	off	0.04	0.03	off	0.05
8	off	off	0.03	off	0.03	0.04	0.05
9	0.04	0.04	off	0.04	off	off	0.04
10	0.03	off	off	0.03	off	off	0.05
11	0.03	off	off	0.04	off	off	0.05
12	0.03	off	off	0.03	off	off	0.05
13	0.03	off	off	0.04	0.03	off	0.05
14	off	off	0.04	off	off	0.03	0.05
15	off	off	0.03	0.04	off	0.03	0.05
16	0.04	0.03	0.03	off	0.04	off	0.04
17	off	off	0.03	0.03	off	off	0.05
18	0.03	off	0.03	0.03	off	off	0.05
19	0.03	off	0.03	0.03	off	off	0.05
20	off	off	0.03	off	off	0.03	0.04
21	off	off	0.03	off	off	0.03	0.05
22	off	off	off	0.03	off	0.03	0.04
23	0.03	0.03	0.03	off	off	0.04	0.05
24	off	off	0.03	off	off	0.03	0.05
25	off	off	0.03	off	0.03	off	0.05
26	off	0.03	off	0.03	0.03	off	0.05
27	off	off	off	0.03	0.04	off	0.05
28	off	0.03	off	0.04	0.04	off	0.04
29	off	off	off	0.04	off	0.03	0.05
30	0.04	0.03	0.04	off	0.03	off	0.05
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?		<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)
All daily turbidity readings ≤ 1 NTU?		<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?
All turbidity readings < IFE ² triggers		<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No

Notes:	Carl Neville		
	SIGNATURE:		DATE: 12-3-2024
	PHONE #: (541) 997-2446		CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#:	41	00301A	Month/Year:	Nov-24	Disinfection Giardia Log Inactiv:	0.5
--------------	-------------	------	----	--------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	78	68.6	14.7	6.50	11.4	Yes	657
2	0.92	78	71.8	14.7	6.50	11.4	Yes	602
3	0.88	78	68.6	14.4	6.40	11.2	Yes	619
4	0.81	78	63.2	14.3	6.50	11.6	Yes	655
5	0.86	78	67.1	14.0	6.50	11.9	yes	619
6	0.86	78	67.1	13.8	6.40	11.6	yes	622
7	0.89	78	69.4	13.9	6.50	12.0	yes	673
8	0.89	78	69.4	13.8	6.50	12.1	yes	597
9	0.88	78	68.6	13.6	6.40	11.8	yes	627
10	0.85	78	66.3	13.7	6.40	11.7	yes	635
11	0.85	78	66.3	13.5	6.40	11.8	yes	626
12	0.83	78	64.7	13.4	6.50	12.3	Yes	612
13	0.85	78	66.3	13.2	6.50	12.5	Yes	656
14	0.89	78	69.4	13.1	6.40	12.2	Yes	583
15	0.9	78	70.2	12.8	6.40	12.5	Yes	674
16	0.95	78	74.1	12.7	6.50	13.1	Yes	617
17	0.9	78	70.2	12.6	6.40	12.6	Yes	594
18	0.92	78	71.8	12.3	6.40	13.5	yes	609
19	0.91	78	71.0	12.0	6.40	13.7	yes	600
20	0.9	78	70.2	11.8	6.40	13.9	yes	615
21	0.89	78	69.4	11.6	6.30	13.6	yes	596
22	0.91	78	71.0	11.7	6.40	14.0	yes	656
23	0.9	78	70.2	11.7	6.30	13.5	yes	584
24	0.85	78	66.3	11.5	6.30	13.6	yes	579
25	0.77	78	60.1	11.4	6.30	13.6	Yes	602
26	0.78	78	60.8	11.3	6.30	13.7	Yes	696
27	0.95	78	74.1	11.2	6.50	15.0	Yes	687
28	0.97	78	75.7	11.0	6.50	15.2	Yes	671
29	0.95	78	74.1	10.7	6.40	15.0	Yes	674
30	0.95	78	74.1	10.5	6.50	15.7	Yes	615
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012