

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Lane
 Month/Year: Jan-25

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A			WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.04	off	off	0.04	off	off	0.20	
2	0.03	off	off	0.04	0.04	off	0.10	
3	off	off	0.06	off	0.04	off	0.20	
4	0.04	off	0.04	0.04	off	off	0.07	
5	0.07	off	off	0.04	off	off	0.20	
6	0.04	off	off	0.04	off	off	0.16	
7	0.04	off	off	0.04	off	off	0.05	
8	0.03	off	off	0.03	off	off	0.06	
9	0.03	off	off	0.03	off	off	0.05	
10	0.03	off	off	0.04	off	0.04	0.06	
11	0.05	0.04	0.03	off	0.04	off	0.05	
12	off	off	off	0.04	off	off	0.05	
13	0.04	off	off	0.04	0.04	off	0.05	
14	off	off	0.04	off	off	0.04	0.10	
15	off	off	off	0.04	off	off	0.06	
16	off	0.03	off	0.04	off	off	0.13	
17	0.04	off	off	0.04	off	0.03	0.06	
18	0.04	0.04	0.04	off	0.04	off	0.06	
19	off	off	0.04	0.04	off	off	0.06	
20	0.04	off	off	0.04	off	off	0.06	
21	0.04	off	off	0.04	off	off	0.05	
22	0.04	off	off	0.04	0.04	off	0.05	
23	off	off	0.05	off	0.04	off	0.06	
24	off	off	0.04	off	off	0.04	0.07	
25	0.04	0.04	0.04	off	0.04	off	0.06	
26	off	off	off	0.04	off	off	0.06	
27	0.04	off	off	0.04	off	off	0.05	
28	off	0.04	off	0.04	off	off	0.06	
29	0.04	off	off	0.05	0.05	off	0.06	
30	off	off	0.04	0.04	off	off	0.06	
31	0.04	off	off	0.04	off	0.04	0.07	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 2-3-2025
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Jan-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------	---------	--------	-------------	--------	------------------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.9	78	70.2	9.7	6.50	16.4	Yes	608
2	0.94	78	73.3	9.9	6.70	17.4	Yes	621
3	0.94	78	73.3	10.0	6.80	17.9	Yes	587
4	0.94	78	73.3	9.9	6.80	18.0	Yes	643
5	0.89	78	69.4	10.1	6.70	17.1	Yes	614
6	0.9	78	70.2	10.2	6.40	15.4	Yes	589
7	0.91	78	71.0	10.1	6.80	17.7	Yes	585
8	0.92	78	71.8	9.9	7.00	19.2	Yes	657
9	0.9	78	70.2	9.9	6.60	16.7	Yes	597
10	0.96	78	74.9	9.9	6.90	18.7	Yes	669
11	0.97	78	75.7	9.8	6.50	16.4	Yes	623
12	0.95	78	74.1	9.7	6.60	17.1	Yes	582
13	0.99	78	77.2	9.6	6.70	17.8	Yes	633
14	1	78	78.0	9.5	6.60	17.4	Yes	579
15	1.02	78	79.6	9.7	6.50	16.6	Yes	637
16	0.98	78	76.4	9.7	6.60	17.1	Yes	592
17	1.02	78	79.6	9.5	6.90	19.3	Yes	664
18	1.04	78	81.1	9.2	6.90	19.7	Yes	606
19	1.02	78	79.6	8.9	6.70	18.7	Yes	596
20	0.97	78	75.7	9.2	7.40	23.3	Yes	610
21	0.99	78	77.2	9.0	6.50	17.3	Yes	613
22	0.99	78	77.2	8.2	6.50	18.2	Yes	659
23	1	78	78.0	8.2	6.60	18.9	Yes	634
24	0.95	78	74.1	8.3	6.60	18.7	Yes	656
25	0.99	78	77.2	8.1	6.50	18.3	Yes	612
26	0.94	78	73.3	7.9	6.60	19.1	Yes	592
27	0.97	78	75.7	8.1	6.60	18.9	Yes	599
28	1	78	78.0	7.9	6.60	19.3	Yes	606
29	1	78	78.0	7.7	6.60	19.5	Yes	665
30	0.88	78	68.6	7.8	6.50	18.5	Yes	568
31	0.87	78	67.9	8.0	6.70	19.5	Yes	671

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012