

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Lane**
 Month/Year: **Feb-25**

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A			WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.04	0.04	0.05	off	off	0.05	0.07	
2	off	off	off	0.04	off	off	0.06	
3	0.04	off	off	off	0.05	off	0.10	
4	off	off	0.05	0.04	off	off	0.10	
5	0.04	off	off	0.04	0.04	off	0.17	
6	off	0.04	off	0.04	0.06	off	0.20	
7	off	off	0.04	0.05	off	0.05	0.20	
8	0.05	0.04	0.04	off	off	0.04	0.17	
9	off	off	off	0.05	off	off	0.20	
10	0.04	off	off	off	0.05	0.06	0.20	
11	off	off	0.04	0.05	off	off	0.13	
12	0.05	off	off	0.05	0.05	off	0.09	
13	off	0.05	off	0.05	0.05	off	0.06	
14	off	0.04	0.05	off	0.05	0.05	0.06	
15	0.05	0.05	0.05	0.05	off	off	0.06	
16	0.05	off	off	0.05	off	off	0.07	
17	0.05	off	off	0.05	off	off	0.07	
18	0.05	off	off	0.05	0.05	off	0.07	
19	off	0.04	off	0.05	off	off	0.11	
20	0.04	off	off	off	off	0.05	0.07	
21	off	off	0.04	0.05	off	0.05	0.07	
22	0.06	0.05	0.05	0.06	off	off	0.07	
23	0.06	off	off	0.05	off	off	0.07	
24	0.05	off	off	0.04	0.05	0.05	0.18	
25	off	off	0.05	0.05	off	0.04	0.06	
26	off	off	0.04	0.06	0.06	off	0.06	
27	off	off	0.05	off	off	0.05	0.07	
28	off	off	off	0.05	0.05	0.05	0.08	
29								
30								
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 3-3-2025
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Heceta WPUD					ID#: 41	00301A	Month/Year: Feb-25	WTP - : 0301A	Disinfection <i>Giardia</i> Log Inactiv: 0.5
---------------------------------	--	--	--	--	----------------	---------------	---------------------------	----------------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.88	78	68.6	8.0	6.50	18.2	Yes	585
2	0.85	78	66.3	7.9	6.60	18.9	Yes	608
3	0.88	78	68.6	7.7	6.60	19.2	Yes	609
4	0.9	78	70.2	7.5	6.40	18.2	Yes	591
5	0.9	78	70.2	7.4	6.40	18.4	Yes	575
6	0.92	78	71.8	7.3	6.50	19.2	Yes	646
7	0.92	78	71.8	7.2	6.40	18.6	Yes	655
8	0.92	78	71.8	7.5	6.40	18.3	Yes	609
9	0.92	78	71.8	7.5	6.40	18.3	Yes	595
10	0.92	78	71.8	7.5	6.40	18.3	Yes	600
11	0.92	78	71.8	7.3	6.50	19.2	Yes	607
12	0.93	78	72.5	7.0	6.60	20.3	Yes	665
13	0.91	78	71.0	7.0	7.10	24.1	Yes	663
14	0.91	78	71.0	7.2	6.60	20.0	Yes	580
15	0.94	78	73.3	7.3	6.60	19.9	Yes	593
16	0.92	78	71.8	7.6	6.60	19.5	Yes	610
17	0.93	78	72.5	7.8	6.60	19.2	Yes	597
18	0.93	78	72.5	7.8	6.70	19.9	Yes	685
19	0.95	78	74.1	7.9	7.10	22.8	Yes	627
20	0.97	78	75.7	7.9	6.80	20.6	yes	677
21	0.97	78	75.7	8.0	6.60	19.1	Yes	662
22	1.05	78	81.9	8.0	6.50	18.6	Yes	591
23	1.08	78	84.2	8.4	6.60	18.8	Yes	605
24	1.09	78	85.0	8.5	6.60	18.7	Yes	677
25	1.01	78	78.8	8.5	6.50	17.9	Yes	618
26	0.99	78	77.2	8.6	6.50	17.8	Yes	601
27	0.99	78	77.2	8.8	6.50	17.5	Yes	601
28	0.96	78	74.9	9.0	6.50	17.3	Yes	626
29	0.88	78	68.6	9.0	6.60	17.7	Yes	640
30			0.0			4.2		
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.