

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: **Lane**
Month/Year: **Mar-25**

System Name: Haceta WPUD		ID#: 41		00301A		WTP : TP - 00301A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.05	0.05	0.06	off	off	0.06
2	0.05	off	off	0.06	0.06	0.05	0.18
3	off	0.05	0.05	off	0.18	0.05	0.20
4	off	off	0.05	0.05	0.04	0.05	0.20
5	off	0.04	off	0.04	0.05	0.05	0.06
6	off	off	0.05	0.05	off	0.04	0.08
7	0.05	off	0.04	0.04	0.04	0.04	0.07
8	0.04	0.04	0.06	0.05	0.05	off	0.06
9	off	0.05	off	0.05	0.05	off	0.07
10	0.04	off	0.04	0.05	0.05	off	0.18
11	0.05	off	0.04	0.04	0.04	off	0.07
12	0.05	off	0.04	off	0.04	off	0.07
13	off	off	off	0.04	off	off	0.06
14	off	off	off	0.04	off	off	0.06
15	0.04	0.04	0.04	0.04	off	0.04	0.07
16	0.04	off	off	0.05	0.04	off	0.06
17	0.05	off	off	0.04	0.04	0.04	0.06
18	off	off	off	0.04	off	off	0.06
19	0.04	off	off	0.04	0.04	off	0.06
20	off	off	0.04	off	off	0.04	0.07
21	0.05	off	off	0.05	off	0.04	0.06
22	0.04	0.04	0.05	0.05	off	off	0.06
23	0.05	off	off	0.05	off	off	0.06
24	0.05	off	off	0.06	0.05	off	0.07
25	off	0.04	off	off	0.06	0.05	0.11
26	off	off	0.04	0.05	0.04	off	0.18
27	off	0.07	0.04	off	0.05	off	0.12
28	off	off	0.05	off	off	0.04	0.09
29	0.04	off	0.05	0.05	off	off	0.20
30	0.05	off	off	0.05	0.05	off	0.20
31	off	off	off	0.05	off	off	0.08

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU? ☒ Yes / No All daily turbidity readings $\leq$ 1 NTU? ☒ Yes / No All turbidity readings < IFE ² triggers ☒ Yes / No		CT's met everyday? (see back) ☒ Yes / No	All Cl2 residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / No
Notes:		Carl Neville	
		SIGNATURE:	
		DATE: 4-1-2025	
		PHONE #: (541) 997-2446	
		CERT #: FE0103	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	78	68.6	9.0	6.60	17.7	Yes	640
2	0.87	78	67.9	8.9	6.60	17.8	Yes	639
3	0.9	78	70.2	9.2	6.70	18.1	Yes	622
4	0.9	78	70.2	9.4	6.60	17.3	Yes	598
5	0.91	78	71.0	9.4	6.60	17.3	Yes	672
6	0.91	78	71.0	9.9	6.60	16.8	Yes	628
7	0.89	78	69.4	9.9	6.60	16.7	Yes	621
8	0.94	78	73.3	10.0	7.10	19.8	Yes	620
9	0.91	78	71.0	9.9	6.90	18.6	Yes	657
10	0.91	78	71.0	9.8	6.80	18.1	Yes	631
11	0.94	78	73.3	10.1	7.00	19.0	Yes	635
12	0.94	78	73.3	10.1	6.60	16.6	Yes	638
13	0.88	78	68.6	9.8	6.40	15.7	Yes	606
14	0.88	78	68.6	9.7	6.50	16.4	Yes	663
15	0.89	78	69.4	9.8	6.40	15.7	Yes	612
16	0.85	78	66.3	9.7	6.50	16.3	Yes	631
17	0.85	78	66.3	9.3	6.40	16.2	Yes	658
18	0.83	78	64.7	9.5	6.50	16.5	Yes	601
19	0.9	78	70.2	9.6	6.60	17.1	Yes	611
20	0.95	78	74.1	9.6	6.90	19.0	Yes	609
21	0.96	78	74.9	9.5	7.00	19.8	Yes	663
22	0.97	78	75.7	9.5	6.50	16.7	Yes	607
23	0.97	78	75.7	9.7	6.50	16.5	Yes	617
24	0.95	78	74.1	10.0	6.70	17.3	Yes	679
25	0.95	78	74.1	10.5	6.80	17.3	Yes	614
26	0.93	78	72.5	10.6	6.50	15.5	Yes	602
27	0.95	78	74.1	10.3	6.50	15.9	Yes	616
28	0.95	78	74.1	10.3	6.70	17.0	Yes	663
29	0.97	78	75.7	10.4	6.50	15.8	Yes	611
30	0.95	78	74.1	10.7	6.50	15.5	Yes	613
31	0.93	78	72.5	10.4	6.70	16.8	Yes	616

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012