

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: **Lane**
Month/Year: **Apr-25**

System Name: Haceta WPUD		ID#: 41		00301A		WTP : TP - 00301A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	off	off	0.04	0.05	off	0.08
2	off	0.04	off	0.04	0.05	off	0.06
3	off	0.04	off	0.04	0.05	0.05	0.07
4	off	off	0.04	0.04	off	0.05	0.07
5	0.04	0.04	0.04	0.05	off	0.05	0.06
6	0.05	off	off	0.05	0.05	off	0.06
7	0.04	off	off	0.04	off	off	0.06
8	0.04	off	off	0.04	0.04	off	0.06
9	off	off	0.05	off	0.05	0.05	0.08
10	off	off	0.05	0.05	off	off	0.08
11	0.08	off	off	0.05	off	0.05	0.08
12	0.05	0.05	0.04	0.05	off	off	0.08
13	0.05	off	off	0.05	off	off	0.07
14	0.04	off	off	0.04	0.05	off	0.06
15	off	0.06	0.04	off	off	0.05	0.06
16	off	off	off	0.04	0.05	0.04	0.06
17	off	off	off	0.05	0.05	0.05	0.06
18	0.04	off	off	0.04	0.04	0.04	0.06
19	0.04	0.04	off	0.05	0.04	off	0.06
20	0.04	off	off	0.05	off	off	0.06
21	0.04	off	off	0.04	0.05	off	0.06
22	off	0.04	off	0.04	0.04	off	0.07
23	off	0.04	off	0.04	0.04	0.04	0.05
24	off	off	0.04	0.04	0.04	0.04	0.06
25	off	off	0.03	0.04	0.04	0.04	0.05
26	0.05	off	0.04	0.04	off	off	0.05
27	0.04	off	off	0.05	0.04	off	0.06
28	off	0.04	off	0.04	0.05	0.05	0.10
29	off	off	0.05	0.05	0.05	0.05	0.06
30	off	off	0.04	0.04	0.05	0.05	0.06
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		
Notes:		Carl Neville	
		SIGNATURE: _____	
		DATE: _____	
		PHONE #: (541) 997-2446	
		CERT #: FE0103	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	Apr-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	78	70.2	10.4	6.60	16.2	Yes	626
2	0.94	78	73.3	10.7	6.60	16.0	Yes	626
3	0.95	78	74.1	11.0	6.90	17.4	Yes	676
4	0.97	78	75.7	11.2	6.80	16.6	Yes	638
5	0.97	78	75.7	11.5	6.60	15.2	Yes	620
6	0.94	78	73.3	11.9	6.50	14.3	Yes	648
7	0.94	78	73.3	11.9	6.40	13.9	Yes	630
8	0.94	78	73.3	11.6	6.60	15.1	Yes	618
9	0.93	78	72.5	11.6	7.00	17.3	Yes	673
10	0.93	78	72.5	11.9	6.50	14.3	Yes	593
11	0.94	78	73.3	12.0	6.60	14.7	Yes	662
12	0.96	78	74.9	12.2	6.50	14.1	Yes	607
13	0.92	78	71.8	12.1	6.60	14.6	Yes	636
14	0.91	78	71.0	12.5	6.50	13.2	Yes	612
15	0.92	78	71.8	13.0	6.50	12.8	Yes	586
16	0.9	78	70.2	13.3	6.50	12.5	Yes	615
17	0.9	78	70.2	13.5	6.80	13.8	Yes	647
18	0.9	78	70.2	14.0	6.80	13.4	Yes	639
19	0.94	78	73.3	14.3	7.00	14.2	Yes	633
20	0.9	78	70.2	14.1	7.00	14.3	Yes	632
21	0.88	78	68.6	14.1	6.70	12.8	Yes	628
22	0.99	78	77.2	14.1	6.90	13.9	Yes	628
23	0.88	78	68.6	14.1	7.10	14.8	Yes	645
24	0.87	78	67.9	14.4	7.10	14.5	Yes	601
25	0.86	78	67.1	14.5	7.00	13.9	Yes	613
26	0.91	78	71.0	14.5	6.90	13.4	Yes	662
27	0.86	78	67.1	14.3	6.80	13.0	Yes	626
28	0.87	78	67.9	14.6	6.80	12.8	Yes	602
29	0.84	78	65.5	14.8	6.90	13.1	Yes	630
30	0.84	78	65.5	14.9	7.10	14.0	Yes	628
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012