

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: **Lane**
Month/Year: **May-25**

System Name: Haceta WPUD		ID#: 41		00301A		WTP : TP - 00301A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.04	0.05	0.05	off	0.06
2	0.04	off	off	0.05	0.05	0.05	0.07
3	0.05	off	0.04	0.05	0.05	off	0.09
4	off	off	0.04	0.05	off	0.05	0.06
5	0.05	off	off	0.05	0.04	0.04	0.06
6	0.04	off	0.05	0.05	0.05	off	0.10
7	off	0.04	0.05	0.05	0.05	0.05	0.07
8	off	off	0.05	0.05	0.06	0.05	0.07
9	off	off	0.05	0.05	0.05	0.05	0.07
10	0.05	0.05	0.05	0.05	0.05	off	0.09
11	off	0.05	off	0.05	off	off	0.07
12	0.06	off	0.05	0.05	off	off	0.08
13	0.06	off	0.05	0.06	0.06	0.07	0.10
14	off	off	0.05	0.06	0.06	0.06	0.07
15	off	off	0.05	0.06	0.06	off	0.07
16	off	0.05	off	0.05	off	0.05	0.08
17	0.06	0.05	0.05	0.05	off	off	0.10
18	0.05	off	off	0.05	0.05	off	0.11
19	off	0.05	off	0.05	0.05	off	0.08
20	off	0.04	0.05	0.05	off	off	0.08
21	0.04	off	0.04	0.04	0.05	0.04	0.08
22	off	off	0.04	0.04	0.04	off	0.09
23	0.04	off	0.04	0.04	off	0.04	0.05
24	0.04	0.04	0.05	0.04	0.04	off	0.09
25	0.04	off	0.04	0.04	0.04	off	0.05
26	off	off	off	0.04	0.04	off	0.05
27	off	0.03	0.03	0.04	0.04	0.04	0.07
28	off	off	0.04	0.04	0.04	0.04	0.06
29	off	off	0.04	0.03	0.04	0.04	0.06
30	off	off	0.04	0.03	off	0.03	0.06
31	0.04	0.04	0.05	0.04	0.04	off	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		
Notes:		Carl Neville	
		SIGNATURE:	
		DATE: 6-3-2025	
		PHONE #: (541) 997-2446	
		CERT #: FE0103	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	May-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.95	78	74.1	15.0	6.50	11.2	Yes	599
2	0.93	78	72.5	15.5	6.80	12.1	Yes	644
3	0.98	78	76.4	15.5	6.90	12.7	Yes	671
4	0.95	78	74.1	15.5	6.60	11.3	Yes	612
5	0.94	78	73.3	15.6	6.50	10.8	Yes	655
6	0.95	78	74.1	16.1	6.60	10.8	Yes	625
7	0.95	78	74.1	16.5	7.30	13.7	Yes	628
8	0.92	78	71.8	16.1	7.10	13.0	Yes	632
9	0.92	78	71.8	16.4	6.70	11.0	Yes	621
10	0.98	78	76.4	16.9	6.50	9.9	Yes	507
11	0.93	78	72.5	16.8	6.90	11.5	Yes	616
12	0.91	78	71.0	16.4	6.80	11.4	Yes	631
13	0.89	78	69.4	16.3	6.70	11.0	Yes	621
14	0.9	78	70.2	16.5	6.80	11.3	Yes	626
15	0.89	78	69.4	16.7	7.00	12.0	Yes	631
16	0.89	78	69.4	16.6	6.60	10.4	Yes	674
17	0.89	78	69.4	16.7	6.50	9.9	Yes	611
18	0.86	78	67.1	16.7	6.50	9.9	Yes	648
19	0.87	78	67.9	16.7	6.70	10.7	Yes	640
20	0.93	78	72.5	16.7	6.40	9.6	Yes	592
21	0.94	78	73.3	16.8	6.40	9.6	Yes	636
22	0.95	78	74.1	17.0	6.90	11.4	Yes	621
23	0.97	78	75.7	17.0	6.80	11.0	Yes	669
24	0.97	78	75.7	17.3	6.50	9.6	Yes	613
25	0.95	78	74.1	17.5	6.60	9.9	Yes	668
26	0.95	78	74.1	17.5	6.60	9.9	Yes	647
27	0.93	78	72.5	17.9	6.70	9.9	Yes	620
28	0.92	78	71.8	18.2	6.50	9.0	Yes	662
29	0.92	78	71.8	18.1	6.80	10.2	Yes	662
30	0.95	78	74.1	18.6	6.80	9.9	Yes	667
31	0.94	78	73.3	19.2	6.50	8.4	Yes	607

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012