

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Lane

Month/Year:

Jun-25

System Name:		Haceta WPUD		ID#: 41		00301A		WTP : TP -		00301A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]				
1	0.04	off	0.03	0.03	0.03	off	0.05				
2	0.03	off	0.03	0.03	0.04	0.03	0.05				
3	off	off	0.04	0.04	0.04	0.04	0.05				
4	0.04	off	0.04	0.04	0.04	0.04	0.05				
5	off	off	0.04	0.04	0.04	0.04	0.05				
6	off	off	0.03	0.04	0.04	0.04	0.05				
7	0.04	0.04	0.04	0.04	0.04	0.04	0.06				
8	0.03	off	0.04	0.03	0.04	0.03	0.05				
9	off	0.03	0.03	0.03	0.03	0.03	0.04				
10	off	0.03	0.03	0.03	0.03	0.03	0.04				
11	0.03	0.03	0.04	0.03	0.03	0.03	0.04				
12	off	0.04	0.03	0.03	0.03	off	0.04				
13	0.03	off	0.03	0.03	0.03	0.03	0.04				
14	off	0.03	0.03	0.02	0.03	0.03	0.04				
15	0.02	0.02	0.02	off	0.02	0.03	0.03				
16	off	0.03	0.02	0.02	0.02	0.02	0.04				
17	off	0.03	0.02	0.02	off	0.03	0.03				
18	0.02	off	0.02	0.03	off	0.02	0.03				
19	off	off	0.02	0.02	off	0.02	0.03				
20	off	off	0.02	0.03	0.03	off	0.03				
21	0.02	off	0.03	0.02	0.02	0.02	0.04				
22	off	off	0.02	0.02	off	0.02	0.03				
23	off	off	0.02	0.03	0.03	off	0.03				
24	0.02	off	0.03	0.02	0.02	0.02	0.04				
25	off	off	0.02	0.02	off	0.02	0.03				
26	off	0.03	0.02	0.02	0.02	0.02	0.03				
27	off	off	0.02	0.02	0.03	0.03	0.03				
28	0.03	off	0.02	0.02	0.02	off	0.03				
29	0.02	off	0.02	0.02	0.02	0.03	0.03				
30	off	off	0.03	off	0.03	0.02	0.03				
31											

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		
Notes:		Carl Neville	
		SIGNATURE:	
		PHONE #: (541) 997-2446	
		DATE: 7-2-2025	
		CERT #: FE0103	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - :
0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Jun-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
---------------------	--------------------	----------------	---------------	--------------------	---------------	---	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.91	78	71.0	19.0	6.50	8.5	Yes	663
2	0.91	78	71.0	18.8	6.70	9.3	Yes	659
3	0.99	78	77.2	18.8	6.40	8.4	Yes	630
4	0.93	78	72.5	19.1	6.70	9.2	Yes	620
5	0.92	78	71.8	19.0	6.70	9.2	Yes	605
6	0.92	78	71.8	19.2	6.50	8.4	Yes	525
7	0.97	78	75.7	19.6	6.40	7.9	Yes	697
8	0.95	78	74.1	19.8	6.40	7.8	Yes	656
9	0.88	78	68.6	20.4	6.50	7.7	yes	650
10	0.88	78	68.6	20.7	6.70	8.2	Yes	589
11	0.9	78	70.2	20.6	6.40	7.4	Yes	648
12	0.85	78	66.3	20.3	6.40	7.5	Yes	631
13	0.91	78	71.0	20.1	6.40	7.6	Yes	641
14	0.93	78	72.5	19.6	6.40	7.9	Yes	671
15	0.88	78	68.6	19.3	6.40	8.0	Yes	640
16	0.91	78	71.0	19.5	6.20	7.4	Yes	694
17	0.9	78	70.2	19.8	6.30	7.5	Yes	663
18	0.85	78	66.3	20.0	6.90	9.2	Yes	581
19	0.83	78	64.7	19.8	6.40	7.7	Yes	625
20	0.89	78	69.4	19.8	6.50	8.1	Yes	641
21	0.91	78	71.0	19.5	6.40	7.9	Yes	650
22	0.93	78	72.5	19.0	6.30	7.9	Yes	583
23	0.87	78	67.9	19.1	7.00	10.2	Yes	624
24	0.94	78	73.3	19.3	6.30	7.8	Yes	654
25	0.9	78	70.2	19.5	6.30	7.6	Yes	648
26	0.87	78	67.9	19.6	6.70	8.8	yes	609
27	0.9	78	70.2	19.7	6.30	7.5	Yes	690
28	0.9	78	70.2	20.3	6.30	7.2	Yes	681
29	0.88	78	68.6	20.5	7.00	9.3	Yes	610
30	0.96	78	74.9	20.7	6.30	7.1	Yes	673
31			0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012