

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Lane

Conventional or Direct Filtration

Month/Year:

Jul-25

System Name:		Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
2	off	off	0.03	0.02	0.02	0.02	0.03	
3	0.02	off	0.02	0.02	0.03	0.02	0.03	
4	off	0.02	0.02	0.02	0.02	0.02	0.03	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
6	0.02	off	0.02	0.03	0.03	0.03	0.03	
7	0.03	off	off	0.02	0.02	0.02	0.03	
8	0.02	0.02	0.03	0.02	0.02	0.02	0.03	
9	0.02	off	0.03	0.02	0.03	0.03	0.03	
10	0.02	off	0.02	0.02	0.02	0.02	0.03	
11	off	off	0.03	0.03	0.03	0.02	0.03	
12	0.02	0.02	0.02	0.02	0.02	off	0.03	
13	0.02	off	0.02	0.02	0.02	0.02	0.03	
14	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
15	off	off	0.02	0.02	0.02	0.02	0.03	
16	0.02	off	0.02	0.02	0.02	0.02	0.04	
17	0.02	off	0.03	0.03	0.03	0.02	0.04	
18	off	0.02	0.02	0.02	0.02	0.02	0.03	
19	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
20	off	off	0.02	0.02	0.02	off	0.03	
21	0.02	off	0.02	0.02	0.02	0.02	0.03	
22	0.02	0.02	0.02	0.02	0.02	0.02	0.04	
23	off	0.03	0.02	0.02	0.02	0.02	0.04	
24	off	0.02	0.02	0.02	0.02	0.02	0.03	
25	off	0.03	0.02	0.02	0.02	0.03	0.03	
26	0.02	0.02	0.03	0.02	0.03	0.02	0.03	
27	0.03	off	0.02	0.02	0.02	0.02	0.03	
28	off	0.03	0.02	0.02	0.02	0.02	0.03	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
30	0.02	off	0.02	0.02	0.02	0.02	0.03	
31	off	0.02	0.02	0.02	0.03	0.02	0.03	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 8-1-2025
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.98	78	76.4	21.3	6.30	6.8	Yes	636
2	0.97	78	75.7	21.1	6.30	6.9	Yes	692
3	0.96	78	74.9	21.2	6.30	6.8	Yes	645
4	0.95	78	74.1	21.0	6.30	6.9	Yes	683
5	0.96	78	74.9	21.0	6.30	6.9	Yes	693
6	0.96	78	74.9	21.1	6.30	6.9	Yes	681
7	0.97	78	75.7	21.4	6.30	6.8	Yes	699
8	1.03	78	80.3	21.3	6.30	6.8	Yes	670
9	1.02	78	79.6	21.1	7.10	9.4	Yes	606
10	1.04	78	81.1	21.4	6.30	6.8	Yes	696
11	0.9	78	70.2	21.8	6.30	6.5	Yes	666
12	0.91	78	71.0	21.8	6.30	6.5	Yes	678
13	0.91	78	71.0	21.8	6.30	6.5	Yes	691
14	0.95	78	74.1	22.2	6.10	5.9	Yes	626
15	0.93	78	72.5	22.0	6.30	6.5	Yes	691
16	0.94	78	73.3	22.2	6.30	6.4	Yes	697
17	0.95	78	74.1	22.2	6.30	6.4	Yes	664
18	0.97	78	75.7	22.2	6.30	6.4	Yes	689
19	0.95	78	74.1	22.2	6.30	6.4	Yes	657
20	0.95	78	74.1	22.0	6.30	6.5	Yes	690
21	0.93	78	72.5	21.9	6.30	6.5	Yes	663
22	0.95	78	74.1	21.9	6.30	6.5	Yes	699
23	0.94	78	73.3	21.9	6.30	6.5	Yes	684
24	0.94	78	73.3	21.9	6.30	6.5	Yes	698
25	0.93	78	72.5	21.8	6.30	6.5	Yes	692
26	0.94	78	73.3	22.0	6.30	6.5	Yes	699
27	0.93	78	72.5	21.8	6.30	6.5	Yes	687
28	0.95	78	74.1	21.8	6.20	6.3	Yes	626
29	0.95	78	74.1	22.0	6.30	6.5	Yes	691
30	0.91	78	71.0	22.0	6.30	6.4	Yes	694
31	0.92	78	71.8	22.1	6.30	6.4	Yes	632

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012